





# **Design and Operations (D&O) Report**

**Grimsby Anaerobic Digestion Site**

ESCARPMENT RENEWABLES

August 27, 2024

<b>Project name</b>		ESCARPMENT-Grimsby AD Permitting					
<b>Document title</b>		Design and Operations (D&O) Report   Grimsby Anaerobic Digestion Site					
<b>Project number</b>		11226032					
<b>File name</b>		Revised December 6-11226032-RPT-3-Design and Operations Report-Revised.docx					
Status Code	Revision	Author	Reviewer		Approved for issue		
			Name	Signature	Name	Signature	Date
S4	00	Dan Turner	Jason Wilson		Victoria Shortreed		Nov. 10, 2023
S4	01	Dan Turner	Jason Wilson		Victoria Shortreed		Aug 27, 2024

**GHD**

Contact: Jason Wilson, Engineer in Training | GHD

455 Phillip Street, Unit 100A

Waterloo, Ontario N2L 3X2, Canada

T +1 519 884 0510 | F +1 519 884 0525 | E info-northamerica@ghd.com | [ghd.com](http://ghd.com)

© GHD 2024

This document is and shall remain the property of GHD. The document may only be used for the purpose for which it was commissioned and in accordance with the Terms of Engagement for the commission. Unauthorised use of this document in any form whatsoever is prohibited.

# Executive summary

The Design and Operations Report has been prepared in accordance with Table E.1 of Ontario Regulation 359/09. A summary of where information is contained in this report as it relates to these requirements is provided below.

**Table E.1** Ontario Regulation 359/09 Compliance Summary

Requirements	Location in Report
Set out a site plan of the project location at which the renewable energy project will be engaged in, including:	
i. One or more maps or diagrams of,	
A. all buildings, structures, roads, utility corridors, rights of way and easements required in respect of the renewable energy generation facility and situated within 300 metres of the facility,	Figure 3
B. any ground water and surface water supplies used at the facility,	Surface water collected in the secondary containment features per Section 3.3.
C. any things from which contaminants are discharged into the air,	Appendix A
D. any works for the collection, transmission, treatment and disposal of sewage,	Not Applicable
E. any areas where waste, biomass, source separated organics and farm material are stored, handled, processed or disposed of,	Figure 3
F. the project location in relation to any of the following within 125 metres: the portion of the Oak Ridges Moraine Conservation Plan Area that is subject to the Oak Ridges Moraine Conservation Plan, the area of the Niagara Escarpment Plan, the Protected Countryside, the Lake Simcoe watershed, and	Not Applicable
G. any noise receptors or odour receptors that may be negatively affected by the use or operation of the facility,	Appendix B and Appendix C
ii. a description of each item diagrammed under subparagraph i,	
A. all buildings, structures, roads, utility corridors, rights of way and easements required in respect of the renewable energy generation facility and situated within 300 metres of the facility,	Section 2
B. any ground water and surface water supplies used at the facility,	Section 3.3
C. any things from which contaminants are discharged into the air,	Section 3.4
D. any works for the collection, transmission, treatment and disposal of sewage,	Not Applicable
E. any areas where waste, biomass, source separated organics and farm material are stored, handled, processed or disposed of,	Section 2.2, 2.3, 2.4 and 2.5
F. the project location in relation to any of the following within 125 metres: the portion of the Oak Ridges Moraine Conservation Plan Area that is subject to the Oak Ridges Moraine Conservation Plan, the area of the Niagara Escarpment Plan, the Protected Countryside, the Lake Simcoe watershed, and	Not Applicable
G. any noise receptors or odour receptors that may be negatively affected by the use or operation of the facility,	Section 3.4 Section 3.5
iii. one or more maps or diagrams of land contours, surface water drainage and any of the following, if they have been identified in complying with this Regulation: properties described in Column 1 of the Table to section 19, heritage resources, archaeological resources, water bodies, significant or provincially significant natural features and any other natural features identified in the Protected Countryside or in the portion of the Oak Ridges Moraine Conservation Plan Area that is subject to the Oak Ridges Moraine Plan,	Not Applicable

iv. a description, map or diagram of the distance between the base of any wind turbines and any public road rights of way or railway rights of way that are within a distance equivalent to the length of any blades of the wind turbine, plus 10 metres,	Not Applicable
v. a description, map or diagram of the distance between the base of any wind turbines and all boundaries of the parcel of land on which the wind turbine is constructed, installed or expanded within a distance equivalent to the height of the wind turbine, excluding the length of any blades, and	Not Applicable
vi. a description, map or diagram of the distance between the base of each wind turbine and the nearest noise receptor.	Not Applicable
2. Set out conceptual plans, specifications and descriptions related to the design of the renewable energy generation facility, including a description of,	Section 4
i. any works for the collection, transmission, treatment and disposal of sewage, including details of any sediment control features and storm water management facilities,	
ii. any things from which contaminants are discharged into the air,	Section 3.4
iii. any systems, facilities and equipment for receiving, handling, storing and processing any waste, biomass, source separated organics, farm material and biogas, and	Section 2.2, 2.3, 2.4 and 2.5
iv. if the facility includes a transformer substation, the works, facilities and equipment for secondary spill containment.	Section 3.3
3. Set out conceptual plans, specifications and descriptions related to the operation of the renewable energy generation facility, including,	
i. in respect of any water takings,	Section 3.3
A. a description of the time period and duration of water takings expected to be associated with the operation of the facility,	Section 3.3
B. a description of the expected water takings, including rates, amounts and an assessment of the availability of water to meet the expected demand, and	Section 3.3
C. an assessment of and documentation showing the potential for the facility to interfere with existing uses of the water expected to be taken,	Section 3.3
ii. a description of the expected quantity of sewage produced and the expected quality of that sewage at the project location and the manner in which it will be disposed of, including details of any sediment control features and storm water management facilities,	Not Applicable
iii. a description of any expected concentration of air contaminants discharged from the facility,	Section 3.4
iv. in respect of any biomass, source separated organics and farm material at the facility,	
A. the maximum daily quantity that will be accepted,	Section 2.2
B. the estimated annual average quantity that will be accepted,	Section 2.2
C. the estimated average time that it will remain at the facility, and	Section 2.2.3
D. the estimated average rate at which it will be used,	Table 2-2
v. in respect of any waste generated as a result of processes at the project location, the management and disposal of such waste, including,	
A. the expected types of waste to be generated,	Sections 2.2.3 and 2.4
B. the estimated annual average quantity that will be accepted,	Section 2.2.3
C. the estimated average time that it will remain at the facility, and	Section 2.2.3
D. the estimated average rate at which it will be used,	Section 2.2.3
vi. if the facility includes a transformer substation,	
A. a description of the processes in place to prevent spills,	Section 3.3
B. a description of the processes to prevent, eliminate or ameliorate any adverse effects in the event of a spill, and	Section 3.3

C. a description of the processes to restore the natural environment in the event of a spill.	Section 3.3
4. Include an environmental effects monitoring plan in respect of any negative environmental effects that may result from engaging in the renewable energy project, setting out,	
i. performance objectives in respect of the negative environmental effects,	Section 5
ii. mitigation measures to assist in achieving the performance objectives mentioned in subparagraph i, and	Section 5
iii. a program for monitoring negative environmental effects for the duration of the time that the project is engaged in, including a contingency plan to be implemented if any mitigation measures fail.	Section 5.1
5. Include a response plan setting out a description of the actions to be taken while engaging in the renewable energy project to inform the public, aboriginal communities and municipalities, local roads boards and Local Services Boards with respect to the project, including,	
i. measures to provide information regarding the activities occurring at the project location, including emergencies,	Section 5.2
ii. means by which persons responsible for engaging in the project may be contacted, and	Section 5.2
iii. means by which correspondence directed to the persons responsible for engaging in the project will be recorded and addressed.	Section 5.2
6. If the project location is in the Lake Simcoe watershed, a description of whether the project requires alteration of the shore of Lake Simcoe, the shore of a fresh water estuary of a stream connected to Lake Simcoe or other lakes or any permanent or intermittent stream and,	Not Applicable
i. how the project may impact any shoreline, including the ecological functions of the shoreline, and	Not Applicable
ii. how the project will be engaged in to,	Not Applicable
A. maintain the natural contour of the shoreline through the implementation of natural shoreline treatments, such as planting of natural vegetation and bioengineering, and	Not Applicable
B. use a vegetative riparian area, unless the project location is used for agricultural purposes and will continue to be used for such purposes.	Not Applicable
7. If it is determined that the project location is not on a property described in Column 1 of the Table to section 19, provide a summary of the matters addressed in making the determination.	The Site was originally established by the Town of Grimsby. The Ministry of Heritage, Sport, Tourism and Culture Industries was contacted on August 19, 2021 to ensure the original archaeological assessment remained valid for the expansion.
8. If section 20 applies in respect of the project and it is determined that the project location does not meet one of the descriptions set out in subsection 20 (2) or that the project location is not in an area described in subsection 20 (3), provide a summary of the matters addressed in making the determination.	Not Applicable
9. If subsection 21 (3) or 23 (2) applies, provide a summary of the matters addressed in making the determination,	The Ministry of Heritage, Sport, Tourism and Culture Industries was contacted on August 19, 2021 to ensure the original archaeological assessment remained valid for the expansion.
i. under subsection 21 (3) or clause 23 (2) (a), as the case may be, including a copy of the document completed under the applicable provision, and	
ii. under clause 23 (3) (b), if applicable.	

Table E.2 below provides a Site Summary.

Table E.2 Site Summary

Parameter	Units	Value/Description
Annual total days of Receiving	Days	303
Days and Hours of Operation	Hours, Days	Monday to Saturday Shipping and Receiving Hours: 7 AM to 7 PM Operating Hours: 24 hours Digestate Shipping Hours: 5 AM to 9 PM
Seasonal Fluctuations	Yes/No	Yes, for digestate shipping only
Average Daily Amount of Waste Received	Tonnes	525
Maximum Daily Amount of Waste Received	Tonnes	Bulk solid waste – 720 Industrial, Commercial, Institutional (ICI) liquid waste – 330
Maximum Annual Amount of Waste Received	Tonnes	159,000
Maximum Waste Storage Quantity	Tonnes	Bulk solid waste – 1,220 Residual waste – 109 Liquid waste – 1,479
Annual Average Amount of Waste Destined for Final Disposal	Tonnes	24,300
Daily Maximum Amount of Waste Destined for Final Disposal	Tonnes	160
Daily Averaged on an Annual Basis Amount of Waste for Final Disposal	Tonnes	80
Environmental Assessment Act Requirements Fulfilled	Yes/No/NA	NA
Waste types	Type	Agricultural Waste
		Source Separated Organics (SSO) (pre-processed and un-processed) - Incoming
		ICI Solid waste – Incoming
		ICI liquid waste <sup>1</sup> - Incoming
		Solid, non-hazardous waste (residuals from pre-processing and digestate skimming/grit) – for final disposal
		Spent carbon – for further processing or final disposal
Density of Each Waste Type	Kilograms (kg) per cubic metres (m <sup>3</sup> )	651 - SSO
	kg/m <sup>3</sup>	850 – ICI Solid
	kg/m <sup>3</sup>	1,000 – ICI Liquid
	kg/m <sup>3</sup>	800 – Solid, nonhazardous waste (residuals)
	kg/m <sup>3</sup>	2,000 – Spent Activated Carbon
Request for Operational Flexibility	Yes/No	Yes

Notes: <sup>1</sup>Liquid ICI organic waste including but not limited to fats, oils and grease (FOG); dissolved air flotation (DAF) sludge, wastewaters from food or beverage companies and biosolids.

# Contents

<b>1.</b>	<b>Introduction</b>	<b>1</b>
1.1	Purpose	1
1.2	Project Location	1
1.3	Surrounding Land Use	1
1.4	Site Description	2
<b>2.</b>	<b>Facility Design</b>	<b>3</b>
2.1	Existing Conditions	3
2.2	Waste Receiving	4
2.2.1	Feedstock Materials	4
2.2.2	Feedstock Receiving	5
2.2.3	Incoming Waste Storage	6
2.3	Waste Pre-processing	6
2.3.1	Organics Pre-processing Building	6
2.3.2	Waste Pre-processing Units	6
2.3.3	Residual Waste	7
2.4	Digestion	8
2.4.1	Pasteurization System	8
2.4.2	Digester System	9
2.4.2.1	Plug Flow Digesters	10
2.5	Digestate Management	10
2.6	Biogas Management	10
2.6.1	Biogas Handling	10
2.6.2	Electricity	10
2.6.2.1	Engines	11
2.6.2.2	Heat Recovery	11
2.6.2.3	Switchgear	11
2.6.3	RNG	11
2.6.3.1	Biogas Pre-Treatment	11
2.6.3.2	Biogas Upgrading to Renewable Natural Gas	11
2.6.4	Flare	12
2.7	Air Treatment	12
<b>3.</b>	<b>Facility Operations</b>	<b>13</b>
3.1	Process Operations	13
3.1.1	Receiving	13
3.1.2	Pre-processing	14
3.1.3	Digestion	15
3.1.4	Biogas Management	15
3.1.5	Digestate Management	16
3.1.6	Air Treatment	16
3.1.7	Outbound Materials	16
3.2	Monitoring, Maintenance, and Reporting	16
3.2.1	Process Control	16

3.2.2	Safeguard Controls	17
3.2.3	Monitoring and Analyses	17
3.2.4	Monitoring and Testing	18
3.2.5	Preventative Maintenance	19
3.2.6	Record Keeping and Reporting	19
3.3	Secondary Containment	19
3.4	Air Emissions	21
3.4.1	Trucks	21
3.4.2	Engines/Turbines	21
3.4.3	Flare	21
3.4.4	Over-Under Pressure Valves	22
3.4.5	Receiving Tank Displacement Air	22
3.4.6	Boiler	22
3.4.7	Biofilter Stack	22
3.4.8	RNG Upgrading System Tail Gas	22
3.4.9	Digestate Loading Displacement Air	22
3.4.10	Digestate/Biogas Storage Tank Membrane Leakage	22
3.4.11	Fugitive Emissions from Organics Pre-processing Building	22
3.4.12	Emergency Generator	23
3.5	Noise Emissions	23
3.5.1	Trucks	23
3.5.2	CHP	23
3.5.3	Flare	23
3.5.4	Organics Pre-processing Building	23
3.5.5	Pump and Pasteurization Building	23
3.5.6	Tank Agitators	24
3.5.7	Digestate Skimming Buildings	24
3.5.8	Backup Generator	24
3.5.9	RNG Upgrading System and Compression Systems	24
3.6	Operating Hours	24
3.7	Staffing and Training Requirements	24
3.8	Traffic Management	25
3.9	Environmental Emergency and Contingency Plans	25
3.9.1	Emergency Contacts	25
3.9.2	Emergency Response Plans	26
3.9.3	Contingency Plans	26
3.9.3.1	Equipment Failure	26
3.9.3.2	Electrical Outage	27
3.10	Site Inspections and Nuisance Controls	27
3.10.1	Dust and Litter Control	27
3.10.2	Noise Control	27
3.10.3	Odour Prevention and Control	28
3.10.4	Odour Complaint Response	29
3.10.5	Pest Control	29
3.11	Fencing and Security	29
<b>4.</b>	<b>Stormwater Management</b>	<b>29</b>



<b>5.</b>	<b>Environmental Effects</b>	<b>30</b>
5.1	Groundwater Monitoring	31
5.2	Communications	31
<b>6.</b>	<b>Operational Flexibility</b>	<b>32</b>
<b>7.</b>	<b>Financial Assurance</b>	<b>34</b>

## Table index

Table 2.1	Feedstock Type and Maximum Annual Tonnage	4
Table 3.1	Process Monitoring	17
Table 3.2	Average Annual Precipitation	20
Table 3.3	Emergency Contacts	25
Table 5.1	Potential Environmental Effects	30
Table 6.1	Operational Flexibility Options	32
Table 6.2	Operational Envelope	33
Table 6.3	Annual Tonnage Limits by Implementation Phase	34

## Figure index

Figure 1.1	Surrounding Land Use from Town of Grimsby Official Plan	2
------------	---	---

## Tables Following Text

Table 7	Mass Balance
Table 8	Truck Traffic Estimate
Table 9	Waste Storage Calculations
Table 10	Organics Pre-Processing Building Air Changes
Table 11	Secondary Containment Calculations

## Figures Following Text

Figure 1	Site Location
Figure 2	Existing Conditions
Figure 3	Proposed Site Layout
Figure 4	Organics Pre-Processing Building Layout
Figure 5	Process Flow Diagram – Waste Receiving and Processing
Figure 6	Process Flow Diagram – Digestion
Figure 7	Process Flow Diagram – Digestate and Biogas Management

## Appendices

Appendix A	Emissions Summary and Dispersion Modelling Report
Appendix B	Odour Report
Appendix C	Acoustic Assessment report
Appendix D	Change Log
Appendix E	Financial Assurance
Appendix F	Fitec Mass Balance
Appendix G	Emergency Response Plan & Fire Safety Plan
Appendix H	As-Built Grading Plan
Appendix I	Detailed Engineering and Equipment Documents

# 1. Introduction

## 1.1 Purpose

This Design and Operations (D&O) Report (D&O Report) is prepared to fulfill the Renewable Energy Approval (REA) requirements as set out in Ontario Regulation 359/09. The project is a Class 3 Anaerobic Digester (AD) with a name plate capacity of 1 MW. The AD facility, owned and operated by Escarpment Renewables, currently operates under REA No. 8541-9HSGG3, as amended. The project has received a Feed-In Tariff (FIT) Contract No. F-000610-BIG-130-302. This D&O Report has been prepared to support an application for amendment to the above -noted REA. Escarpment Renewables intends to complete a site expansion and additional site improvements. This includes acceptance of new waste types and increased waste tonnage, along with building new infrastructure on site to manage additional waste processing requirements. The proposed site expansion will have effects on the AD facility's design, capacity, and processes.

## 1.2 Project Location

The project will be constructed on lands owned by Escarpment Renewables, which owns and operates the Grimsby AD Facility located at 424 Soby Road, Grimsby, Ontario (Site). The Site is located on the northwestern 4 hectares (ha) of a 10.5 ha property located on the south side of Soby Road approximately 300 m east of Park Road South. The proposed expansion will further develop the 10.5 ha property to utilize a total of approximately 6 ha. The legal description of the property is part of Lots 1 and 2, Concession 6, Former Township of North Grimsby. The Site is located on land that is zoned A(H), Agricultural with a Holding designation, under the Town of Grimsby Zoning By-law No. 14-45. Agricultural zoned properties have setback limits that are minimum 15 metres (m) for front yards, interior and exterior side yards, and rear yards. There are no building height requirements. The Holding designation requires that zone be used only for the uses, buildings and structures that existed at the date of the passing of the by-law. The land is also located in an area of high aquifer vulnerability.

Escarpment Renewables has engaged with the Town of Grimsby to initiate a Minor Variance for the expansion outlined in this proposed amendment, as the existing Site use was legally established but is currently a legal non-conforming use.

In the Town of Grimsby's Official Plan, the land use for the site is rural and it is located in the countryside. The Plan also defines the Site and surrounding areas as a Waste Disposal Assessment Area due to the presence of the adjacent closed landfill as noted in Section 1.3.

The location of the project is shown in Figure 1.

## 1.3 Surrounding Land Use

The surrounding area is mostly zoned for agricultural purposes. In the immediate vicinity are a number of poultry and cattle farms. Immediately to the west of the subject property at the southeast corner of Soby and Park Roads is a closed landfill site owned by the Region of Niagara. This site was closed in 1995. This area is zoned for agricultural use. To the north is a radio transmission tower field. This area is zoned SC(H), Specialty Crop with a Holding designation.

To the east is undeveloped farmland and a poultry farm that is in the agricultural use zone. The lands to the south of the property are classified as Significant woodlands, with some wetlands, and contain a small watercourse. This area is zoned for agricultural use with a Holding designation, and also has an additional permitted use as a riding stable. The lands to the south also contain areas zoned Environmental Conservation (EC) and Hazard which restricts development in these areas.

The Niagara Escarpment Plan Boundary is located 1 kilometre (km) north of the Site.

The nearest receptor to the Site is a farmhouse located on the west side of Park Rd south of Soby Road. This home is located approximately 400 m from the western property line and is separated from the project site by the closed landfill which is approximately 8 m above grade.

In the Town of Grimsby's Official Plan, the lands to the west and south are considered potential natural heritage corridors.

There are 11 groundwater wells installed in the current monitoring well network on Site. Additionally, based on a review of Ontario Ministry of the Environment, Conservation and Parks (MECP) well record database, there are nearby wells associated with the adjacent Park Road Landfill and potential domestic groundwater users near the Site. The confined bedrock aquifer is used as a source of potable water in the area.

There is also a significant groundwater recharge area located approximately 300 m to the south of the Site. The Site's surrounding area is also an area of high aquifer vulnerability. The surrounding area is depicted on Figure 1.1.




Figure 1.1 Surrounding Land Use from Town of Grimsby Official Plan

## 1.4 Site Description

The Site is flat, sloping gently to the southeast. The Site is developed within the footprint permitted by the current REA. Most development is concentrated in the northwestern area of the Site and consists of staff buildings, AD tanks, digestate storage tanks, and biogas management areas. Most of the Site is gravel and grass covered, with a gravel road running around the perimeter of the AD facility and buildings. To the west of the gravel road is the unused open-air concrete storage bunkers. East of the Site is undeveloped farmland, which will now be partially developed as part of the AD facility. The existing condition for the site is shown on Figure 2, following the text.

## 2. Facility Design

Figure 2 shows the existing site layout. The proposed Site layout for the project is depicted on Figure 3. The conceptual organics pre-processing building layout is shown in Figure 4.

The Site consists of an organic processing facility, which will be capable of receiving and processing up to 159,000 tonnes of organic waste per year by AD. The existing solids storage bunkers will be decommissioned. A new organics pre-processing building will be constructed with the necessary equipment to receive, temporarily store, and process solid organic material for digestion. Liquid receiving tanks are located near the existing pump and pasteurization building and will continue to receive liquid organic material for processing. The AD facility, which is currently operational, will be expanded with additional digester tanks and additional processing equipment. Digestate management currently consists of two storage tanks that will remain. Two additional digestate storage tanks will be constructed.

The existing biogas management area consists of a combined heat and power (CHP) engine, flare, and biogas storage area. The Site will continue to utilize biogas in the existing CHP. The existing temporary biogas storage will be decommissioned in favour of storing biogas in double membrane roof systems on the new digestate storage tanks.

Biogas will also be upgraded to renewable natural gas (RNG) for temporary storage on Site in tube trailers prior to transportation off Site. The existing administration buildings, which consist of an office and staff building will remain but be relocated. Air treatment will be managed by a new air treatment system, managing potentially odour-impacted air generated within the organics pre-processing building. There are also two stormwater management ponds located at the south end of the Site, which will be unchanged. Site access consists of mostly gravel road which will be realigned to make space for additional tanks and equipment.

The process flow diagrams for the facility are shown on the following figures:

- Figure 5 – Waste Receiving and Processing
- Figure 6 – Digestion
- Figure 7 – Digestate and Biogas Management

### 2.1 Existing Conditions

The existing Site layout is shown in Figure 2. When Escarpment Renewables purchased the Site in 2019, several upgrades were constructed to bring the facility into compliance with the REA as well as prepare the site for the potential of a future expansion. These included:

- Addition of three lined and agitated liquid receiving tanks
- Addition of the feed pasteurization system to digesters with two pasteurization lines and room for a third
- Addition of digestate skimming systems to existing digesters
- Construction of the pump and pasteurization building and digestate skimming building
- Grading and stormwater management improvements
- Removal of outdoor waste storage to prevent leachate generation

These upgrades were completed with the pending expansion in mind. As such, the process equipment supplier designed the receiving, pasteurization, conveyance, and digestate management equipment to manage an incoming feedstock capacity higher than the currently approved and processed 23,000 tonnes per year. The existing equipment was sized to manage 33,000 tonnes per year.

The feedstock mix that's currently received at the Site is different than the feedstock mix that was originally proposed in the existing REA. The majority of current feedstock is pre-processed SSO, and various Industrial, Commercial, and Institutional (ICI) liquids, whereas the originally design consisted of more agricultural feedstocks. With over one year of operating the upgraded Site, it has been determined that to achieve 1 MW of electrical output, the Site would need to

receive and process at a higher rate than 23,000 tonnes per year. An updated mass balance for 33,000 tonnes per year can be found in Appendix F, which was prepared by Fitec, who was the equipment supplier for the equipment installed as part of the existing upgrades.

## 2.2 Waste Receiving

### 2.2.1 Feedstock Materials

The proposed waste types for receipt at the Site are:

- Agricultural waste including Swine manure; poultry manure; cattle manure, and paunch manure; grape pomace; corn silage; silage of all types of grasses; dairies and facilities that process dairy products; fruit and vegetable wastes; wastes from cereal and grain processing facilities, oil seed processing facilities, breweries and distillers' grain; glycerin; and herbaceous plant material from greenhouse, nurseries, garden centres and flower shops
- Source -Separated Organics (SSO) (pre-processed and un-processed), received as either a liquid or solid waste
- Packaged ICI organic waste
- Solid and liquid ICI organic waste including but not limited to bakeries; confectionary processing facilities; dairies and facilities that process dairy products; fruit and vegetable processing facilities; fruit and vegetable packing facilities; cereal and grain processing facilities; oil seed processing facilities; food manufacturing facilities; food processing facilities; grocery stores; food distribution companies; beverage manufacturing facilities; breweries and distillers grain; wineries; milling facilities; pet food manufacturing; production of ethanol or biodiesel; greenhouses, nurseries, garden centers and flower shops, limited to herbaceous plant material; biosolids

Table 2.1 provides the maximum annual tonnes of waste received by feedstock. The maximum annual tonnes in feedstock composition are intended to provide the AD facility with the flexibility to change the composition of the total combined feedstock to suit current AD facility operation conditions, changing organic waste market conditions, optimize biogas production and AD facility performance. The annual composition of waste received may consist of any combination of the below waste types up to maximum tonnes indicated and not exceeding a combined maximum of 159,000 tonnes per year.

The expected annual combination of waste tonnes received is estimated to be approximately 109,000 tonnes of SSO and 50,000 tonnes of ICI liquids.

**Table 2.1 Feedstock Type and Maximum Annual Tonnage**

Waste Type	Maximum (tonnes per year)
Agricultural Waste	7,000
SSO (pre-processed and/or unprocessed)	120,000
ICI Packaged	100,000
ICI Liquid	100,000
Maximum total	159,000

The mass balance for the AD facility feedstock using average expected volumes of each waste type shown above is presented in Table 7 following the text. The mass balance presents the breakdown of waste composition, including contaminants and resulting organics fraction, by waste type.

Waste will be received 6 days per week (Monday through Saturday) for an average of 526 tonnes per day. The peak daily tonnage is based on 2 times the average for a total of 1,050 tonnes per day. The AD facility will accept a maximum of 1,050 tonnes per day which may be comprised of any combination of the above waste types. There will be temporary storage area in the organic pre-processing building for the unprocessed waste to provide buffer to the daily average and daily maximum capacity. The types of material being pre-processed from the storage area (i.e.,

higher moisture content vs. lower moisture content) will be selected to make a desirable consistency of feedstock (12% to 27% TS).

## 2.2.2 Feedstock Receiving

Loaded trucks will enter the Site and be weighed on the scale before discharging their material. Incoming unprocessed ICI and SSO, as well as any agricultural waste that is not unloaded as liquid waste, will be unloaded in the new organics pre-processing building. The incoming trucks will travel south on the site road towards the organics pre-processing building and reverse into the receiving bays to unload material onto the tip floor.

The Organics Receiving Building is operated and maintained at a negative pressure environment (rolling arithmetic average over 30-minute period), such that all potentially process -related odorous air is collected and treated using the fully functional Biofilter. All windows and doors in the Organics Receiving Building are kept closed at all times, except when the doors are used for necessary personnel and/or vehicle entrance and exit. Only one (1) of the three (3) loading/unloading doors (2 bay doors and 1 dock-level bay) in the processing area of the preprocessing building is opened at any one time, and only one (1) of the four (4) loading/unloading doors (4 bay doors) in the receiving area of the preprocessing building are opened at any one time. The opening and closing of the seven (7) loading/unloading doors, the negative pressure differential sensor(s) and the ventilation systems are interlocked, monitored and controlled through the same Supervisory Control and Data Acquisition (SCADA) system to maintain adequate negative air balance and negative air pressure within the Organics Receiving Building. Overhead doors for the pre-processing building will remain closed at all times during off -hours. The tip floor area will be constructed with an estimated height of 14 m to provide required height for unloading of all potential types of trucks. Waste will be tipped, and a front-end loader will move material to the temporary storage area. A steel--plated- push wall will allow the loader to lift material for conveyance to the waste pre-processing unit hoppers.

Certain ICI waste brought to the Site on pallets will be unloaded at a dock -level receiving bay. Trucks will back up to the loading dock and engage with a dock seal. Once engaged, the seal will be visually inspected, and the dock door and truck door may be opened. The seal will help prevent fugitive odour emissions. ICI waste will be unloaded by forklift or similar equipment and brought to the temporary waste storage area on the tip floor.

Pre-processed SSO, ICI liquid feedstock, and liquid agricultural waste will be deposited into the three existing 493 cubic metres (m<sup>3</sup>) underground liquid receiving tanks. The liquid receiving tanks are constructed of lined concrete. Each has an installed agitator to allow mixing of the substrate and low-level- and high-level- alarms to manage tank levels. Pumps for the liquid receiving tanks are located in the basement of the pump and pasteurization building. The liquid receiving tanks can pump contents between one another to mix incoming feedstocks prior to digestion. One of the three liquid receiving tanks will be designated for waste requiring pasteurization and the other two liquid receiving tanks will be designated for waste not requiring any pasteurization.

Liquid feedstock trucks will travel around the Site Road to the liquid receiving tanks and reverse into the area located adjacent to the liquid receiving tanks. This area allows trucks to have room to park and unload liquid waste, without blocking the Site's access road. Each liquid receiving tank has room for one waste truck to park directly in front of it. For most liquid loads, a flexible hose with camlock connections will be available if the truck has the connection capability to transfer material this way and the air being exhausted through the activated carbon unit. For all other loads the materials will be discharged into the tank with lid partially or fully open.

The liquid receiving tanks are 10 m in diameter and 6.3 m deep, below grade. The liquid receiving tanks can be heated using a heat exchanger system. The liquid receiving tanks temperature is monitored through the control system. They also contain agitators to prevent solids settling and to ensure a homogenous mixing of the feedstock. The underground liquid receiving tanks are surrounded by an at grade concrete pad that is sloped to a drain, connected to the liquid receiving tanks. This provides spill containment in the liquid waste unloading area. Each liquid receiving tank is also equipped with a grate to prevent large contaminants from damaging internal equipment.

Mixing of feedstock in the existing liquid receiving tanks will include the ability to recirculate digestate, when required, or add water collected in the secondary containment system or stormwater ponds to provide dilution as needed to achieve target solids content.

The expected truck movements are provided in Table 8 following the text. Truck movements are divided into the areas of the Site they are directed to load or unload. Delivery of incoming feedstocks has been split into various types of trucks expected to arrive at the site and divided between weekday and Saturday traffic. Digestate may be transported year-round, however the volume of trucks required to manage annual digestate generation rates has been compressed into an eight-month period to provide a more conservative estimate.

## 2.2.3 Incoming Waste Storage

Waste storage for solids feedstock will be limited to the available space on the tip floor area within the organics pre-processing building. On -Site storage will accommodate up to three days' worth of average incoming SSO waste volumes. This results in a maximum 1,220 tonnes (or 1875 m<sup>3</sup>) of waste stored on the tip floor. This waste may be comprised of SSO, solid ICI organics, and solids Tier 1 and 2 biomass. Solid waste stored on the tip floor will be conveyed via loader to the waste pre-processing operations.

There are three existing underground liquid receiving tanks with a total capacity of 1,479 m<sup>3</sup>, which will be used for storage of liquid feedstock. At an average density of 1 tonne per cubic metre, this results in 1,479 tonnes of liquid waste storage. This provides for storage of 8-days' worth of average incoming liquid ICI waste.

## 2.3 Waste Pre-processing

### 2.3.1 Organics Pre-processing Building

The organics pre-processing building will be approximately 46 m by 53 m, constructed with a concrete foundation and a pre-engineered, insulated steel structure. Incoming trucks will enter through overhead doors and unload as described in Section 2.2. A manual wheel wash station will be provided to wash outbound truck wheels as necessary. Runoff on the tip floor will be collected in floor trench drains and sumps, with the water directed to the liquid receiving tanks.

Waste from the tip floor will be managed by a front-end loader and stored in the temporary waste storage area. The front-end loader operator will identify any large contaminants within the bulk solid waste and segregate them adjacent to the tip floor for later removal and off-site disposal.

The organics pre-processing building contains the waste pre-processing equipment and residual waste storage areas described below.

Ancillary features provided in the organics pre-processing building include:

- Electrical/control room
- Shop
- Storage
- Heating, ventilation, and air conditioning systems
- Offices, washrooms, change rooms, kitchen/lunchroom

### 2.3.2 Waste Pre-processing Units

Solid waste will be pre-processed to prepare the feedstock for anaerobic digestion by removing contaminants that may hinder the digestion process or accumulate within the digesters. From the tip floor/pit, waste will be transported by the front-end loader to angled hoppers that will transport material to the waste pre-processing units by a series of screw and/or belt conveyors.

The waste pre-processing units will consist of two units in parallel designed to separate contaminants from the organic material. The units will be arranged in a staggered layout and will be loaded with material from the tip floor using a front-end loader that will unload waste into a series of hoppers. From the hoppers, waste is conveyed in a contained



auger to a waste pre-processing unit. The waste separation unit is enclosed and uses mechanical means to separate organics from contaminants.

The hopper part of the waste pre-processing unit will be separated from the screening and conveyer section using a concrete wall, with the hopper situated on the tip floor side and the waste screening and conveyor situated in the waste pre-processing room. This will help contain the odorous air that is generated in the tip floor. As the waste pre-processing units are fully contained downstream of the hoppers, they will generate less odorous air in the waste pre-processing room.

The waste processing units will create a light rejects stream (mostly plastics and packaging), which will then be dewatered further through a dewatering press. The liquids from the press will be captured and utilized in the process, while the pressed solids will be conveyed into residue trailers for disposal. The hammermill system will create a paste (20% to 32% TS) that will be conveyed into the liquids receiving tanks or one (1) trailer within the Residual Waste Storage via enclosed conveyers for off-site shipping. Each hammermill system can process SSO at a consistent rate of 15 tonnes/hour (2 units = 30 tonnes/hours). The units will be operated based on demand. The hammermill system can accept raw feedstock as is. The residue from hammermills will be conveyed continuously to a dewatering press. This press can process up to 10 tonnes/hour of incoming material.

The waste pre-processing units will also include connections that will allow the addition of liquid from the dewatering unit or from stormwater pond to generate a pumpable organic slurry (12% to 27% TS). The organic slurry from the waste pre-processing units will all be sent to the existing liquid receiving tanks to be combined with other waste prior to feeding the digesters or one (1) trailer within the Residual Waste Storage via enclosed conveyers for off-site shipping.

Paste/slurry will be moved through a sealed conveyance system (i.e., auger, high solids pump). Paste loading into trailers will be relatively infrequent. However, there will be a paste loading system installed to load trailers and controls put in place to ensure proper operation and reduction of the potential for spills. The material in the pre-processing building that is loaded into trailers is either solid (i.e., residues) or semi-solid (i.e., paste/slurry), they will not free flow into a floor drain. In case of a spill, the material would be handled more like a solid (mostly scooped into a bin and then transfer to the trailer) and then the area and equipment would be washed down. Floors will be sloped into the building at a 1-2% grade. The tip floor will have a sump that collects any runoff from the organics and the sump pump will pump liquids directly into the liquids receiving tanks. With the entire floor sloping into the building and the sump, there should not be any liquids that escape out the door from the inside. Waterstops and sealant will be applied to ensure the concrete floor is waterproof.

Residual wastes, such as plastics, glass, packaging, or other inert material will be output from the waste pre-processing units and conveyed to the residual waste storage area within the pre-processing building.

### 2.3.3 Residual Waste

Solid reject materials including grit, plastics and other contaminants will be transported from the pre-processing equipment outlets utilizing an additional series of conveyors to the residual waste storage area. Residual waste from the pre-processing system will include large contaminants mistakenly included in the waste stream (heavies), plastics and other inert such as packaging (lights). Skimmings and grit will be separated out during the digestion process. The quantity of each will be largely dependent on the type and origin of the waste. Initial estimates of residual waste are provided below.

- Heavies – estimated at one percent of total incoming SSO – 1,090 tonnes per year or 3.5 tonnes per operating day stored on the tip floor for direct loading into trucks for off-Site disposal
- Lights – estimated 18% of total incoming SSO and 5% of ICI – 22,120 tonnes per year or up to 73 tonnes per operating day
- Skimmings and Grit – estimated one percent of total incoming waste – 1,090 tonnes per year or 3.5 tonnes per operating day

Estimated total residual waste may therefore amount to 80 tonnes per operating day.

Heavy residuals will be manually removed on an ongoing basis from the material received on the tip floor. These heavies will be put aside on the tip floor and moved to the residue trailer regularly during each operating day. Light residual waste from the waste pre-processing units will be conveyed and dewatered along with residues from grit and skimming building prior loading into trailers. A Komar press (or equivalent) will be used for dewatering, which is a progressive, ultra-high pressure compaction equipment. The press offers high-pressure auger compaction and a proprietary wedge bar separation system for dewatering. The proposed design is that pressed organic liquids will be collected within the equipment and continuously transferred to liquids receiving tanks.

Two trailers will be located in the residual waste storage area (about 120 m<sup>2</sup>). One trailer will be used for residual waste and the second trailer for organic paste/slurry, when required. Once full, the residual waste trailer will be removed from the Site and transported to a licensed waste disposal facility. Additional lights and grit will be collected from the digestate and digester feed skimming/grit removal systems as follows:

- Digestate from the existing digesters is skimmed and filtered through a press prior to transfer to digestate storage. The press collects plastics in a storage bin in the adjacent skimming building. The four new digesters will be equipped with skimming and grit removal systems that collect grits and plastics and store them in bin/bunker in the adjacent skimming buildings. Two skimming systems in two buildings will provide the skimming required for the four new digesters. Each skimming system will have a processing capacity of 1080 tonnes-digestate/day
- Once the bin is full, a cover will be placed on the bin, and it will be transferred to the preprocessing building where it is further dewatered and loaded into a trailer to be transported off-site. Alternatively, the material will be collected in bunkers within the skimming and grit buildings and loaders will scoop up the skimmer/grit and put them in a covered bucket inside the skimming building prior to outdoor transport to the pre-processing building.

The following residual waste storage volumes are provided:

- Up to 5 m<sup>3</sup> on the tip floor, included in the total storage volume for waste receipt
- Up to 95 m<sup>3</sup> in two trailers within the organics pre-processing building
- 5 m<sup>3</sup> in a bin in the existing digester skimming building
- 9 m<sup>3</sup> in a bunker in the new digester skimming/grit building 1
- 9 m<sup>3</sup> in a bunker in the new digester skimming/grit building 2

Bins and heavies may be periodically transported to the residual waste storage area in the organics pre-processing building to be combined with residual waste stored in the residual waste trailers for efficient transportation off Site.

The storage volumes above collectively provide approximately 1.2-days of storage for average residual waste. Overall Site waste storage calculations are provided in Table 9 following the text.

## 2.4 Digestion

### 2.4.1 Pasteurization System

The existing pasteurization system is located in the pump and pasteurization building adjacent to the liquid receiving tanks. There are two existing pasteurization system trains, each with a capacity of 23,500 tonnes per year, which are connected to the liquid receiving tanks.

Mixed feedstock, requiring pasteurization, from the liquid receiving tanks is pumped to the pasteurization system. Pasteurization is achieved by heating liquid waste to a minimum temperature of 70°C via heat exchangers followed by holding for 1-hour at a minimum temperature of 70°C in the substrate holding tanks. The substrate temperature and pasteurization system glycol temperature are both carefully monitored. Following pasteurization, the substrate is cooled using glycol cooling fans prior to conveying the liquid to the digesters. Each pasteurization holding tank is equipped with level sensors to measure liquid levels, high level alarms to prevent overflow, and one centrally located thermocouple for temperature monitoring. Three tanks are used in each pasteurization train to allow one tank to be filled, one tank to hold the required temperature for 1-hour and the third to be emptied to the digesters. The

pasteurization holding tanks are passively vented through a common pipe which is connect to an activated carbon unit.

The total capacity of the two existing pasteurization trains is 21 m<sup>3</sup> (2 trains x 3 tanks per train x 3.5 m<sup>3</sup> per tank).

In addition to the existing pasteurization system, there will be pasteurization system with sufficient capacity in place to pasteurize the digestate to meet the pathogen levels required by the CFIA. The heat exchangers use recovered heat from the existing CHP. Additional heat will be provided by a new propane or biogas fuelled- boiler located in the second pump and pasteurization building.

The pasteurized feedstock is pumped into the digester tanks automatically and controlled through the AD facility SCADA system.

## 2.4.2 Digester System

The Site digester systems will consist of:

- Two existing digester tanks each with a capacity of 2,166 m<sup>3</sup> for a total of 4,332 m<sup>3</sup>. Each tank is 22 m in diameter and 6 m deep, constructed primarily below grade
- Four new digesters tanks, each with a capacity of 3,435 m<sup>3</sup> for a total of 13,740 m<sup>3</sup>. Each tank will be 18 m in diameter and 13.5 m high

The resulting total digester capacity will be 18,072 m<sup>3</sup>.

Substrate is pumped from the pasteurization system to the digesters via parallel feeding pipes or from the two liquid receiving tanks containing liquid waste not requiring pasteurization. Design hydraulic retention time (HRT) will be forty-five (45) days during normal operation based on an annual average for the organic waste fed to each anaerobic digester. The HRT needs to be kept at a minimum of twenty-five (25) days at all times. On peak days, the incoming tonnages will be spread over several days to accommodate the minimum HRT (25 days) requirement. Digester operating conditions are based on the type of waste, expected waste characteristics, water balance, and desired biogas consistency.

Each digester is dosed with ferric chloride, or equivalent, from the dosing system daily. Ferric chloride reduces the generation of hydrogen sulphide (H<sub>2</sub>S) in biogas. Ferric chloride dosing will be based on monitoring of the H<sub>2</sub>S concentrations in the biogas. Stock ferric chloride will be stored in a self-contained double-walled tank located outside on a concrete pad by the digesters.

The design loading conditions are based on the total volume of the average digester feedstock mix and a target 20% dry solids content. The organic loading rate of the digester capacity on Site will be approximately 2.8 kg VS/ m<sup>3</sup>day

The headspace of each tank will be connected to the new dual membrane roofed digestate storage tanks utilized for biogas storage and buffer. Additional details of the digestate storage tanks are provided in Section 2.5. These tanks will be designed to meet Canadian Standards Association (CSA) B149.6 – Biogas and Landfill Gas Code.

The new digesters will be self-cleaning digesters outfitted with agitators, in-vessel floor sweepers for grit removal, and skimming systems to skim digestate to remove contaminants and regulate the tank filling level. The self-cleaning feature will continuously clean the digester of fine silting contaminants. The speed setting of the agitators can allow particles to remain in suspension or settle in the bottom of the tank while plastics and other contamination float to the top to be removed. The plastics and other contamination are conveyed to the skimming and grit storage buildings and disposed of offsite.

The existing digesters are outfitted with top mounted skimmers that skim digestate and pump the skimmed digestate to the digestate separation building to filter out contamination. A screw press with a 1.0 mm screen filters the digestate to remove visible plastics and contamination, which are then collected and stored in an adjacent roll-off bin. Two additional screw presses/skimming systems will be installed in phases 1 and 2.

All digesters will be equipped with over/under pressure devices to provide safety pressure relief.

### 2.4.2.1 Plug Flow Digesters

The REA permits the operation of two plug flow digesters, which were constructed at the Site, each with a 900 m<sup>3</sup> capacity. Each digester is 30 m long, 6 m wide and 6 m high built entirely of concrete. The Site will utilize wet AD and does not need these digesters to function. Escarpment Renewables will maintain this infrastructure on Site for the purpose of potential future research and development studies with partners that may include industry, research institutes, and government agencies. Proposed studies using these digesters may include, but not be limited to:

- Evaluating the effectiveness of the AD process to breakdown compostable or bio-based plastics
- Investigation into the suitability of the organic fraction from mixed waste processing called facility sorted organics (FSO) as an AD feedstock.

All studies completed in these digesters would consider the materials ability to digest in the AD process (e.g, VS reduction and biogas production) and generation of a beneficial end use product. It would also evaluate possible improvements that would be required to efficiently process these types of feedstocks and the effect of the material on the quality of the AD process end products.

## 2.5 Digestate Management

An estimated average 115,763 tonnes of digestate from the 6 digesters will be produced annually, with between 4 and 7% solids content. Digestate is pumped from the digesters to the digestate storage systems. Digestate storage will be provided by the two existing 4,029 m<sup>3</sup> storage tanks and two 8,000 m<sup>3</sup> tanks, for a total of 24,058 m<sup>3</sup>. This will provide approximately 76-days of digestate storage. To provide a minimum storage capacity of 150-days, additional lagoon storage will be secured through contract with local farmers. Digestate will continue to be managed as a fertilizer under the Canadian Food Inspection Agency (CFIA). In the event that the digestate can't be managed as CFIA fertilizer, it will be managed as Non-Agricultural Source Material (NASM) for land application under a NASM plan.

The existing digestate storage tanks are constructed largely below grade. They are concrete with a fixed roof and agitators to keep digestate mixed.

The two new digestate storage tanks will be constructed above grade and include double membrane biogas bladders installed at the top of the tank.

A digestate filling station will be located beside the secondary containment area, where trucks will be filled with digestate through a discharge pump. Digestate filling may occur during extended hours to accommodate agricultural operations. Trucks take digestate to farms and lagoons to be applied to fields as a fertilizer.

## 2.6 Biogas Management

### 2.6.1 Biogas Handling

Biogas will be generated in each of the existing, and new digesters. All digesters will be piped to collect biogas in the new digestate storage tanks with membrane- roofs. The digestate storage tank will be dome style with a diameter of up to 32 m. Each tank will have sufficient capacity to store biogas up to 11-hours at maximum biogas production. The existing biogas storage bladders and building will be decommissioned.

The Site will generate up to 1,883 cubic metres per hour (m<sup>3</sup>/hr) of biogas. Biogas will be used either for generation of electricity or RNG, as discussed below.

### 2.6.2 Electricity

Prior to combustion in the CHP, moisture is removed from the biogas through a gas cooler. Condensate from the moisture removal operation is collected and pumped back to the liquid receiving tank for reuse in the system. Final polishing for H<sub>2</sub>S removal is completed by a carbon vessel prior to combustion in the CHP. Electricity generation from the CHP engine produces heat and carbon dioxide (CO<sub>2</sub>). Heat is currently used in the digester operation. Electricity is

fed to the grid through the existing FIT contract. The REA Amendment will see the existing CHP engine continue to operate.

### **2.6.2.1 Engines**

The existing CHP engine is a 1-MW cogeneration engine which runs 24-hours per day. This is located in the northernmost portion of the Site beside the staff building and the transformer. Also located near the engines is a 200 kW backup diesel generator that provides backup power for critical operations in the event of a power outage.

### **2.6.2.2 Heat Recovery**

The engines produce about 1 MW of thermal energy in the form of heat. The engines are equipped with a heat recovery system located in the heat distribution room, which will be relocated into a new boiler and heat distribution building. Heat from the CHP is used to heat the digester feedstock and for supplying heat to the pasteurization system.

### **2.6.2.3 Switchgear**

The engine room also contains the electrical switchgear that controls the quality of the power exported to the grid. A transformer is located beside the engine container in secondary containment.

## **2.6.3 RNG**

Biogas produced on site will be upgraded to RNG. Biogas generated within the anaerobic digestion process will contain approximately 60% methane (CH<sub>4</sub>) with the balance consisting primarily of CO<sub>2</sub> and small amounts of other trace elements. In addition, the biogas will contain H<sub>2</sub>S, siloxanes, ammonia, and trace quantities of additional volatile organic compounds (VOCs). In order to produce RNG, the biogas will be upgraded within a treatment process designed to remove impurities, producing a gas consisting primarily of CH<sub>4</sub> that meets the utilization specifications.

### **2.6.3.1 Biogas Pre-Treatment**

Biogas will be drawn from the digestate/biogas storage into the preliminary biogas treatment stage designed for removal of mainly H<sub>2</sub>S and moisture.

An activated carbon system will be used to remove H<sub>2</sub>S and VOCs through adsorption. The activated carbon media would require periodic removal once it is spent. Spent activated carbon would be sampled and subjected to TCLP (Toxicity Characteristic Leaching Procedure) prior to off-Site disposal. All spent adsorbents will be dumped into a roll-off bin and landfilled or into a dedicated bin and regenerated offsite.

The biogas pre-treatment system will be implemented to achieve the required inlet quality for the RNG upgrading system. The final configuration of the biogas pre-treatment system will be based on the manufacturer requirements of the RNG upgrading technology described below.

### **2.6.3.2 Biogas Upgrading to Renewable Natural Gas**

RNG upgrading will be completed using a packaged system designed by an RNG upgrading technology provider. The RNG upgrading system is used to generate gas with very high CH<sub>4</sub> content suitable for use as RNG. The primary gas to be removed from pre-treated biogas is CO<sub>2</sub>.

Two potential technologies may be implemented at the Site; pressure swing adsorption (PSA) or membrane technology.

PSA is an effective method of gas separation, particularly where a complex mixture of gases is generated from feedstock, or where there is high humidity. Under high pressure different gases are attracted to different solid surfaces. The higher the pressure, the more gas is absorbed and when the pressure is reduced, the gas is released or desorbed.

PSA systems monitor the biogas volume and quality to control the system operation. An adsorbent material is used in PSA gas separation vessels to separate CO<sub>2</sub> and oxygen (O<sub>2</sub>) from the product gas, producing a CH<sub>4</sub> rich biomethane or RNG gas. A PSA system would be manufactured to meet the requirements of the latest version of CSA B51, Boiler, Pressure Vessel, and Pressure Piping Code. Typically, PSA systems operate in batches to remove CO<sub>2</sub> and O<sub>2</sub> and collect the CH<sub>4</sub>-rich RNG, depressurize and regenerate the adsorptive media and then release the captured CO<sub>2</sub> and O<sub>2</sub>.

Membrane technology uses a compressor to pressurize the pre-treated biogas to have it pass through a membrane. Selective membranes are utilized that allow the passage of CO<sub>2</sub> but prevent the passage of CH<sub>4</sub> based on the differences in their molecular size. Typically, multiple tubular membrane modules are arranged in parallel and series. Three stage membrane technology will have a higher recovery rate versus the two-stage membrane technology. The retained CH<sub>4</sub> is often recirculated to achieve high rates of CO<sub>2</sub> removal. The final CH<sub>4</sub> concentration will be determined based on the requirements of RNG injection contracts with the natural gas utility owner.

Both systems involve pre-treatment of the biogas which will consist of coolers, chillers, liquid knock outs, H<sub>2</sub>S removal and H<sub>2</sub>S polishing (typically using activated carbon). A combination of this pre-treatment equipment will remove H<sub>2</sub>S, VOCs and siloxanes from the biogas prior to generation of RNG either PSA or membrane system.

Any condensate generated in the RNG upgrading system will be reused by discharging into the liquids receiving tanks or reused in the upstream processes on Site.

Estimated RNG production based on a 95% uptime and 98.5% recovery rate is estimated to be 1050m<sup>3</sup>/hr and 9,200,000 m<sup>3</sup> per year.

PSA and three stage membrane technologies are capable of producing high CH<sub>4</sub> content RNG and minimal CH<sub>4</sub> slip. The off -gas or tail gas from these technologies, which is primarily CO<sub>2</sub>, will be vented to atmosphere.

Following upgrading, RNG will be compressed up to 3,600 psi, and stored in portable storage vehicles (i.e., tube trailers) on Site. When filled the trailers will then transport compressed natural gas (CNG) to an injection point on the existing pipeline, “virtual pipeline”, or to another Site for utilization. For direct injection into the pipeline, RNG will be compressed up to 300 psi of injection pressure.

## 2.6.4 Flare

In the event that surplus or poor -quality gas is produced, an automatic -start flare, capable of combusting biogas is included in the design of the project. Gas is piped from the storage tanks to the flare, RNG upgrading system, and engine. The flare is designed for a capacity of 2,966 m<sup>3</sup>/hr at 60% CH<sub>4</sub>, providing full redundancy. Additional flaring capacity will be added to account for increased biogas production. The flare will be relocated to the southeast corner of the expanded site near the digestate/biogas storage area.

The flare is designed for operation at 870°C with a 0.7-second retention time and a minimum CH<sub>4</sub> destruction efficiency of 98%. The flare will be connected to the backup generator to keep the flare controls active during power outage. The biogas flare will be directly connected to the digestate/biogas storage and will be activated when the pressure in the digester or digestate/biogas storage reaches above the flare operating pressure setpoint.

In the event of a failure of the RNG upgrading system or the production of upgraded biogas that does not meet the RNG quality requirements, the biogas would be redirected to the flare.

## 2.7 Air Treatment

The organics pre-processing building will generate odours. The waste receiving and temporary storage area will generate the most odour. Other odourous areas include the residual storage area and the waste pre-processing area. Since the waste pre-processing units are enclosed, lower odour is expected in this portion of the building.

A ventilation system will be provided to maintain negative pressure in the organic pre-processing building so that there are no odour complaints at nearby sensitive receptors. To minimize air volumes requiring treatment, air will be

cascaded from areas with lower odour potential to areas with higher odour potential, with air ultimately being drawn from the waste receiving area and into a biofilter. The biofilter will be equipped with either organic or inorganic media.

Table 10 provides the design air changes per hour for each area of the organics pre-processing building, with the final volume to be extracted to the biofilter of 78,306 m<sup>3</sup>/hr, or 21.75 cubic metres per second (m<sup>3</sup>/s). This represents the air exchanges required under the worst-case scenario corresponding to maximum odour generation. However, the actual air exchanges per hour will vary between 2 to 5 depending on the environmental and operational conditions.

The Company will monitor and record the following physical parameters of the Biofilter, through a combination of sensors, meters and physical probes, at frequencies as recommended by the Equipment suppliers:

- a. process air flow through each cell;
- b. differential pressure across media bed in each cell;
- c. media temperature in each cell;
- d. inlet air temperature (after the wet water scrubber);
- e. inlet air relative humidity (after the wet water scrubber);
- f. water flow through the wet scrubber;
- g. water pressure and flow, at irrigation supply to each cell;
- h. moisture content of media in each cell; and
- i. media pH in each cell.

Electrical, control, and administrative rooms will have separate air handling systems that are not connected to the biofilter. Odorous air will not be generated in these rooms, and they will be maintained under positive pressure.

## **3. Facility Operations**

### **3.1 Process Operations**

#### **3.1.1 Receiving**

The AD facility will receive liquid and solid waste from the sources noted in Section 2.2. Waste will be received as bulk solid waste, containerized solid waste, or liquid waste with the infrastructure outlined in Section 2.2. Trucks will enter the Site and pass over a weigh bridge documenting the quantity of incoming material. A scale house attendant or an automated assistant will direct trucks to the appropriate location for unloading of wastes. Incoming wastes will be received and unloaded under the monitoring of an onsite operator. Operators within the material receiving areas will be responsible for the following primary tasks:

Organics Pre-processing Building:

- Oversight of material receipt including preliminary scanning or visual inspection
- Operation of the truck door permitting access and egress from the building
- Assisting truck drivers backing into the building
- Segregation of rejected waste within the receiving area
- Operation of front-end loader, or forklifts for transfer of material into the waste receiving bunkers
- General housekeeping in the receiving area including floor washing and truck wheel washing prior to exit, as needed

Liquid Receiving Tanks:

- Monitor/supervise the driver in backing up to the liquid receiving tank's lid and stopping the trailer as close to the lid as possible without damaging the tank
- Properly connect hose between truck and liquid receiving tank's lid
- Confirm that there is enough space in the liquid receiving tanks. Records and signal's controlled by the tank's liquid level sensor, provide indication of the liquid receiving tanks liquid levels. The operator will be available to do a visual check to confirm the tank's liquid level as needed.
- Ensure ventilation systems are operational

Anticipated operator staffing and training requirements are presented in Section 3.7.

Records of incoming material are discussed in Section 3.2.

Liquid receiving tanks will require periodic cleaning and removal of grit that accumulates, despite being equipped with agitators. Grit will be collected and disposed of off Site at licensed waste management facilities.

An outbound scale and Site exit will be constructed on the east side of the Site. Trucks will travel around the exterior road and leave by driving over the outbound scale for weighing. This includes trucks bringing waste to the Site, trucks removing residual waste from the Site, and trucks removing digestate from the Site.

All incoming feedstocks will be sampled and tested according to Section 43 of REA number 8541-9HSGG3 dated October 1, 2014.

#### Reject Waste

If waste is brought to the Site and inspections indicate that the waste is not licensed for acceptance at the Site, the load will be rejected and sent back to the originator (or directed by the originator to a site permitted to receive this material). A record of the reject load will be maintained including:

- Date/time
- Originator
- Transporter
- Material description
- Reason for rejection
- Weight
- Type of material

Site staff will notify the MECP and customer of the reject load within one business day and will maintain the reject load record on Site.

### 3.1.2 Pre-processing

Waste pre-processing equipment is loaded using a front-end loader or grapple feeding mechanism. The operator will scan or visually inspect material as it is loaded to identify any large contaminants that require segregation.

An operator will be available within the waste pre-processing area for:

- Cleaning
- General equipment maintenance
- Controlling throughput
- Sampling/visual quality control

Pre-processing lines will have a local control and programmable logic controller (PLC) system that is integrated into the Site SCADA system. Waste mixing within the existing liquid receiving tanks can also be controlled from the facility SCADA system. This allows for transfer of feedstock between liquid receiving tanks to blend and generate the desired



mix for digestion. Remote monitoring will be provided through the SCADA system, supplementing the operational oversight of the designated pre-processing operator.

Waste pre-processing will be conducted in two, eight-hour shifts to manage material as it is delivered to the Site. While there is storage capacity adjacent to the tip floor to provide buffer for the pre-processing equipment and to help ensure a continuous supply of feedstock to the digesters, waste will not be stored long-term and waste that has been on the tip floor longest will be prioritized for pre-processing to avoid generation of odours.

### **Residue Management**

Residue generated at the Site includes rejected materials, pre-processing residuals, and digestate/digester cleaning residuals. Rejected materials are items incompatible with the waste pre-processing system which are identified in the receiving and storage areas and separated from the waste solids intended for pre-processing. The materials will be temporarily stored in the bulk waste receiving area. Arrangements will be made by the operator to remove these materials from the Site.

Residuals separated from the waste solids during the pre-processing stage will be conveyed along the residuals conveyor to the residual press systems and ultimately stored in indoor trailers until they are full.

Residuals from digestate/digester feed skimming and grit removal systems will be stored in bins or bunkers in the skimmings storage buildings.

Trailers will be backed into the bay within the organics pre-processing building and trailers will be disconnected from the truck. Trucks will typically be coordinated to pick up a nearly filled residual waste trailer when delivering an empty trailer to limit truck traffic associated with residual waste disposal.

Residual wastes will be transported off-Site to a waste disposal facility licensed for receipt of the transported materials.

## **3.1.3 Digestion**

Digestion, digestate management and biogas management systems will be primarily controlled automatically through the SCADA system with remote monitoring of process conditions through the human machine interface (HMI). All systems will be operated 24-hours per day, 7-days per week with remote warnings identifying low- and high-level alarm conditions to standby process operators for determination of manual intervention requirements.

Digester operating pressure will primarily be regulated through the extraction of biogas from the storage tanks. Over/under pressure devices will be equipped on all digesters for safety.

The digestors will be operated at mesophilic temperature range (35° C to 43° C). Temperature will be regulated through the inlet material feed via heating/cooling the feedstock to maintain the mesophilic temperature in the digester. Heating demands are controlled in the heat distribution system that utilizes waste heat from the CHP and supplements with heat from boilers. Each pasteurization/holding tank has a thermocouple to measure the temperature of the substrate to ensure it maintains the desired temperature in the pasteurization/holding tanks. Substrate holding tanks are filled and held for the required duration prior to discharging a batch of feed to the digesters.

Digester feed rate will be set in the HMI and controlled through the SCADA system ensuring appropriate feeding rates and appropriate material retention time.

Routine operational and maintenance requirements will be outlined within the Operation and Maintenance (O&M) Manual prepared during system commissioning.

## **3.1.4 Biogas Management**

Biogas is continuously generated in the digesters. The headspace of the digesters are connected together and to the digestate storage tanks. Biogas accumulates within the digestate storage tanks, with storage volumes fluctuating due to the use of two double-membrane roof arrangements, one on each digestate storage tank. Digestate storage tanks will be equipped with pressure sensing devices to monitor the pressure with the tanks.

The double membrane digestate/biogas storage area is connected to the CHP inlet and pre-conditioning systems, the RNG upgrading system, and the flare. The CHP and RNG upgrading systems will automatically allow biogas input based on their available capacity. The CHP engine has a rated capacity of 1MW and gas consumption rate of 450-500 m<sup>3</sup>/h. The RNG upgrading system will have a rated capacity as appropriate for the biogas production in the plant. If either system is down for maintenance, biogas will accumulate in the digestate/biogas storage. If digestate/biogas storage pressure is exceeded, then biogas will be sent to the flare for combustion.

The double membrane roof system will have a maximum permeability of 200 cm<sup>3</sup>/m<sup>2</sup>/day/bar.

### 3.1.5 Digestate Management

Digestate production volumes will be monitored to coordinate tanker truck pickups. An operator will oversee all material shipments from the Site and will ensure correct documentation is coordinated with the weigh scale operator.

Upon completion of Phase2, up to 24,000 m<sup>3</sup> of digestate can be stored on Site to accommodate seasonal variation in use. During seasons when digestate application is more in demand, digestate will be removed from Site more rapidly to free up available storage space. Digestate trucking may also be conducted during extended hours to accommodate agricultural operations.

Digestate will be loaded onto trucks through a digestate loading station that provides for both top and bottom loading options. The digestate filling station will be sloped to the containment area for the existing digesters and storage tanks. This containment volume will be sufficient for the largest digestate loading truck in the facility.

### 3.1.6 Air Treatment

Odorous air generated at the Site will be treated as described within Section 2.7.

### 3.1.7 Outbound Materials

Outbound materials include:

- Digestate
- RNG
- Residual waste
- Reject waste
- Organic paste/slurry, if required

Inbound trucks, including empty trucks to collect material from the Site, will be weighed at the inbound weigh scale. After collecting material from the designated storage areas, trucks will be weighed at the outbound weigh scale prior to leaving the Site. Truck traffic estimates are provided in Table 8 following the text.

## 3.2 Monitoring, Maintenance, and Reporting

### 3.2.1 Process Control

The facility will be operated by minimum of two operators per shift. A minimum of one operator is required to load and supervise the waste receiving/pre-processing operations and a second to operate the remaining digester feed, digestate, and biogas operations. Additional operators and staff will be on Site as required.

The plant will be controlled by a SCADA and PLC system. The pre-processing, pasteurization feed, RNG upgrading system, heat distribution, and flare will have a local control/PLC panel and will be connected to the main SCADA system for overall plant control. The control system will be designed in such a way that digesters and biogas management systems can run 24-hours per day/7-days per week without onsite- supervision during nights and weekends. These processes will run highly automated and will have a self controlling-ability. In case of irregularities,

the system will automatically go into safe mode and the operator will be informed via message on their cell phone. The operator can remotely log on via a secured connection to the SCADA system for remote process control if required.

An O&M Manual will be prepared and maintained at the Site based on the equipment installed and will be generated by the suppliers, installers, and contractors during the procurement and construction process.

### 3.2.2 Safeguard Controls

All tanks will be equipped with a low and high-level switch for safety to prevent overflowing or pump dry running.

Tanks which are connected to the air treatment systems will have an open fresh air inlet to prevent damage to the tank by over/under-pressure. Non-atmospheric tanks have mechanical and hydraulic over/under-pressure safety devices. In the current operation, the pressure relief valves in the digesters/storage tanks are set 2-3 mbar above the nominal operating pressure.

In the event, biogas cannot be utilized, a flare system will be used to burn the unused gas and prevent pressure buildup in the system.

The exact operating pressures of the new equipment will be determined during the detailed design phase of the project. The setpoints for the flare will ensure that the flare is turned on at pressures below the max allowable pressure for the system. The flare set point will also be set lower than the overpressure relief valve's set point.

Pumps will be protected against dry running, by application of low level- switches or integrated temperature/pressure switches.

All automatic valves will be equipped with open/close notification and control valves will have feedback of the actual valve position. Some manual valves have open/close notification as well, if this is relevant for process control.

Contingency valves not intended for normal operation will be secured in the desired position during normal operations to prevent use unless necessary.

### 3.2.3 Monitoring and Analyses

As a minimum, the following parameters will be monitored and analyzed:

*Table 3.1 Process Monitoring*

Process Location	Measurement	Method	Frequency
Inbound/Outbound Materials	Weight	Weigh bridge	Each load
	Waste type	Scale operator logs	Each load
Liquid receiving tanks	Level	Level Sensor	Continuous
	High Level	Level Switch	Continuous
	Temperature	Sensor	Continuous
Pasteurization (each tank and glycol loops)	Temperature	Thermocouple	Continuous
Digesters	Level	Level Sensor	Continuous
	Temperature	Sensor	Continuous
	Solids	Lab Analysis	Weekly
	VS, COD, nutrients	Lab Analysis	Monthly
Digestate	Solids	Lab Analysis	Monthly
	Quality (for end use)	Certified Lab Analysis	Per end-use requirements

Process Location	Measurement	Method	Frequency
Biogas	Flow	Flow Meter	Continuous or as required
	CH <sub>4</sub>	Sensor	Continuous or as required
	O <sub>2</sub>	Sensor	Continuous or as required
	CO <sub>2</sub>	Sensor	Continuous or as required
	H <sub>2</sub> S	Sensor	Continuous or as required
	Pressure	Sensor	Continuous or as required
Engine – Heat Distribution	Temperature	Sensors	Continuous
Odour treatment (biofilter)	Flow	Meter	Continuous
	Humidity	Sensor	Continuous
	Odour Units emission at stack	Certified lab	Annual

Additional analytical testing will be completed by operators to inform process adjustments using the on-Site laboratory located in the pump and pasteurization building.

### 3.2.4 Monitoring and Testing

Daily inspections include Site perimeter inspections for the presence of litter, sediment, excessive noise, or odour.

The three liquid receiving tanks constructed prior to 2022 were built with a perimeter tile around the bottoms of the tanks to collect potential leakage. There is a monitoring well to the northwest side of the Liquid Receiving Tank 1. In addition to tank leakage, the weeper collects ground water and transports it to the monitoring well from which it can be sampled by an operator.

The digester and storage tanks constructed prior to 2020 were built with a single perimeter tile to collect potential leaks and transport them to a central sump in the intermediate building. A new perimeter tile will be installed around the 4 new digesters and 2 new storage tanks similar to the existing tanks. This new perimeter tile will be connected to the same central sump as the existing one such that it allows inspection of the incoming water. Additionally, the level of liquid in the digester and storage tanks will be continuously monitored by an instrumentation and control system like the one on the existing tanks to indicate the presence of a leak. The continuous tank level monitoring for the new tanks will be integrated into the existing Site SCADA system.

Samples will be collected daily by operators from the monitoring wells and central sump as part of their regular inspections of the plant and visually inspected for unusual colour and odour. If the samples do show signs of unusual colour and odour, a sample is submitted to an analytical laboratory for pH, COD and optical density testing. If any of these parameters are atypical for historical groundwater conditions on the site, it is a sign that the tanks should be inspected.

Other inspection activities will include equipment inspections to determine maintenance needs and recording and adjusting process conditions per Section 3.2.3.

Routine testing of the incoming organic waste materials and digestate will be conducted to meet the quality criteria. All new incoming waste will be assessed for metal concentrations. In the absence of literature data, laboratory testing will be conducted for metal analysis. The digestate will be analysed for metals, foreign matters, plastics, and pathogens (Faecal coliforms and Salmonella) depending on the intended use and in accordance with the approved schedule by the ministry. Depending on the intended use and pathogen level, the digestate may be pasteurized prior to shipping off site.

Odour and reduced sulphur testing will be conducted in accordance with the approved schedule at the following sources: biofilter exhaust, grit/skimming building, and receiving tanks.

### 3.2.5 Preventative Maintenance

Escarpment Renewables uses a computerised maintenance management software (CMMS) system to track and assign routine monitoring. Site operators are provided with a schedule of inspections and maintenance actions to be performed daily, weekly, and monthly.

Preventative plant maintenance is carried out based on a pre-determined schedule. All moving parts are regularly greased and inspected. CHP Engine maintenance is carried out under contract to the supplier.

Cleaning and first line maintenance will be performed by the staff. Preventive maintenance and corrective maintenance items will be performed by staff, third-party company, or the equipment supplier.

### 3.2.6 Record Keeping and Reporting

On-Site records will be maintained of materials received, stored, processed, transferred, and sold, as well as the operational equipment.

Measurements of the following parameters are recorded in the daily log:

- Source, types, and weights of wastes received
- Types, weights, and destinations of all wastes transferred from the Site
- Materials rejected from the Site

Measurements of the following are also recorded and kept:

- Calibration and maintenance of monitoring equipment
- Records produced during any air treatment source testing
- Regulatory reports
- Site laboratory analytical data
- Record of bypass or malfunction of any part or equipment at the Site
- Complaints received and response forms (Complaint Management Reports)
- Emergency situation response

These records will be retained at the Site for at least 2-years and will be made available to the MECP District Manager or Environmental Officer upon request.

Other records that will be recorded and kept on Site include:

- Inspection Reports
- Maintenance Records
- Maintenance Activities
- Monitoring Records

An annual report will be prepared and retained on-Site at the end of March each year.

## 3.3 Secondary Containment

The liquid receiving tanks are constructed below grade and the unloading area is sloped to drains connected to the storage tanks. Should a spill occur during unloading, it will drain to the tanks and be contained.

The existing digesters and storage tanks are constructed below grade. A secondary containment area will be provided for the new digesters and digestate storage tanks, which will be constructed above grade. Secondary containment will include compacted clay base and berms, constructed to achieve a permeability of less than  $1 \times 10^{-6}$  cm/s. Alternatively, concrete or asphalt will be used to line the areas if the clay material on Site is not suitable for use as secondary containment. The berms will be a minimum 2.5 m depth, designed in accordance with the Guidelines for

Environmental Protection Measures at Chemical and Waste Storage Facilities. This provides for 100% of the volume of the largest tank in each containment area plus 10% of the aggregate volume of all other tanks and additional runoff for 100-year storm for the expanded site. Secondary containment calculations are provided in Table 11 following the text and show that the containment area provides the minimum required volume 844 m<sup>3</sup>.

Precipitation will accumulate in the secondary containment area. Minor flows will be directed to private storm sewers and overland to the new retention area. Major flows will be directed overland to the new retention area. The new retention area is designed for the runoff from rainfall events and the secondary containment. The retention area does not have a direct gravity outlet rather, it will be pumped to the east pond once it has available capacity. Routine visual inspection and continuous tank level monitoring will identify if a spill has occurred. In case of a spill, the material will be contained within the secondary containment area and disposed of according to the spill management & environmental safety protocol. Alternatively, the accumulated water will be used in the digestion process by mixing with incoming feedstock to achieve desired solids content and reduce the need to import water. This will be done on an as-needed basis. The secondary containment will have an area of approximately 4288 m<sup>2</sup>. Total annual precipitation from Environment Canada records for the Grimsby Mountain weather station are shown in Table 3.2 below for the past five years. The average annual precipitation is 986 mm. Therefore, approximately 4227 m<sup>3</sup> water will be available within the secondary containment area that could be utilized in the on-site anaerobic digestion process. Realistically, the water demand will be consistent, with precipitation varying seasonally. The feedstock mix will be altered as needed to maintain the desired solids content.

**Table 3.2** Average Annual Precipitation

Year	Total Annual Precipitation (mm)
2020	815
2019	1,141
2018	1,051
2017	1,175
2016	748
Average	986

The collection and use of precipitation from this area is not anticipated to impact existing water use, especially given the historical Site use was agricultural crop growth, which utilizes significant volumes of water.

If collected stormwater is determined to be contaminated, it will only be used in the digestion process, treated in a mobile treatment unit (MTU) under its own ECA or collected in tanker trucks to be managed off-Site at a wastewater treatment plant permitted to manage and process the contaminated water.

The 1,500 kilovolt-amp (kVA) transformer which will be employed in this application contains approximately 2,200 litres of oil and is located at the frontage of the property. Secondary containment is provided to contain a spill.

Buildings are constructed with concrete floors graded to contain interior drainage and spills. This will ensure that any spills will remain inside the building and will be collected and recycled into the process or disposed of if necessary.

The following spill response plan will be followed in the event of a spill at the Site and will be updated as necessary prior to commencing operations.

Generally, upon discovery, the Escarpment Renewables General Manager will assess the significance of the spill by considering the following factors:

- Location and cause/source of the spill
- Substance spilled and its hazard potential
- Amount of the spill and the extent of spreading
- Potential public or environmental impact

- Immediate actions required to protect on-Site staff
- Immediate actions required to contain the spill
- Notification and reporting requirements

Spills of liquid wastes brought to the Site and spills from tanks within containment areas will be contained quickly through the features discussed above. Spills may occur in other areas. Every reasonable effort will be made to minimize the area affected by the spill. The affected area will be cordoned off to prevent access. The spill will then be reported immediately.

Reportable spills will be reported immediately to the Spills Action Centre at the number provided in the emergency contacts in Section 3.9.

Information on spills must be recorded including names, times, type of spill, investigations and corrective actions taken.

Spill kits will be prepared and provided within the processing buildings.

If a spill is determined to be of such a magnitude that it cannot be safely and effectively controlled by on-Site personnel, then the General Manager shall promptly notify outside emergency response companies to implement control and clean-up.

In the event of a spill, restoration activities may be required if the spill is determined to have had an impact on the soil or groundwater. In this instance, specific plans will be developed to remediate or remove impacted materials and manage in accordance with provincial regulations.

## **3.4 Air Emissions**

Locations of potential air emissions are shown on the figure included in Appendix A. An Emissions Summary and Dispersion Modelling (ESDM) Report and Odour Study have also been prepared for the proposed expansion that detail the anticipated emission concentrations, location of sensitive receptors, and resulting point of impingement concentrations. These can be found in Appendix A and Appendix B respectively.

Air emission sources are described in the following subsections.

### **3.4.1 Trucks**

An estimate as to the number of trucks that will be required for incoming feedstock and outgoing material is provided in Table 8. Trucks represent a potential source of dust emissions that is evaluated in the ESDM Report.

### **3.4.2 Engines/Turbines**

Air emissions occur from the exhaust stack of the CHP as a result of combustion of biogas. Engine emissions include nitrous oxide, sulphur dioxide, and total reduced sulphur. The emissions are evaluated to confirm compliance with provincial regulations in the ESDM Report.

### **3.4.3 Flare**

The flare will be designed to combust 100% of the biogas produced at the Site in the event of malfunction or required maintenance of the CHP and RNG upgrading system. The flare will start automatically when needed. It is connected to the alarm system and its use is recorded in the computer system. Flare emissions include nitrous oxide, sulphur dioxide, and total reduced sulphur. The emissions are evaluated to confirm compliance with provincial regulations in the ESDM Report.

### 3.4.4 Over-Under Pressure Valves

The digesters and digestate storage tanks are equipped with over–under pressure relieving valves. These valves will release biogas to atmosphere in the event of an over pressure situation. The valves will only operate in the event the CHP, RNG upgrading system, and the flare are inoperable, which is not anticipated to occur.

### 3.4.5 Receiving Tank Displacement Air

The liquid/slurry/paste feedstock is delivered to Site in a sealed truck and transferred to the receiving tank via camlock connection or end-dumping. As the tank is filled there will be some air displacement. The primary emission of concern from this source is odour. The odour is evaluated to confirm compliance with provincial regulations in the Odour Study.

### 3.4.6 Boiler

A supplemental heat boiler is required for digester operation. The boiler is anticipated to be propane-fired and uses glycol to heat digester feedstock. Emissions from the boiler exhaust include nitrous oxides. The emissions are evaluated to confirm compliance with provincial regulations in the ESDM Report.

### 3.4.7 Biofilter Stack

The biofilter will treat air collected from within the organics pre-processing building where bulk solid organic waste is received and processed and residual waste is stored. Exhaust from the biofilter stack may contain ammonia, H<sub>2</sub>S, and odour. The emissions are evaluated to confirm compliance with provincial regulations in the ESDM Report. The odour is evaluated to confirm compliance with provincial regulations in the Odour Study.

### 3.4.8 RNG Upgrading System Tail Gas

The RNG upgrading system separates CH<sub>4</sub> from CO<sub>2</sub> and other contaminants for use as RNG. The remaining gas is primarily CO<sub>2</sub> with a small quantity of CH<sub>4</sub> slip, estimated at 1.5% of total CH<sub>4</sub> from the biogas. The RNG upgrading system tail gas may also contain some VOCs. The emissions are evaluated to confirm compliance with provincial regulations in the ESDM Report.

### 3.4.9 Digestate Loading Displacement Air

As digestate is loaded into tanker trailers, the air within the trailer that is exposed to the digestate will be exhausted. The primary emission of concern from this source is odour. The odour is evaluated to confirm compliance with provincial regulations in the Odour Study.

### 3.4.10 Digestate/Biogas Storage Tank Membrane Leakage

The digestate/biogas storage tanks will have double membrane roof systems. Some biogas will permeate the inner membrane and be exhausted from the interstitial space. The primary emission of concern from this source is odour. The odour is evaluated to confirm compliance with provincial regulations in the Odour Study.

### 3.4.11 Fugitive Emissions from Organics Pre-processing Building

Doors to the organics pre-processing building will remain closed at all times unless personnel are entering/egressing, or a truck is entering/exiting the building. While doors are closed, the building will be maintained under negative pressure to mitigate fugitive emissions from the Organics Receiving Building to any off-site sensitive receptor location. However, during the periodic door opening to allow a truck to enter, there is a potential for fugitive emissions of indoor air. The primary emission of concern from this source is odour. The odour is evaluated to confirm compliance with provincial regulations in the Odour Study.



## 3.4.12 Emergency Generator

The existing diesel emergency generator may occasionally be used if power is lost at the Site. Emissions from the emergency generator exhaust include combustion products. The emissions are evaluated to confirm compliance with provincial regulations in the ESDM Report.

## 3.5 Noise Emissions

Noise emission sources are discussed in the following subsections.

### 3.5.1 Trucks

An estimate as to the number of trucks that will be required for incoming feedstock and outgoing material is provided in Table 8 following the text. Trucks will travel to various parts of the Site as shown in Table 8. The speed limit noted in Section 3.8 will be enforced. Noise from the trucks is assessed in the AAR to confirm noise emissions meet provincial regulations.

### 3.5.2 CHP

The CHP is currently operational in an acoustic enclosure. Noise measurements during operation were collected and included in the AAR. Noise from the CHP is assessed in the AAR to confirm noise emissions meet provincial regulations.

### 3.5.3 Flare

The flare will require a blower to operate when the CHP and/or RNG upgrading systems are not operational. Noise from the flare is assessed in the AAR to confirm noise emissions meet provincial regulations.

### 3.5.4 Organics Pre-processing Building

The organics pre-processing building will contain a number of pieces of equipment including:

- Front-end loader
- Forklift
- Pumps
- Organic pre-processing units
- Residual waste compactors
- Conveyors
- Ventilation system fans for intake and exhaust

The construction materials of the doors and walls will mitigate the transmission of noises from within the building. Noise from the organics pre-processing building is assessed in the AAR to confirm noise emissions meet provincial regulations.

### 3.5.5 Pump and Pasteurization Building

The existing pump and pasteurization building contains mixing pumps and piston pumps to manage the transmission of digester feedstock to and from pasteurization. Noise measurements during operation were collected and included in the AAR. Noise from the pump and pasteurization building is assessed in the AAR to confirm noise emissions meet provincial regulations.

### 3.5.6 Tank Agitators

The liquid receiving tanks, digesters and digestate storage tanks are equipped with multiple agitators to keep the tanks mixed. The new digesters and digestate storage tanks will also have similar agitators. Noise from the agitators is assessed in the AAR to confirm noise emissions meet provincial regulations.

### 3.5.7 Digestate Skimming Buildings

Three digestate skimming buildings will be required to each manage digestate from two digesters. One digestate skimming building exists and noise measurements during operation were collected and included in the AAR. Noise from the digestate skimming buildings is assessed in the AAR to confirm noise emissions meet provincial regulations.

### 3.5.8 Backup Generator

The backup generator is existing and used in the event of a power outage. Noise measurements during operation were collected and included in the AAR. Noise from the backup generator is assessed in the AAR to confirm noise emissions meet provincial regulations.

### 3.5.9 RNG Upgrading System and Compression Systems

The RNG upgrading system and tube trailer compression systems will be located on the eastern portion of the site. Noise from the RNG upgrading system and compression systems is assessed in the AAR to confirm noise emissions meet provincial regulations. A berm will be installed along the eastern side of the site to mitigate noise emissions from the site to below the allowable limits as outlined in the AAR.

## 3.6 Operating Hours

The Site will be opened to receive materials:

- Monday – Saturday: 7:00 AM to 7:00 PM

Waste processing/management, Digestion, Odour Treatment, Biogas Management and other such operations, as well as maintenance, will occur 24-hours a day, 7-days a week

Digestate removal will occur:

- Monday to Saturday: 5:00 AM to 9:00 PM

## 3.7 Staffing and Training Requirements

The Site will require the following staff:

- Weigh scale attendant(s)/administrators to be present for receiving and monitoring inbound and outbound materials, entering information in Site records, directing traffic, and other administrative duties
- General Manager responsible for overall Site operations and inbound/outbound material contracts
- Facility operator(s) responsible for control of process equipment, adjustment to operating conditions, generation of digester feed mix
- Operation and maintenance personnel responsible for general maintenance of equipment, routine inspections, and cleaning

Staff at the weighbridges and operators will be trained in the identification of approved waste types, hazardous materials, and large contamination. The purpose of the training will be to understand and comply with waste manifestation and tracking requirements, ensure only waste licensed for acceptance at the Site is received, reject and

document waste that is not licensed for acceptance at the Site, and identify and communicate contamination to operators responsible for removal.

Operators, supervisors, managers, and maintenance teams will be trained in the safe use and care of the equipment installed at the Site. An O&M Manual will be prepared and maintained at the Site based on the equipment installed and will be generated by the suppliers, installers, and contractors during the procurement and construction process. Site personnel will be aware of the O&M Manual, its contents, and use.

Operators, supervisors, and managers will be trained in the use of the Site control systems through the HMI and SCADA system.

All staff will be provided with Health and Safety training, including Site-specific training based on the chemicals and materials present at the Site. Training will include what to do in case of emergency for health-related emergencies, fire emergencies, and other catastrophic events. Health and Safety training will be handled by service providers or in-house programs.

Most process related training will be handled through on the job training by experienced operators or staff. Environmental training is process and site specific and will be handled in-house. Environmental training is focused on odour control and spill control.

All staff will be trained in environmental emergency procedures including what to do in case of a spill.

Training requirements will be reviewed annually and new or refresher training provided as required.

## 3.8 Traffic Management

Truck volumes have been estimated based on an average breakdown of material per waste type. The total weekday and Saturday truck traffic estimates when operating at maximum capacity are provided in Table 8 following the text.

Approximately four trucks per hour are anticipated to arrive at the Site. This is a conservative estimate given the inclusion of RNG tube trailer pickups, which are not expected to be conducted on a daily basis. At this rate, minimal queuing is expected and will be limited to peak hours. Trucks coming to the Site will be staggered to the extent possible to maintain traffic routes and avoid queuing. Should any queuing be required, trucks can bypass the scale and circle the perimeter road to queue along the northern portion of the on-Site access road. No trucks will queue on Sobie Road.

On-Site speeds are posted and limited to 15 km/hr.

## 3.9 Environmental Emergency and Contingency Plans

### 3.9.1 Emergency Contacts

Contacts in case of an emergency are provided in the table below.

Table 3.3 Emergency Contacts

Emergency	Phone Number
Ambulance	911
Fire Department	911
Police (emergency)	911
Police (non-emergency)	905-945-2211
Spills Action Centre	416-325-3000 or 1-800-268-6060

An emergency after hours' number will be posted on the sign at the entrance to the Site.

## 3.9.2 Emergency Response Plans

An Emergency Response Plan (ERP) is available for the Site and routinely updated. The ERP covers requirements for fires, accidents, and spills and also includes a Fire Safety Plan. A review of the plan is undertaken annually and updated as required. The current Site ERP and Fire Safety Plan can be found in Appendix G.

The ERP documents the roles and responsibilities of the operating staff and other organizations in responding to various types of on-Site emergencies.

The ERP documents the on-Site equipment and/or materials necessary to be available at the Site to respond to the emergencies.

Communication of the contents of the ERP will be completed during employee training.

## 3.9.3 Contingency Plans

### 3.9.3.1 Equipment Failure

The equipment used on-Site is capable of 24-hour, 365-days-per-year operation.

A preventive maintenance schedule will be in place to minimize the possibility of an equipment failure and documented in the O&M Manual. A procedure will be in place to monitor the causes of failures and to prevent repeat occurrences.

An inventory of spare parts will be maintained on Site.

In the event of a mechanical breakdown at the Site that causes the Site to be temporarily unable to process waste solids, waste solids will be temporarily stored in the receiving areas until the storage capacity is reached. If the storage capacity is fully utilized, waste solids will be redirected to another licensed processing/disposal facility.

If another facility is not available that can handle the material, the waste solids will be disposed of as municipal waste at a licensed facility until normal operations resume.

In the event of a mechanical breakdown at the Site that causes the Site to be temporarily unable to process liquid waste, liquid waste will be temporarily stored in the liquid waste storage tanks until the storage capacity is reached. If the storage capacity is fully utilized, liquid waste will be redirected to another licensed processing facility or shipped back to the supplier.

In the event of a mechanical breakdown or biological upset that causes the anaerobic digestion operation to be temporarily unable to receive feedstock, one digester can be taken out of service while the others continue to operate. If inadequate digester capacity is available at the site, the digester feed tanks will be pumped (using an emergency emptying connection at the tank and a temporary pumping system into tanker trucks for off-Site disposal at licensed facilities and/or used as a feedstock for anaerobic digestion processes if appropriate.

Adequate redundancy has been incorporated into design to tackle mechanical breakdown or system maintenance. If a liquid receiving tank is out of operation (i.e., clean out), the site is still able to properly operate using the other 2 tanks. The liquids receiving tanks are relatively small and easily accessible, a cleanout can typically be done in one day.

Pre-processing units will provide redundancy inherently, more shifts can be run on one unit to meet the pre-processing needs. In case the processing rate cannot keep up, temporary storage will be utilized up to the maximum limit and any further material receipt would have to be halted or diverted to other pre-processing site and the pre-processed material can then be returned to the site

Digester feed pumps are plumbed to be able to feed from any tank and to any tank. This will provide considerable redundancy for system reliability and operability. Critical spare parts are kept on site for timely repairs. Multiple digesters will allow flexibility and redundancy for operations; additionally, the new digesters will be self-cleaning greatly reducing the need for cleanout shutdowns.

On completion of Phase 2, there will be up to 4 digestate storage tanks, and any downtime can be scheduled during the Spring-Fall months so that digestate can be directly applied to the farm field without having to be held in the storage tanks for lengthy periods of time or transferring the digestate to additional lagoon storage which will be secured through contract with local farmers. One of the contingencies for any time when the digestion process capacity is decreased would be to ship paste/slurry to other processing sites (e.g., during digester maintenance).

There will also be redundancy in the skimming system by connecting each digester to at least two skimming systems.

### **3.9.3.2 Electrical Outage**

The Site's general building systems, including heating, ventilation and air conditioning (HVAC) building management system, as well as the waste pre-processing systems, pasteurization, anaerobic digestion, digestate management, biogas management, and residue management systems are electrically powered.

Loss of electrical power is not an emergency for the Site. All relevant valves and systems will have failsafe operation in case of power outage. The flare will not extinguish unless biogas production ceases, and will not be affected by electricity outages, thereby providing capacity for biogas management in the event of an electrical outage.

A backup diesel generator is available at the Site to maintain critical systems during an electricity outage. This allows the Site to maintain operations during short term outages.

The Site will not receive waste during a prolonged electricity outage where the diesel generator is not able to maintain the Site operations. In this event, material will be diverted back to the supplier or disposed of at a licensed off-Site facility. Normal deliveries will resume when the electricity supply is restored.

During an electricity outage and in event the operation of the organics pre-processing building HVAC system will be interrupted, the building receiving doors will remain closed to minimize fugitive odour release. The backup generator may be used to maintain the HVAC system operation if sufficient power for other critical operations is available as well otherwise, additional portable generators will be used as needed.

## **3.10 Site Inspections and Nuisance Controls**

### **3.10.1 Dust and Litter Control**

Areas within the Site that have truck traffic are paved and thus are unlikely to create dust. Inspections will be undertaken for dust and litter will be communicated immediately to the General Manager and recorded. Issues with dust will be dealt with immediately by tracing the issue back to the source and dealing with it through appropriate means such as water spraying for dust on roadways. The high moisture content of the feedstock, residual waste, and the digestate materials managed at the Site minimize the potential for dust emissions. All incoming waste is stored and processed indoors.

The primary source of litter at the Site is from material that falls from trucks. Unloading of SSO and ICI material takes place within the receiving bays of the organics pre-processing building with doors closed. Plastic and grit residual is loaded onto tractor trailers located inside the organics pre-processing building and a residual press is used to remove excess liquid from the waste.

Daily perimeter monitoring is conducted per Section 3.2.4 to identify the need for cleaning, which will be conducted by Site personnel.

### **3.10.2 Noise Control**

The primary sources of noise expected at the Site include:

- Incoming and outgoing truck traffic
- Mechanical equipment such as pre-processing equipment, pumps, blowers, front end loader, RNG upgrading system

- CHP

Trucks transporting incoming feedstock and outgoing material are on Site for a minimum amount of time where possible, and with a minimum of truck idling and minimal queuing, which limits the impact of excess vehicular noise on the Site. On-Site speed limits will be posted at 15 km/hr.

The majority of the mechanical equipment contained at the Site is enclosed within a building and is not expected to generate significant noise outside of the AD facility. The doors of the receiving bays will remain closed except to admit vehicles, minimizing potential noise from internal operations.

Issues with respect to noise will be communicated immediately to the General Manager and recorded. Issues with noise will be dealt with immediately by tracing the issue back the source and dealing with it through appropriate means such as closing doors or instructing drivers not to idle.

### 3.10.3 Odour Prevention and Control

All incoming waste unloading, storage, and pre-processing activities will occur within the organics pre-processing building, or enclosed tanks. The organics pre-processing building will be equipped with air ventilation systems, discharging to air treatment systems. Interlocking bay doors will be installed to ensure desired pressure level can be maintained within the preprocessing building. Refer to Section 2.7 for more information on the air treatment systems.

To reduce the air treatment volume required, air will be cascaded throughout the organics pre-processing building (i.e., air from clean areas will move to areas with more contamination to reduce outside air intake and overall air flow treatment requirements). This building will operate under negative pressure with the exception of the electrical, control, and administrative areas, which will have designated ventilation systems under positive pressure.

Liquid receiving tanks will be enclosed during normal operations to reduce the release of odours from the tanks.

Daily inspections will be conducted of waste receiving operations. This will include all door seals and loading dock seals and other openings to prevent fugitive odour emissions. Daily perimeter inspections for the presence of odour will also be conducted.

Leaks and spills within the organics pre-processing building will be corrected quickly, and floors will be washed down to minimize odour within the building. Spilled materials on the roadways on the Site will be cleaned up and neutralized as necessary.

Odour monitoring will be an integral part of daily Site operations. The goal of odour monitoring will be to identify potential odour sources which enables proactive implementation of odour prevention and control measures. Odour monitoring will include on-Site inspections and off-Site inspections in the event of an odour concern. Current information on wind speed and direction will be obtained from an on-Site weather station in the event of an odour concern. The findings of the odour concern inspections will be recorded in the daily operations log.

The General Manager will review the daily operations logs and records of complaint/incident forms when applicable. If trends of odour sources develop, additional monitoring and strategies will be developed to reduce or eliminate causes.

#### **Potential Odour Sources and Contingency Plan**

Potential odour sources are identified in Section 3.4.

The following Odour Contingency Plan is proposed for the Site:

- The biofilter will have redundant capacity, capable of operating at a higher volume to surface area loading rate if needed to manage short-term- odour concerns
- In case of an extended power outage, the backup generator (plus any additional portable generators) will maintain building ventilation.
- Space is reserved in the layout for an additional treatment step before or after the biofilter

Refer to the Odour Study for further odour management practices.

### 3.10.4 Odour Complaint Response

The odour complaint response procedure is provided in the Odour Study.

### 3.10.5 Pest Control

The Site will maintain good housekeeping procedures to discourage vector and vermin. Potential sources of attraction are with material located within enclosed buildings. The Site will be cleaned on a regular basis to minimize the potential of vermin.

The Site is equipped with rodent traps and bug zappers to prevent pests. If vector or vermin are discovered, the Site will hire a qualified pest control professional to control the nuisances. In general, maintaining the facilities in clean conditions, keeping waste storage indoors, and following guidance of professional pest control specialists should keep the vector and vermin to a minimum at the Site.

## 3.11 Fencing and Security

There is an existing fence surrounding the majority of the Site as shown on Figure 2. The fence will remain or be upgraded as shown in Figure 3 to provide security. In addition, security cameras are installed to provide surveillance. Site access is controlled and monitored through a sign in system which will record all Site personnel and visitors accessing the Site.

## 4. Stormwater Management

The REA requires stormwater management in the form of a sediment basin with a total capacity of 675 m<sup>3</sup>. The two existing ponds include a west pond and an east pond that are interconnected by a series of culverts between them. The east pond drains into the west pond. The estimated total volume of the two ponds is approximately 3,000 m<sup>3</sup>.

The ponds currently receive runoff from the perimeter ditch and the central area around the existing digesters, servicing the currently -developed portion of the property (approximately 4 ha). The discharge from the west pond is directed along a swale running to the southwest corner of the Site and discharging to existing drainage features consistent with the historical use of the property as an agricultural field. The stormwater runoff from the pre-expansion area will continue to be directed towards the existing ponds.

A secondary containment system will be constructed for the new above -grade tanks, with an area of approximately 0.4 ha. This area will contain stormwater, which will either be used in the AD process, or discharged to the head of the east stormwater management pond if not needed and deemed to not be impacted by site operations. This pumping will be done during periods where the stormwater ponds have capacity to manage the volume of water to be pumped. The total drainage area that the stormwater ponds will be servicing post--expansion is approximately 6 ha, which is higher than the current conditions (approximately 4 ha). The proposed retention area will have the capacity to accommodate entire runoff from the 100-year storm plus the volume requirement for the secondary containment of the new digesters and tanks. Therefore, in spite of increase in direct -flow service area, the combined volume of the existing ponds (approximately 3,000 m<sup>3</sup>) and proposed secondary containment (approximately 11,000 m<sup>3</sup>) are sufficient and larger than that required by the current REA and no changes are proposed to the stormwater management ponds.

Silt fencing is installed and will be maintained along the western property line a minimum 3 m from the edge of an existing drainage area to prevent migration of sediment during construction of the Site. The existing drainage is vegetated, and any vegetation removed as part of the construction will be restored following construction and prior to any silt fence being removed. The stormwater management ponds collect runoff from the Site and provide sedimentation. A silt sock exists in the effluent ditch from the existing stormwater management ponds to further protect the downstream receiving environment from potential sediment migration from the stormwater management ponds.

## 5. Environmental Effects

The existing operation and proposed expansion provide many positive environmental effects including:

- Diverting organic waste from landfill to support the growing demand for organic waste management options needed to meet the goals of the Strategy for a Waste-Free Ontario
- Generates renewable energy in the form of both electricity and RNG
- Recovering nutrients in the form of digestate fertilizer for reuse in agricultural operations in accordance with the Resource Recovery and Circular Economy Act and Food and Organic Waste Policy Statement
- Reducing pathogens to an acceptable level in the digestate

However, the operations have potential environmental effects that are detailed in Table 5.1 along with mitigating features and procedures to be implemented.

**Table 5.1** Potential Environmental Effects

Environmental Effect	Performance Objective	Mitigation
Noise Emissions	Meet Provincial Standard	<p>The organics pre-processing building will have noise ratings for the pre-engineered steel structure established to provide a minimum standard to ensure noise mitigation for sources within the building.</p> <p>The CHP and backup generator have acoustic enclosures.</p> <p>A berm will be constructed on the eastern portion of the Site to mitigate noise mainly from the RNG Facility.</p> <p>Truck traffic noise will be mitigated through the implementation of on-site speed limits and a no idling policy.</p>
Odour	Meet Provincial standard	<p>Liquid receiving tanks are closed to minimize the possibility of fugitive odour emissions.</p> <p>The Organics Pre-processing Building is fully enclosed and maintained under negative pressure with doors closed at all times unless personnel or trucks are entering/exiting.</p> <p>Digestate is fully contained.</p> <p>Digestate/biogas storage permeability requirements are met.</p> <p>Also see the Odour Study Report.</p>
Air Emissions	Meet Provincial standard	<p>The CHP, backup generator, RNG upgrading system, boiler and flare emissions will be designed to meet Provincial standards.</p> <p>Also see the ESDM report.</p>
Spills/Leaks	None	<p>The potential for spills at the Site is minimized by the design of the facilities including the use of a perimeter road and secondary containment to prevent contact between tanks and vehicles.</p> <p>The liquid receiving tanks are lined to reduce potential for leaks. All waste is stored and processed indoors with concrete foundations and sumps to minimize potential for leaks.</p> <p>Cam lock connections and grading around liquid receiving tanks ensure that the possibility of spillage is minimized and contained.</p> <p>All above -grade tanks are contained in a secondary containment system designed in accordance with the Guidelines for Environmental Protection Measures at Chemical and Waste Storage Facilities.</p>



Environmental Effect	Performance Objective	Mitigation
Siltation Control	None	Silt fencing will be installed at the western perimeter of the Site and in construction areas. After construction is complete, the disturbed area is to be seeded to prevent erosion from occurring. The stormwater ponds are existing and contain additional erosion and sedimentation protection through the use of silt socks.
Natural Heritage Impacts	None	<p>Potential natural heritage impacts were identified during the initial development of the Site and remain the same for the expansion. These included:</p> <p>Noise impacts (identified above)</p> <p>Siltation impacts (identified above)</p> <p>Potential for winter deer congregation</p> <p>Lighting</p> <p>Consistent with the mitigation measures proposed for the Site development, 3.2-m high fence will be considered to prevent deer entering the Site and new lighting will be installed downward facing to prevent adverse effects to the surrounding natural environment.</p>

Neither the construction of the project nor its long-term operation will have an adverse effect on the surrounding environment. The woodland to the south will remain untouched. There are no archaeological or heritage resources identified in the area.

## 5.1 Groundwater Monitoring

The entire Site is visually checked daily by the operator and any issues are documented and repaired as required. Inspection and record keeping procedures are described in Section 3.2. The facility operator is also provided with a cell phone that is directly connected to the facility alarm system. As a result, the plant is monitored 24-hours a day, 7-days a week and any repairs required can usually be completed by telephone or internet connection.

Before proceeding with Phase 1 the monitoring wells will be monitored in accordance with the Hydrogeological Assessment Report for the potential presence of groundwater impacts from the operations. Baseline groundwater quality will be established by monitoring the wells over a period of 4-years. Should potential impacts be identified, they will continue to be monitored to evaluate the potential for off-Site impacts. All potential contaminants of concern and their relevant trigger level, and contingency plan will be developed and submitted to the director for approval. Following the baseline period, groundwater monitoring will be annually. Mitigation and contingency measures will be developed on a case-by-case basis but could include the removal of liquid from underground tanks to isolate and complete repairs due to leaks. Such incidents will be recorded and notified to the MECP District Manager.

## 5.2 Communications

As part of the expansion, Escarpment Renewables will complete engagement activities with the public, including provision of notification through newspaper advertising and publishing documentation on their website. A public consultation meeting will also be held to provide the public with details of the proposed expansion. A Consultation Report will be prepared to document any public comments and responses.

A sign will be posted on site with the name and contact information for concerns or complaints. In addition, key emergency information such as fire, police, ambulance and the MECP spills action centre will be on the sign. Emergency procedures are maintained within the ERP.

All correspondence to the owner received from the public or agency will be recorded by Escarpment Renewables and a response provided. Spills will be reported to the MECP Spills Action Centre.

## 6. Operational Flexibility

Table 6.1 outlines the areas of operational flexibility for the Site. The design presented in this D&O report is the base case. The potential modifications outlined below will not result in additional adverse impacts on the environment outside of regulatory limits. Should the base case be modified Escarpment Renewables will provide the local district office with a letter outlining the modification and any revised technical reports requiring updates to demonstrate that the modification has not resulted in additional adverse impacts to the environment outside of regulatory limits.

**Table 6.1** Operational Flexibility Options

Design	Base Case	Potential Modification
Organics pre-processing	Two pre-processing units within the organics pre-processing building.	Flexibility to install additional pre-processing units with similar or different technologies, providing that the overall pre-processing throughput remains the same.
New digesters	Four new self-cleaning digesters with a volume of 3,435m <sup>3</sup> each.	Flexibility to install two to six new digesters providing the minimum HRT and organic loading rate remains in the same range.
New digestate/biogas storage tanks	Two new digester/biogas storage tanks with a liquid volume of 8,000m <sup>3</sup> each.	Flexibility to install a pad-mounted biogas bladder instead of the second digestate/biogas storage tank. This will serve as additional biogas storage only, if required.
Digester technology	A digester technology which contains a skimmer and floor sweeper to remove light and heavy fractions from the digesters.	<ul style="list-style-type: none"> <li>– Flexibility to utilize additional pre-processing equipment to remove light and heavy fractions or build in additional digester volume to account for grit accumulation instead of utilizing skimmer and floor sweeper technology.</li> <li>– Flexibility to incorporate substrate pre-treatment technologies for enhancing biogas yield</li> <li>– Flexibility to implement alternative pasteurization technologies.</li> </ul>
Feedstock receiving area within the organics pre-processing building	It is currently proposed to utilize a front-end loader on the tipping floor to manage the incoming solid feedstock in the organics pre-processing building.	Flexibility to use a pit and grapple system given that the storage volumes remain the same.
Odour management technology	Biofilter for odour management within the organics pre-processing building.	<ul style="list-style-type: none"> <li>– Flexibility to select a different technology or media (organic or inorganic).</li> <li>– Flexibility to increase number of media cells</li> </ul>
RNG Upgrading System	PSA or Membrane for CO <sub>2</sub> removal and Activated carbon/iron oxide for biogas pre-treatment	<ul style="list-style-type: none"> <li>– Flexibility to utilize a different technology for CO<sub>2</sub> removal and equipment for pre-treatment.</li> <li>– Flexibility to distribute total capacity into two or more parallelly operating units (~900m<sup>3</sup>/hr capacity each)</li> </ul>
RNG Injection or transportation	RNG is currently planned to be compressed into tube trailers prior to transportation off Site.	Flexibility to inject RNG directly into an onsite natural gas pipeline.
Site Layout	Proposed Site Layout (Figure 3)	<ul style="list-style-type: none"> <li>– Flexibility to change equipment locations</li> <li>– Flexibility to change berm dimension and location to mitigate noise level as assessed in the AAR</li> </ul>

The Site will be developed in phases to allow for progressive expansion as waste receiving volumes are realized. Table 6.2 provides the number of units of infrastructure that will be installed during each Phase. Phase 0 represents the existing Site conditions.

**Table 6.2**      *Operational Envelope*

<b>Equipment</b>	<b>Phase 0 (Existing)</b>	<b>Phase 1</b>	<b>Phase 2</b>
Inbound Scale	1		
Outbound Scale		1	
Office Building	1		
Staff Building	1		
CHP	1		
Organics Pre-processing Building		1	
Waste Pre-processing Unit		1	1
Pasteurization Lines	2		
Boiler	1	1	
Liquid Receiving Tanks	3		
Plug Flow Digesters	2		
Existing Digesters	2		
New Digesters		2	2
Existing Digestate Storage Tanks	2		
Biogas Storage Bladder	1		
Digestate Storage Tanks with Biogas Storage		1	1
Secondary Containment Area		1	
Digestate Skimming Systems/Buildings	1	1	1
RNG Upgrading System		1	1
Flare	1	1 (replace existing)	
Stormwater Ponds	2		
Biofilter		1	

The existing infrastructure in Phase 0 was sized to receive up to 33,000 tonnes per year of incoming material. Prior to construction and commissioning of the expansion the Site will receive up to 33,000 tonnes per year of incoming material as outlined in Table 6.3 which provides the annual waste limits for each Phase.

**Table 6.3 Annual Tonnage Limits by Implementation Phase**

Waste Type	Annual Tonnes		
	Phase 0 (Existing)	Phase 1	Phase 2
Agricultural Waste	7,000	7,000	7,000
SSO (pre-processed and/or unprocessed)	33,000 <sup>(1)</sup>	75,000	120,000
ICI Packaged	0	25,000	100,000
ICI Liquid	10,000	38,000	100,000
Maximum total	33,000	120,000	159,000

Notes:

<sup>(1)</sup> pre-processed only

The maximum annual tonnes in feedstock composition are intended to provide the AD facility with the flexibility to change the composition of the total combined feedstock to suit current AD facility operation conditions, changing organic waste market conditions, optimize biogas production and AD facility performance. The annual composition of waste received may consist of any combination of the above waste types and not exceeding a combined maximum of tonnes per year per phase.

A change log is provided in Appendix E, providing details of revisions made to the Site under operational flexibility.

## 7. Financial Assurance

In accordance with MECP Guideline F-15, Financial Assurance (FA) is normally required for all private waste processing sites. FA for the Site has been calculated in accordance with this Guideline and is included in Appendix E.

# Tables

**Table 7**  
**Mass Balance**  
**Design and Operational Report**  
**Escarpment Renewables, Grimsby Anaerobic Digestion Facility**

Incoming Waste	Amount	Amount	Amount	Units
	Phase 0	Phase 1	Phase 2	
Total processed waste volume	33,000	89,920	142,342	Tonnes
Processed waste solids	18%	18%	19%	Percent
Contaminants, Avg (SSO)	0%	13%	13%	Percent
Contaminants, Avg (ICI)	0%	5%	5%	Percent
Proportion Solids	70%	64%	68%	Percent
Proportion Liquids	30%	37%	32%	Percent
Raw Waste, Solids	23,100	63,500	108,850	Tonnes
Raw Waste, Liquids	10,000	37,000	50,000	Tonnes
Raw Waste, Total	33,000	100,000	159,000	Tonnes
Average daily solid waste receipt*	76	189	319	Tonnes
Average daily liquid waste receipt	33	121	166	Tonnes
Average feedstock volatile solids	85%	82%	82%	Percent
* Average daily solid waste receipt represents the raw SSO waste before de-packaging as well as the preprocessed SSO and slurry				

**Table 7**  
**Mass Balance**  
**Design and Operational Report**  
**Escarpment Renewables, Grimsby Anaerobic Digestion Facility**

Waste Processing	Amount			Units
	Phase 0	Phase 1	Phase 2	
SSO incoming, avg	23,000	64,000	109,000	Tonnes
ICI Liquids incoming, avg	10,000	36,000	50,000	Tonnes
SSO, processed	23,000	55,936	95,266	Tonnes
ICI, processed	10,000	34,200	47,500	Tonnes
SSO solids	0%	27%	27%	Percent
ICI Liquids Solids	5%	5%	5%	Percent
Total solids of average mix	4,140	16,813	28,097	Tonnes
Solids of average mix	18%	18%	19%	Percent
Target solids to digester	20%	20%	20%	Percent
Liquids from dewatering press		2,700	5,400	Tonnes
Total mix to digester	33,000	92,836	148,166	Tonnes
Residual Waste, avg		6,300	12,600	Tonnes

**Table 7**  
**Mass Balance**  
**Design and Operational Report**  
**Escarpment Renewables, Grimsby Anaerobic Digestion Facility**

Digestion	Amount	Amount	Amount	Units
	Phase 0	Phase 1	Phase 2	
Total digester capacity	4332	11,202	18,072	m <sup>3</sup>
Existing Digester (2,166 m <sup>3</sup> ) loading rate	45	50	48	m <sup>3</sup> /day
Existing Digester (2,166 m <sup>3</sup> ) organic loading rate	3.5	3.3	3.3	kg VS/m <sup>3</sup> d
New Digester (3,435 m <sup>3</sup> ) loading rate		79	76	m <sup>3</sup> /day
New Digester (3,435 m <sup>3</sup> ) organic loading rate		3.3	3.3	kg VS/m <sup>3</sup> d
Retention time	48	44	45	days
Inerts	10%	10%	10%	Percent
VS conversion	80%	80%	80%	Percent
Solids not converted	1,448	3,971	6,276	Tonnes
Digestate	25,773	65,700	115,763	Tonnes
Digestate Solids content	<3%	<3%	<3%	%

---



**Table 7**  
**Mass Balance**  
**Design and Operational Report**  
**Escarpment Renewables, Grimsby Anaerobic Digestion Facility**

Biogas Management	Amount	Amount	Amount	Units
	Phase 0	Phase 1	Phase 2	
Biogas Yield	123	106	104	m <sup>3</sup> /Tonnes
Biogas Flow	462	1,210	1,883	m <sup>3</sup> /hr
Utilized in CHP	462	500	500	m <sup>3</sup> /hr
Biogas Flow for RNG		710	1,383	m <sup>3</sup> /hr
Biogas Methane Content	60%	60%	60%	%
Methane Recovery		98.5%	98.5%	Percent
RNG Flow		420	817	m <sup>3</sup> /hr
Uptime		95%	95%	Percent
Annual Flow		3,491,377	6,802,511	m <sup>3</sup> /yr
HHV RNG		37.67	37.67	MJ/m <sup>3</sup>
HHV		131,520	256,251	GJ/yr
Methane density at 38C, 14.5 psi		0.621	0.621	kg/m <sup>3</sup>
Methane, assumed 100% RNG for simplicity		2,168,145	4,224,360	kg/yr
Methane moles per kg		62.3346	62.3346	moles/kg
Methane Mole (n)		135,150,408	263,323,677	moles/yr
Gas Constant, R		8.3144626	8.3144626	m <sup>3</sup> *Pa/mol*K
Compressed pressure		3,600	3,600	psi
Compressed pressure		24,821,136	24,821,136	Pa
Temperature		311.15	311.15	K
V (Compressed)		14,086	27,446	m <sup>3</sup> /yr

Table 8

Truck Traffic Estimate  
Design and Operations Report  
Escarpment Renewables, Grimsby Anaerobic Digestion Facility

WEEKDAYS - Max Daily Truck Count <sup>1</sup>												
Incoming	Volumes (tonnes/year)	Volumes (m <sup>3</sup> /year)	Transfer Trailer (small)	Transfer Trailer (large)	Collection Trucks	Walking Floor Trailers (small)	Tube Trailers (small)	Tube Trailers (large)	Tanker Trucks (medium)	Tanker Trucks (large)	Roll-Off Trucks (large)	Notes
SSO 1	80,353	123,620		4							8	Remaining SSO Divided equally amongst large transfer trailer, and large roll-off trucks
SSO 2 (local)	9,941	15,293			6							
ICI Liquid	41,419	41,419							5	3		Maximum 12,000 tpy curbside collection Total ICI Liquid divided equally between medium and large tankers
<b>TOTAL</b>	<b>131,713</b>	<b>131,713</b>		4	6				5	3	8	
Outgoing												
Total Residuals	18,324	22,905	2	1								Total residuals divided equally between small and large transfer trailers
RNG		25,349					1	1				Converted RNG volume assuming 100% methane at 14.5 psi and 38C to volume at 3600 psi 38C and divided equally amongst small and large tube trailers
Digestate	102,403	102,403								16		Total digestate concentrated to 8 months of the year and spread over longer daily operating hours
<b>TOTAL</b>	<b>120,726</b>	<b>120,726</b>	2	1			1	1		16		
Noise Source ID												
T1	Daily total for Processing Area Trucks			18	per hour	1.50						
T2	Daily total for Liquid Loading Trucks			8	per hour	0.67						
T3	Daily total for Residuals Area Trucks			3	per hour	0.25						
T4	Daily total for RNG Area Trucks			2	per hour	0.17						
T5	Daily total for Digestate Trucks			16	per hour	1.00						
					TOTAL	3.58						

SATURDAYS - Max Daily Truck Count <sup>1</sup>												
Incoming	Volumes (tonnes)	Volumes (m <sup>3</sup> /year)	Transfer Trailer (small)	Transfer Trailer (large)	Collection Trucks	Walking Floor Trailers (small)	Tube Trailers (small)	Tube Trailers (large)	Tanker Trucks (medium)	Tanker Trucks (large)	Roll-Off Trucks (large)	Notes
SSO 1	16,647	25,611		4							8	Remaining SSO Divided equally amongst large transfer trailer, and large roll-off trucks
SSO 2 (local)	2,059	3,168			6							
ICI Liquid	8,581	8,581							5	3		Maximum 12,000 tpy curbside collection Total ICI Liquid divided equally between medium and large tankers
<b>TOTAL</b>	<b>27,287</b>	<b>27,287</b>		4	6				5	3	8	
Outgoing												
Total Residuals	3,796	4,745	2	1								Total residuals divided equally between small and large transfer trailers
RNG		5,252					1	1				Converted RNG volume assuming 100% methane at 14.5 psi and 38C to volume at 3600 psi 38C and divided equally amongst small and large tube trailers
Digestate	21,215	21,215								16		Total digestate concentrated to 8 months of the year and spread over longer daily operating hours
<b>TOTAL</b>	<b>25,011</b>	<b>25,011</b>	2	1			1	1		16		
Noise Source ID												
T1	Daily total for Processing Area Trucks			18	per hour	1.50						
T2	Daily total for Liquid Loading Trucks			8	per hour	0.67						
T3	Daily total for Residuals Area Trucks			3	per hour	0.25						
T4	Daily total for RNG Area Trucks			2	per hour	0.17						
T5	Daily total for Digestate Trucks			16	per hour	1.00						
					TOTAL	3.58						

Notes  
1 - Calculations round up to nearest truck, providing a worst case scenario

Table 8

Truck Traffic Estimate  
Design and Operations Report  
Escarpment Renewables, Grimsby Anaerobic Digestion Facility

**ASSUMPTIONS**

	Daily hours	
Incoming		
Weekday (Hours)	60	12
Saturday (hours)	12	12
Outgoing		
Weekday (Hours)	60	12
Saturday (hours)	12	12
Digestate	16	16
Working weekdays/year	251	
Working Saturdays/year	52	
Working Digestate Weekdays/Year	168	
Working Digestate Saturdays/Year	35	

**Waste Volumes**

Incoming	Gross Volume	Net Volume	Residual Waste Volumes	Volume for Collection Trucks	Volume for Remaining Trucks
SSO	109,000	89,380	19,620	12,000	97,000
SSO/ICI Liquid	50,000	47,500	2,500		
<b>Outgoing</b>					
Residual SSO	19,620	19,620			
Residual ICI	2,500	2,500			
Total Residuals	22,120	22,120			
RNG (compressed)	30,601	30,601			
Digestate	123,618	123,618			

Truck Types	Typical Truck Capacities	Assumed Truck Capacities (m <sup>3</sup> )	Notes
Transfer Trailers	13.6 - 22.6 tonnes (15-25 tons)	31	Small
	76 cubic metres (100 cubic yards)	76	Large - 76 m <sup>3</sup> capacity
Collection Trucks	5-7 tonnes (6-7.5 tons)	11	
	10 -31 cubic metres (14-40 cubic yards)	31	Small - 31 m <sup>3</sup> capacity
Walking Floor Trailers	25 tonnes	38	Large
	5000 litres (1,320 gallons)	5	Small - 5000 L capacity
Tanker Trucks (ICI Liquid)	20000 litres	20	Medium - 20000 L capacity
	1500-40,000 litres	40	capacity
Roll-Off Trucks	2-7 tonnes (2-8 tons)	9	Small
	15 - 31 cubic metres (20-40 cubic yard)	31	Large - 31 m <sup>3</sup> capacity
Compressed Gas Tube Trailers	5,000 m <sup>3</sup> in 20 ft trailer	5000	
	12,000 m <sup>3</sup> in 40 ft trailer	12000	
<b>Waste Density</b>			
Organic Waste (t/m <sup>3</sup> )	0.65		
ICI Liquid (t/m <sup>3</sup> )	1		
Residual Waste (t/m <sup>3</sup> )	0.8		
Digestate	1		

**Waste Storage Calculations**  
**Design and Operations Report**  
**Escarpment Renewables, Grimsby Anaerobic Digestion Facility**

<b>Storage Area</b>	<b>Quantity (m<sup>3</sup>)</b>	<b>Quantity (Tonnes)</b>
Tip Floor	1,271	1,080
Existing Receiving Tank 1	493	493
Existing Receiving Tank 2	493	493
Existing Receiving Tank 3	493	493
Existing Digester 1	2,166	2,166
Existing Digester 2	2,166	2,166
New Digester 1	3,435	3,435
New Digester 2	3,435	3,435
New Digester 3	3,435	3,435
New Digester 4	3,435	3,435
Existing Digestate Storage Tank 1	4,029	4,029
Existing Digestate Storage Tank 2	4,029	4,029
New Digestate Storage Tank 3	8,000	8,000
New Digestate Storage Tank 4	8,000	8,000
Residual Waste Trailers	95	76
Existing Grit/Skimmings 1	5	4
Grit/Skimmings 2	9	7
Grit/Skimmings 3	9	7




Table 11


**Secondary Containment Calculations  
Design and Operations Report  
Escarpment Renewables, Grimsby Anaerobic Digestion Facility**

<b>Parameter</b>	<b>Amount</b>	<b>Units</b>
<b>Digesters</b>		
Diameter	18	m
Height	13.5	m
Embedded depth	1.8	m
Area <i>[example - <math>\pi * R(18/2)^2</math>]</i>	254	m <sup>2</sup>
Volume <i>[example - Area (254)*Height (13.5-1.8)]</i>	2972	m <sup>3</sup>
Number of units	4	
Total Volume <i>[example - Volume(3,435)*No.(4)]</i>	11,887	m <sup>3</sup>
<b>Digestate Storage</b>		
Diameter	32	m
Height	10	m
Embedded depth	1.8	m
Area	804	m <sup>2</sup>
Volume	6,593	m <sup>3</sup>
Number of units	2	
Total Volume	13,186	m <sup>3</sup>
<b>Containment Volume Required</b>		
<i>[example - Digestate Storage volume + 10%*(Digestate Storage volume+total digester volume)</i>	8441	m <sup>3</sup>
Containment Height	2.5	m
Net Containment Area Required	3376	m <sup>2</sup>
Area Provided (secondary containment+100-year storm)	4288	m <sup>2</sup>
<b>Containment Volume Provided</b>	10,720	m <sup>3</sup>

# Figures



- Legend**
- Arterial Street
  - Waterbody
  - Watercourse
  - Wetland
  - Elevation (masl)
  - Building Footprint
  - Wooded Area




**ESCARPMENT RENEWABLES**  
442 SOBYE ROAD, TOWN OF GRIMSBY,  
ONTARIO

Project No. 11226032  
Date Jun 9, 2021

**SITE LOCATION MAP**


**FIGURE 1**





**PRELIMINARY**

No.	Issue	Checked	Approved	Date	
				2022-01-17	
Author	SPENCER H	Drafting Check	KALINDER D	Project Manager	JASON W
Designer	JASON W	Design Check	RYAN L	Project Director	VICTORIA S



Bar is 25mm on original size sheet  
0 5 10 15 25mm



Conditions of Use  
This document and the ideas and designs incorporated herein, as an instrument of professional service, is the property of GHD. This document may only be used by GHD's client (and any other person who GHD has agreed can use the document) for the purpose for which it was prepared and must not be used by any other person or for any other purpose.



Client	ESCARPMENT RENEWABLES
Project	ESCARPMENT RENEWABLE ENERGY APPROVAL AMENDMENT
Project No.	11226032
Date	2022-01-17
Scale	1:500

Title	EXISTING CONDITIONS
Sheet No.	FIGURE 2



**SITE LEGEND**

- PARKING SPACE TAGS
- BARRIER FREE PARKING SPACE
- TREE / PLANTING
- PROPERTY LINE
- ZONING SETBACKS
- GRAVEL
- EXISTING BUILDING
- PROPOSED BUILDING
- RIP-RAP
- SWM POND
- EXTERIOR DOOR / B.F. ENTRANCE
- UNOBSTRUCTED FIRE FIGHTER ACCESS DOOR/WINDOW/PANEL
- OVERHEAD DOOR
- TRUCK ROUTE
- FENCE LINE
- SOD / GRASS
- CONCRETE
- ASPHALT
- RECLAIMED ASPHALT
- FARM FIELD

**ZONING:**  
 A - AGRICULTURAL ZONE (REFER TO ZONING INFO TABLE FOR DETAILS)

**OFF-STREET PARKING: (AS PER ZBL SECTION 5.1)**

**EXISTING:**  
 PUMP AND PAST. BUILDING = 532m<sup>2</sup> x 1 SPACE / 90m<sup>2</sup> = 6 SPACES  
 SEPARATION BUILDING = 60m<sup>2</sup> x 1 SPACE / 90m<sup>2</sup> = 1 SPACES  
 EXISTING BUILDINGS = 101m<sup>2</sup> x 1 SPACE / 28m<sup>2</sup> = 4 SPACES  
 TOTAL FOR EXISTING = 11 SPACES

**PROPOSED:**  
 OFFICE = 74m<sup>2</sup> x 1 SPACE / 28m<sup>2</sup> = 3 SPACES  
 PRE-PROCESS BUILDING = 2 230m<sup>2</sup> x 1 SPACE / 90m<sup>2</sup> = 25 SPACES  
 BOILER & HEAT BUILDING = 300m<sup>2</sup> x 1 SPACE / 90m<sup>2</sup> = 4 SPACES  
 PUMP BUILDING #2 = 250m<sup>2</sup> x 1 SPACE / 90m<sup>2</sup> = 3 SPACES  
 TOTAL PROPOSED REQUIRED = 35 SPACES  
 TOTAL PROPOSED PROVIDED = 48 SPACES

**BARRIER FREE (AS PER ZBL SECTION 5.13):**  
 TOTAL REQUIRED PARKING SPACES (1 PER 20 SPACES)  
 (11 EXISTING + 38 PROPOSED) x 1 SPACE / 20 SPACES = 3 SPACES  
 THEREFORE, REQ'D NO. OF BARRIER FREE SPACES = 3 SPACES




OVERALL TOTAL PROVIDED ON SITE = 46 SPACES  
 - INCLUDING BARRIER FREE

**OFF-STREET LOADING SPACES: (AS PER ZBL SECTION 5.15)**  
 REQUIRED LOADING SPACES (AS PER ZBL SECTION 5.15)  
 GROSS FLOOR AREA (2.351 to 7.900m<sup>2</sup>) = 2 SPACE  
 TOTAL REQUIRED = 2 SPACE  
 TOTAL PROPOSED = 2 SPACE


**SITE PLAN NOTES:**

- FIRE ROUTE ACCESS REQUIRES FIRE PERSONNEL ACCESS AS REQUIRED BY OBC.
- FIRE ROUTE TO BE POSTED AND DESIGNATED UNDER MUNICIPAL BY-LAW DESIGN REQUIREMENTS AS FOLLOWS:
  - MIN. 6m WIDE
  - 12m CENTRE LINE TURNING RADIUS
  - MAX. 8% SLOPE
- FIRE ROUTE SIGNS MUST BE STANDARD OF APPLICABLE MUNICIPALITY AND ARE TO BE PLACED AS FOLLOWS:
  - INTERVALS OF NOT LESS THAN 15.2m (50')
  - NOT MORE THAN 45.7m (150') ALONG THE DESIGNATED FIRE ROUTE
  - AT A HEIGHT OF NOT LESS THAN 1.8m (6')
- ANY SITE FENCING TO BE CONFIRMED WITH OWNER PRIOR TO CONSTRUCTION
- STANDARD BUMP BLOCKS TO BE INSTALLED FOR PARKING SPOTS ON GRAVEL SURFACES. PAINTED LINES TO BE INSTALLED FOR PARKING SPOTS ON PAVED SURFACES
- YARD LIGHTING LOCATION AND ORIENTATION TO BE INSTALLED TO NOT INTERFERE WITH TRAFFIC ON COUNTY ROADS PLUS MINIMIZE INTERFERENCE ON NEIGHBORING PROPERTIES.
- PROPERTY LINES ARE APPROXIMATE AND MAY NEED TO BE CONFIRMED BY AN OLS.

ZONING BY-LAW INFORMATION TABLE			
	ZONING BY-LAW	EXISTING	PROPOSED
LOT AREA (MIN.)	400 000 m <sup>2</sup>	105 026 m <sup>2</sup>	105 026 m <sup>2</sup>
LOT FRONTAGE (MIN.)	183 m	380 m	380 m
FRONT YARD SETBACK	15 m	30 m	22.3 m
EAST SIDE YARD SETBACK	15 m	175.4 m	106.2 m
WEST SIDE YARD SETBACK	15 m	97.7 m	37.1 m
REAR YARD SETBACK	15 m	102 m	77.3 m
LOT DEPTH (MIN.)	NO PROVISIONS	226.3 m	226.3 m
BUILDING FLOOR AREA	NO PROVISIONS	N/A	3 546 m <sup>2</sup>
GROSS FLOOR AREA	NO PROVISIONS	N/A	3 546 m <sup>2</sup>
LOT COVERAGE (ALL BLDGS)	20% (MAX.)	N/A	3.4%
LOT COVERAGE (ACCESSORY)	NO PROVISIONS	0%	7.1%
BUILDING HEIGHT (MAX.)	NO PROVISIONS	N/A	14 m
NUMBER OF PARKING SPACES	44	8	47
BARRIER FREE SPACES	3	0	3
NUMBER OF LOADING SPACES	1	3	4
LANDSCAPED AREA	NO PROVISIONS	N/A	74 396 m <sup>2</sup>
GRANULAR AREA	NO PROVISIONS	N/A	8 336 m <sup>2</sup>
PAVED AREA	NO PROVISIONS	N/A	11 271 m <sup>2</sup>




**NOTES:**  
 1. ALL DIMENSIONS ARE IN MILLIMETERS.  
 2. SIGN TO CONFORM TO ALL APPLICABLE BY-LAWS AND GAATES ILLUSTRATED TECHNICAL GUIDE TO THE ACCESSIBILITY STANDARD FOR DESIGN OF PUBLIC SPACES. EXACT SIZE TO BE CONFIRMED BY GC / SUPPLIER.  
 3. OPTIONAL MOUNTING ON BUILDING OR POLE.



**NOTES:**  
 PLEASE READ NOTE PAGE AT BEGINNING OF DRAWING SET FOR ALL NOTES REGARDING THIS PROJECT

NO.	DATE	DESCRIPTION

**NOTES:**  
 1. OWNER: ESCARPMENT RENEWABLES  
 2. LEGAL DESCRIPTION: PART OF LOT 1 CONCESSION 6 GEOGRAPHIC TOWNSHIP OF GRIMSBY TOWN OF GRIMSBY COUNTY OF LINCOLN  
 3. SITE GRADING, SERVING AND EROSION & SEDIMENT CONTROL PLAN PROVIDED BY GRIT ENGINEERING INC. REFER TO PROJECT No. GE22-0178-1 DRAWING No. C300 & C500




PROFESSIONAL ENGINEER'S SEAL  
**STONECREST ENGINEERING INC.**  
 EST. 1995  
 440 Wright Blvd Unit #2, Stratford, ON, N4Z 1H3  
 519-625-8025 - info@stonecrestengineering.com

CONTRACTOR TO CHECK ALL DIMENSIONS AND ELEVATIONS AND REPORT ANY DISCREPANCIES TO THE ENGINEER BEFORE PROCEEDING WITH THE WORK  
 DO NOT SCALE THE DRAWINGS

**CLIENT:** ESCARPMENT RENEWABLES  
**LOCATION:** 424 SOBYE ROAD, BEAMSVILLE, ON  
**PROJECT NAME:** PRE-PROCESS BUILDING  
**PROJECT STATUS AND VERSION:** CONCEPT DRAWINGS

**DESIGNED BY:** T.L./M.W. **PRINT DATE:** 2024.02.01  
**PAGE DESCRIPTION:** SITE LAYOUT  
**SCALE:** AS NOTED  
**FILE:** 8016-1  
**PAGE NUMBER:**

BRANDON WARTMAN, TOWN OF GRIMSBY




MIN. COORDINATE  
SCALE 1/8"=1'-0"

**NOTES:**  
PLEASE READ NOTE PAGE AT  
BEGINNING OF DRAWING SET FOR ALL  
NOTES REGARDING THIS PROJECT

NO.	REVISIONS	DESCRIPTION

- LEGEND**
- SPOT ELEVATION
  - ⊕ DOOR IDENTIFICATION TAG
  - ⊕ WALL IDENTIFICATION TAG
  - ⊕ WINDOW IDENTIFICATION TAG
  - ⊕ PERI COLUMN IDENTIFICATION TAG
  - ⊕ FOOTING IDENTIFICATION TAG
  - ▭ FIBRE SEPARATION SATED WALL (FIB)
  - ▭ FIB REFERENCE SATED WALL (FIBR)



**DRAFT - NOT FOR CONSTRUCTION**


PROFESSIONAL ENGINEER'S SEAL

**Stonecrest**  
ENGINEERING  
SHAKESPEARE, ONTARIO, CANADA  
PH: (519) 825-8025  
FX: (519) 825-8998

CONTRACTOR TO CHECK ALL DIMENSIONS AND ELEVATIONS AND REPORT ANY DISCREPANCIES TO THE ENGINEER BEFORE PROCEEDING WITH THE WORK.  
DO NOT SCALE THE DRAWINGS

CLIENT	MILAR WASTE SYSTEMS
LOCATION	421 SCORIE ROAD, BEAVERVILLE, ON
PROJECT TYPE	PRE-PROCESSING BUILDING
PROJECT STATUS AND VERSION	PRELIMINARY DRAWINGS

DRAWN BY	TRAVEL	PRINT DATE	2024
PAGE DESCRIPTION	FLOOR PLAN		
SCALE	AS NOTED		
FILE	8118 - PRE-PROCESS - 1		
PAGE NUMBER	1		



PRELIMINARY


No.	Issue	Checked	Approved	Date
				2023-12-04
Author	SPENCER H	Drafting Check	KALINDER D	Project Manager
Designer	JASON W	Design Check	RYAN L	Project Director
			VICTOR B S	

Bar is 25mm on original size sheet  
 25mm

Conditions of Use  
 This document and the ideas and designs incorporated herein, are the property of GHD. This document may only be used by GHD's client (and any other person who GHD has agreed can use this document) for the purpose for which it was prepared and must not be used by any other person or for any other purpose.

Client	ESCARPMENT RENEWABLES
Project	ESCARPMENT RENEWABLE ENERGY APPROVAL AMENDMENT
Project No.	11226032
Date	2023-12-04
Scale	N.T.S.

140  
 PROCESS FLOW DIAGRAM WASTE RECEIVING AND PROCESSING ESCARPMENT RENEWABLES  
 FIGURE 5



PRELIMINARY

No.	Issue	Checked	Approved	Date
				2023-12-04
Author	SPENCER H	Drafting Check	KALINDER D	Project Manager
Designer	JASON W	Design Check	RYAN L	Project Director
			VICTOR B S	

Bar is 25mm on original size sheet  
 25mm


Conditions of Use  
 This document and the ideas and designs incorporated herein, as an instrument of professional service, is the property of GHD. This document may only be used by GHD's client (and any other person who GHD has agreed can use this document) for the purpose for which it was prepared and must not be used by any other person or for any other purpose.

client ESCARPMENT RENEWABLES  
 Project ESCARPMENT RENEWABLE ENERGY APPROVAL AMENDMENT

140 PROCESS FLOW DIAGRAM DIGESTION ESCARPMENT RENEWABLES

Project No. 11226032 Date 2023-12-04 Scale N.T.S.

Sheet No. FIGURE 6



**PRELIMINARY**

No.	Issue	Checked	Approved	Date	
				2023-12-04	
Author	SPENCER H	Drafting Check	KALJINDER D	Project Manager	JASON W
Designer	JASON W	Design Check	RYAN L	Project Director	VICTOR B S

Bar is 25mm on original size sheet  
 25mm



Conditions of Use  
 This document and the ideas and designs incorporated herein, are the property of GHD. This document may only be used by GHD's client (and any other person who GHD has agreed can use this document) for the purpose for which it was prepared and must not be used by any other person or for any other purpose.

Client	ESCARPMENT RENEWABLES
Project	ESCARPMENT RENEWABLE ENERGY APPROVAL AMENDMENT
Project No.	11226032
Date	2023-12-04
Scale	N.T.S.

Title	PROCESS FLOW DIAGRAM DIGESTATE AND BIOGAS MANAGEMENT ESCARPMENT RENEWABLES
Sheet No.	FIGURE 7
Std	ANSI D

# Appendices

# **Appendix A**

**Emissions Summary and Dispersion  
Modelling Report**





# **Emission Summary and Dispersion Modelling Report**

**424 Soby Road, Grimsby, Ontario**

Escarpment Renewables

July 29, 2024

**GHD**



455 Phillip Street, Unit 100A

Waterloo, Ontario N2L 3X2, Canada

T +1 519 884 0510 | F +1 519 884 0525 | E info-northamerica@ghd.com | **ghd.com**

<b>Printed date</b>	2024-06-26 5:00:00 PM
<b>Last saved date</b>	July 26, 2024
<b>File name</b>	https://projects-northamerica.ghd.com/sites/na06_02/triplemanbrampton471/ProjectDocs/11208632-RPT-2-Emission Summary and Dispersion Modelling Report.docx
<b>Author</b>	Punith Nallathamby
<b>Project manager</b>	Jason Wilson
<b>Client name</b>	Escarpment Renewables
<b>Project name</b>	Escarpment Renewables
<b>Document title</b>	Emission Summary and Dispersion Modelling Report   424 Soby Road, Grimsby, Ontario
<b>Revision version</b>	Rev 02
<b>Project number</b>	11226032-RPT-4-Rev1

**Document status**

Status Code	Revision	Author	Reviewer		Approved for issue		
			Name	Signature	Name	Signature	Date
S3	00	Punith Nallathamby	Matthew Griffin		Victoria Shortreed		Jan.26/22
S4	01	Punith Nallathamby	Matthew Griffin		Victoria Shortreed		July29, 2024

© GHD 2022

This document is and shall remain the property of GHD. The document may only be used for the purpose for which it was commissioned and in accordance with the Terms of Engagement for the commission. Unauthorised use of this document in any form whatsoever is prohibited.

# Version Control

Revision	Date	Revised Description	Reviewer Initials
	October 1, 2014	Original Renewable Energy Approval (REA) Application – REA No. 8541-9HSGG3	
	October 31, 2018	Amendment to REA No. 8541-9HSGG3	
	July 26, 2019	Amendment to REA No. 8541-9HSGG3	
1.0	November 2021	ESDM update for REA Application for Facility updates	MG

# Executive summary

This Emission Summary and Dispersion Modelling (ESDM) Report was prepared to support an application for an Amendment for Renewable Energy Approval (REA) (Air & Noise) No. 8541-9HSGG3. The ESDM Report was prepared in accordance with s.26 of Ontario Regulation (O. Reg.) 419/05 to support the REA amendment application. In addition, guidance in the ministry publication "Procedure for Preparing an Emission Summary and Dispersion Modelling Report" dated March 2018 (ESDM Procedure Document) was followed, as appropriate.

Escarpment Renewables operates an anaerobic digester to produce renewable energy from digester biogas on their property, located at 424 Soby Road in Grimsby, Ontario (Facility). The Facility is in an area zoned 'Agricultural'.

This application and supporting documentation were prepared in accordance with all applicable regulatory and Ministry requirements that were in effect at the time of application.

The primary North American Industrial Classification System (NAICS) Code that applies to the Facility is 562210 – "Waste Treatment and Disposal". Compliance has been assessed using the AERMOD dispersion model and the standards listed in Schedule 3 of O. Reg. 419/05, in the document entitled "Air Contaminants Benchmarks (ACB) List: Standards, guidelines and screening levels for assessing point of impingement concentrations of air contaminants", version 2.0, dated April 2018 (ACB List).

The Facility is expected to emit odour, volatile organic compounds (VOCs) and products of combustion. Some of the sources and contaminants were considered negligible in accordance with s.8 of O. Reg. 419/05.

The maximum point of impingement (POI) concentrations were calculated based on the operating conditions where all significant sources are operating simultaneously at their individual maximum rates of production. The maximum emission rates for each significant contaminant emitted from the significant sources were calculated in accordance with s. 11 of O. Reg. 419/05 and the data quality assessment follows the process outlined in the requirements of the ESDM Procedure Document.

A POI concentration for each significant contaminant emitted from the Facility was calculated based on the calculated emission rates and the output from the approved dispersion model; the results are present in the following Emission Summary Table in accordance with s.26 of O. Reg. 419/05.

The POI concentrations listed in the Emission Summary Tables were compared against criteria in the ACB List. All of the predicted POI concentrations for contaminants listed in the Emission Summary Table that are included in the ACB List, are below the corresponding limits.

# Contents

<b>1.</b>	<b>Introduction and Facility Description</b>	<b>1</b>
1.1	Purpose and Scope of ESDM Report	1
1.2	Description of Processes and NAICS Codes	1
1.3	Description of Products and Raw Materials	1
1.4	Process Flow Diagram	2
1.5	Operating Schedule	2
1.6	Feedstock and Site Changes	2
<b>2.</b>	<b>Initial Identification of Sources and Contaminants</b>	<b>2</b>
2.1	Sources and Contaminants Identification Table	3
<b>3.</b>	<b>Assessment of Significance of Sources and Contaminants</b>	<b>3</b>
3.1	Identification of Negligible Contaminants and Sources	3
3.2	Rationale for Assessment	3
<b>4.</b>	<b>Operating Conditions, Emissions Estimating and Data Quality</b>	<b>3</b>
4.1	Description of Operating Conditions	4
4.2	Explanation of the Methods Used to Calculate Emission Rates	4
4.3	Sample Calculations	4
4.4	Assessment of Data Quality	4
<b>5.</b>	<b>Source Summary Table and Site Plan</b>	<b>4</b>
5.1	Source Summary Table	5
5.2	Site Plan	5
<b>6.</b>	<b>Dispersion Modelling</b>	<b>5</b>
6.1	Co-ordinate System	6
6.2	Meteorology and Land Use Zoning Plan	6
6.3	Terrain	6
6.4	Receptors	6
6.5	Building Downwash	7
6.6	Deposition	7
6.7	Averaging Time and Conversions	7
6.8	Dispersion Modelling Options	7
6.9	Dispersion Modelling Input and Output Files	8
<b>7.</b>	<b>Emission Summary Table and Conclusions</b>	<b>8</b>
7.1	Emission Summary Table	8
7.2	Conclusions	8

## Figure index

Figure 1	Site Location Plan
Figure 2	Land Use Zoning Designation Plan
Figure 3	Site Layout Plan
Figure 4A	Process Flow Diagram – Waste Receiving and Processing
Figure 4B	Process Flow Diagram – Digestion
Figure 4C	Process Flow Diagram – Digestate and Biogas Management

## Table index

Table 1	Source and Contaminant Identification Table
Table 2A	Source Summary Table – Sorted by Source
Table 2B	Source Summary Table – Sorted by Contaminant
Table 3	Dispersion Modelling Input Summary Table
Table 4	Emission Summary Table

## Appendices

Appendix A	Existing Renewable Energy Approval
Appendix B	Supporting Calculations
Appendix C	Supporting Information for Assessment of Negligibility
Appendix D	Dispersion Modelling Input

# 1. Introduction and Facility Description

This section provides a description of the facility as required by sub paragraph 1 of s.26 (1) of Ontario Regulation 419/05 (O. Reg. 419/05). Escarpment Renewables operates an anaerobic digester (AD) facility at 424 Soby Road in Grimsby, Ontario (Facility). The location of the Facility is presented on Figure 1 and the land use designation of the site and surrounding area is presented on Figure 2. The property line along with the location of the discharges from each of the sources is presented on Figure 3. The location of each of the sources is specified with the source reference number.

The primary North American Industrial Classification System (NAICS) that applies to the Facility is 562210 – "Waste Treatment and Disposal". This NAICS Code is listed in Schedule 5 of O. Reg. 419/05. The assessment of compliance was performed using the AERMOD dispersion model and the standards listed in Schedule 3 of O. Reg. 419/05, in the document entitled "Air Contaminants Benchmarks (ACB) List: Standards, guidelines and screening levels for assessing point of impingement concentrations of air contaminants", version 2.0, dated April 2018 (ACB List).

## 1.1 Purpose and Scope of ESDM Report

The ESDM report was prepared in accordance with s.26 of O. Reg. 419/05 and guidance in the Ontario Ministry of the Environment, Conservation and Parks (MECP) publication "Procedure for Preparing an Emission Summary and Dispersion Modelling Report" dated March 2018 (ESDM Procedure Document) PIBS 3614e04.1.

This ESDM Report has been prepared as part of an Amendment Application for a Renewable Energy Approval (REA) (Air & Noise). The Facility currently operates under REA (Air & Noise) No. 8541-9HSGG3 that was originally dated February 16, 2012 and was most recently amended April 22, 2020. The current REA is provided in Appendix A. The Facility is planning an expansion and has prepared an up-to-date ESDM, incorporating all proposed modifications to be made to the Facility.

For ease of review and to promote clarity, this ESDM Report is structured to correspond to each of the items listed in the Ministry publication "Emission Summary and Dispersion Modelling Check-List", March 2017, PIBS 5357E.

## 1.2 Description of Processes and NAICS Codes

Escarpment Renewables operates a renewable energy generation facility with an anaerobic biodigester. The raw materials include solid and liquid wastes that are brought to the facility for the anaerobic digesting process. The digestates are then shipped off site for beneficial use while the biogas is used to generate electricity, renewable natural gas (RNG) or combusted.

The NAICS Code that applies to this Facility is 562210 – "Waste Treatment and Disposal".

## 1.3 Description of Products and Raw Materials

The processes at the Facility include material receiving, heating, digesting, electricity and RNG generation and waste disposal.

Product usages and process information are provided in greater detail in Appendix B – Supporting Calculations. Refer to Table 1 - Sources and Contaminants Identification Table, which tabulates the individual sources of emissions at the Facility.

## 1.4 Process Flow Diagram

Refer to Figure 4A, Figure 4B, and Figure 4C – Process Flow Diagram for a graphical representation of the manufacturing processes at the Facility.

## 1.5 Operating Schedule

The Facility can operate up to 24 hours per day, 365 days per year.

## 1.6 Feedstock and Site Changes

A summary of the changes to:

- Feedstock waste types and quantities can be found in Section 2.2 of the Design & Operation (D&O) Report. In summary Escarpment Renewables is currently approved to process a maximum of 23,000 tonnes of biomass per year which will be increased to 159,000 tonnes per year and include the following waste types and maximum tonnages:
  - Agricultural waste (up to 7,000 tonnes per year)
  - Source-Separated Organics (SSO) (up to 120,000 tonnes per year)
  - Industrial, Commercial, and Institutional (ICI) packaged waste (up to 100,000 tonnes per year)
  - ICI Liquid waste (up to 100,000 tonnes per year)
  - Combined maximum 159,000 tonnes per year

The annual composition of waste received may consist of any combination of the above waste types up to the maximum tonnes indicated and not exceeding a combined maximum of 159,000 tonnes per year.

- Changes to the Site (equipment, process and layout) can be found in Section 2 of the D&O Report. In summary these will include:
  - Increased digester capacity
  - Expanded Site footprint
  - Operating Hours
  - Waste Storage Improvements
  - New organics pre-processing building
  - New air treatment
  - New digestate/biogas storage tanks
  - New RNG Upgrading System
  - New Flare

## 2. Initial Identification of Sources and Contaminants

This section provides an initial identification of all of the sources and contaminants emitted at the Facility, as required by subparagraphs 2 to 4 of s.26 (1) of O. Reg. 419/05.

There may be general ventilation from the Facility that only discharges uncontaminated air from the workspaces or air from the workspace that may include contaminants that come from commercial office supplies, building maintenance



products or supplies and activities; these types of ventilation sources are considered to be negligible and were not identified as sources at the Facility.

General ventilation located in the process area that does not vent process emissions is also considered negligible.

## **2.1 Sources and Contaminants Identification Table**

Table 1 – Sources and Contaminants Identification Table tabulates all the emission sources at the Facility. Table 1 provides the information required for sub paragraphs 2 to 4 of s.26 (1) of O. Reg. 419/05.

The expected contaminants emitted from each source are also identified in Table 1. Each of the identified sources has been assigned a source reference number.

The site plan, including the property line is presented along with the location of the discharges from each of the sources is presented on Figure 3. The location of each of the sources is specified with the source reference number.

# **3. Assessment of Significance of Sources and Contaminants**

This section provides an explanation for each source and contaminant identified as negligible in Table 1, as required by subparagraph 5 of s.26(1) of O. Reg. 419/05.

In Accordance with s.8 of O. Reg. 419/05, emission rate calculations and dispersion modelling does not have to be performed for emissions from negligible sources or for the emission of negligible contaminants from significant sources.

## **3.1 Identification of Negligible Contaminants and Sources**

Each negligible source is identified in Table 1 – Sources and Contaminants Identification Table. The remaining sources are significant. These sources will be included in the dispersion modelling for the Facility.

## **3.2 Rationale for Assessment**

For each source in Table 1 that has been identified as being negligible there is an accompanying documented rationale. The technical information required to substantiate the argument that each of the identified sources is negligible is presented in Appendix C – Supporting Information for Assessment of Negligibility.

# **4. Operating Conditions, Emissions Estimating and Data Quality**

This section provides a description of the operating conditions used in the calculation of the emission estimates and an assessment of the data quality of the emission estimates for each significant contaminant from the facility as required by sub paragraphs 6 and 7 of s.26 (1) of O. Reg. 419/05. In accordance with s.8 of O. Reg. 419/05, emission rate calculations and dispersion modelling does not have to be performed for emissions from negligible sources or for the emission of negligible contaminants from significant sources.

## **4.1 Description of Operating Conditions**

Section 10 of O. Reg. 419/05 states that an acceptable operating condition is a scenario that assumes operating conditions for the Facility that would result, for the relevant contaminant, in the highest concentration of the contaminant at POI that the Facility is capable of, the operating condition described in this ESDM Report meets this requirement.

The operating conditions that would result in the highest concentration of the contaminants were used for this assessment. The individual maximum rates of production for each significant source of emissions are explicitly described in Appendix B.

## **4.2 Explanation of the Methods Used to Calculate Emission Rates**

The maximum emission rates for each significant contaminant emitted from the significant sources were calculated in accordance with requirements of the ESDM Procedure Document.

The emission rate for each significant contaminant emitted from a significant source was estimated and the methodology for the calculation is documented in Table 2A and Table 2B.

## **4.3 Sample Calculations**

The technical rationale, including sample calculations, required to substantiate the emission rates presented in Table 2A and Table 2B is documented in Appendix B.

## **4.4 Assessment of Data Quality**

This section provides a description of the assessment of the data quality of the emission estimates for each significant contaminant from the facility.

The assessment of the data quality of the emission rate estimates for each significant contaminant emitted from the significant sources was performed in accordance with the requirements of subparagraph 7iii of s.26 (1) of O. Reg. 419/05.

For each contaminant, the emission rate was estimated and the data quality of the estimate is documented in Table 2A and Table 2B. The assessment of data quality for each source listed in Table 2A and Table 2B is documented in Appendix B.

All the emission rates listed in Table 2A and Table 2B correspond to the operating scenario where all significant sources are operating simultaneously at their individual maximum rates of production. Therefore, emission rate estimates listed in Table 2A and Table 2B are not likely to be an underestimate of the actual emission rates and use of these emission rates will result in a calculated concentration at POI greater than the actual concentrations.

## **5. Source Summary Table and Site Plan**

This section provides the table required by subparagraph 8 and the site plan required by subparagraph 9 of s.26 (1) of O. Reg. 419/05.

## 5.1 Source Summary Table

For each source of significant contaminants, the following parameters are referenced:

- Contaminant
- Chemical Abstract Society (CAS) reference number
- Source reference number
- Source description
- Stack parameters (flow rate, exhaust temperature, diameter, height above grade, height above roof)
- Location referenced to a Universal Transverse Mercator (UTM) coordinate system presented in Figure 3A
- Maximum emission rate
- Averaging period
- Emission estimating technique
- Estimation data quality
- Percentage of overall emission

## 5.2 Site Plan

The locations of the emission sources listed in Table 2A and Table 2B are presented on Figure 3; the location of each of the sources is specified with the source reference number. The location of the property-line is indicated on Figure 3, with the end points of each section of the property-line clearly referenced in a Cartesian coordinate system. The location of each source is referenced to this coordinate system under a column in Table 2A and Table 2B.

The heights of the structures that are part of the Facility are labeled on Figure 3.

# 6. Dispersion Modelling

This section provides a description of how the dispersion modelling was conducted at the Facility to calculate the maximum concentration at a POI.

The dispersion modelling was conducted in accordance with the ministry publication "Air Dispersion Modelling Guideline for Ontario" PIBS 5165e03 (ADMGO). A general description of the input data used in the dispersion model is provided below and summarized in Table 3.

The Schedule 3 standards have been applied to Escarpment Renewables in this ESDM for the February 1, 2020 implementation date.

The emission rates used in the dispersion model meet the requirements of Section 11(1) 1 of O. Reg. 419/05, which requires that the emission rate used in the dispersion model is at least as high as the maximum emission rate that the source of contaminant is reasonably capable of for the relevant contaminant. These emission rates are further described in Appendix B.

The AERMOD modelling system has been identified by the MECP as one of the approved dispersion models under O. Reg. 419/05, and currently includes the Plume Rise Model Enhancements (PRIME) algorithms for assessing the effects of buildings on air dispersion.

The AERMOD modelling system is made up of the AERMOD dispersion model, the AERMET meteorological pre-processor and the AERMAP terrain pre-processor. The following approved dispersion model and pre-processors were used in the assessment:

- AERMOD dispersion model (v. 19191)

- AERMAP surface pre-processor (v. 18081)
- BPIP building downwash pre-processor (v. 04274)

A summary of the AERMOD source input parameters is provided in Appendix D.

AERMET was not used in this assessment, as a pre-processed MECP meteorological dataset was used.

The emission rates used in the dispersion model meet the requirements of Section 11(1) 1 of O. Reg. 419/05, which requires that the emission rate used in the dispersion model is at least as high as the maximum emission rate that the source of contaminant is reasonably capable of for the relevant contaminant. These emission rates are further described in Appendix B.

There is no childcare facility, health care facility, senior's residence, long-term care facility, or an education facility located at the Facility. Furthermore, the nearest POI is located greater than 5 metres (m) from the building on which the point of emissions are located. As such, same structure contamination was not considered.

## 6.1 Co-ordinate System

The UTM coordinate system, as per Section 5.2.2 of the ADMGO, was used to specify model object sources, buildings and receptors. All coordinates were defined in the North American Datum of 1983 (NAD83).

All sources, building, and the property line coordinates are provided on Figure 3.

## 6.2 Meteorology and Land Use Zoning Plan

Subparagraph 10 of s.26 (1) of O. Reg. 419/05 requires a description of the local land use conditions if meteorological data described in paragraph 2 of s.13 (1) of O. Reg. 419/05 was used. Site specific meteorological data was obtained from the MECP.

A land use zoning plan is provided on Figure 2. Figure 2 also illustrates the extents of the Facility property boundary and provides the zoning of adjacent land uses. The Facility is located in an area zoned 'Agricultural'. The land use surrounding the Facility is zoned 'Agricultural' as well.

## 6.3 Terrain

AERMOD captures the essential physics of dispersion in complex terrain though the use of a separate height scale factor for each receptor (United States Environmental Protection Agency [USEPA], 1998 – AERMAP UG). The highest scale factor represents the terrain that would dominate flow in the vicinity of the receptor.

The height scale factor that is used by AERMOD is generated by the AERMAP terrain pre-processor. AERMAP utilizes terrain data, or Digital Elevation Model (DEM) data in conjunction with a layout of receptors and sources to height scale factors that can be directly used in AERMOD. Terrain data used in this assessment was obtained from MECP (7.5-minute format).

## 6.4 Receptors

Receptors were chosen based on recommendations provided in Section 7.1 of the ADMGO, which is in accordance with s.14 of O. Reg. 419/05. A tiered receptor grid was defined starting with a rectangular boundary that encloses all the modelled sources (bounding box). A tiered grid was then defined starting from the edge of the bounding box with a fine resolution, to coarser resolutions further away. All tiered distances were defined relative to the bounding box. The receptor grid used is described as follows:

- 20-m spacing within 200 m of the edge of the bounding box
- 50-m spacing from 200 to 500 m
- 100-m spacing from 500 to 1,000 m

- 200-m spacing from 1,000 to 2,000 m
- 500-m spacing from 2,000 to 5,000 m

A property line ground level receptor grid with 10-m spacing was used to evaluate the maximum property boundary concentration. No receptors were placed inside the Facility's property line.

## 6.5 Building Downwash

The Facility buildings were entered into the model using the USEPA Building Profile Input Program (BPIP-PRIME). The inputs into this pre-processor include the co-ordinates and heights of the buildings and stacks. The BPIP program was executed to evaluate any building cavity downwash effects. Cavity downwash can result in air contaminants being forced to ground level prematurely under certain meteorological conditions. The on-site buildings and structures were modelled with their respective average roof heights.

The PRIME plume rise algorithms include vertical wind shear calculations (important for buoyant releases from short stacks (i.e., stacks at release heights within the recirculation zones of the buildings). The PRIME algorithm also allows for the wind speed deficit factors to improve the accuracy of predicted concentrations within building wake zones that form in the lee of buildings. The BPIP input file is provided in Appendix D.

## 6.6 Deposition

AERMOD has the ability to account for wet and dry deposition of substances that would reduce ground level concentrations at POIs. However, the deposition algorithm has not been implemented in this assessment and therefore, the predicted POI concentrations are considered to be more conservative.

## 6.7 Averaging Time and Conversions

The shortest time scale that AERMOD predicts is a 1-hour average value. Schedule 3 standards were used to assess compliance at this Facility. Many of these standards are based on 1-hour and 24-hour averaging times, which are averaging times that are easily provided by AERMOD. In cases where a standard has an averaging period less than 1 hour (e.g., 10-minute), a conversion to the appropriate averaging period was completed using the MECF recommended conversion factors, as documented in the ADMGO.

## 6.8 Dispersion Modelling Options

The options used in the AERMOD dispersion model are summarized in the table below.

Modelling Parameter	Description	Used in the Assessment?
DFAULT	Specifies that regulatory default options will be used	Yes
ADJ_U*	Specifies that AERMET is pre-processed to adjust friction velocity for low wind speed conditions	Yes
CONC	Specifies that concentration values will be calculated	Yes
DDPLETE	Specifies that dry deposition will be calculated	No
WDPLETE	Specifies that wet deposition will be calculated	No
FLAT	Specifies that the non-default option of assuming flat terrain will be used	No, the model will use elevated terrain as detailed in the AERMAP output
NOSTD	Specifies that the non-default option of no stack-tip downwash will be used	No

Modelling Parameter	Description	Used in the Assessment?
AVERTIME	Time averaging periods calculated	1-hour, 24-hour, Annual
URBANOPT	Allows model to incorporate the effects of increased surface heating from an urban area on pollutant dispersion under stable atmospheric conditions	No
FLAGPOLE	Specifies that receptor heights above local ground level are allowed on the receptors	No

## 6.9 Dispersion Modelling Input and Output Files

The information input into the approved dispersion model is recorded in Appendix D. Appendix D also includes the input and output files from the AERMOD model in electronic form.

Table 3 provides a detailed description of the source input parameters.

# 7. Emission Summary Table and Conclusions

This section provides the table required by subparagraph 14 of s.26 (1) of O. Reg. 419/05 and provides an interpretation of the results as required by the ESDM Procedure Report.

## 7.1 Emission Summary Table

A POI concentration for each significant contaminant emitted from the Facility was calculated based on the emission rates listed in Table 2A and Table 2B and the output from the approved dispersion model presented in Appendix D. The results are presented in Table 4. This table follows the format provided in the ESDM Procedure Document. For each source of significant contaminants, the following parameters are referenced:

- Contaminant name
- CAS number
- Total facility emission rate
- Approved dispersion model used
- Maximum POI concentration
- Averaging period for the dispersion modelling
- MECP POI limit
- Indication of limiting effect
- Schedule in O. Reg. 419/05
- The percentage of standard

The POI concentrations listed in Table 4 were compared against Schedule 3 criteria in the ACB List.

## 7.2 Conclusions

This ESDM Report was prepared in accordance with s.26 of O. Reg. 419/05. In addition, guidance in the ESDM Procedure Document was followed as appropriate.

The emission rate estimates for each source of significant contaminants are documented in Table 2A and Table 2B. All the emission rates listed in Table 2A and Table 2B correspond to the operating scenario where all significant

sources are operating simultaneously at their individual maximum rates of production. Therefore, these emission rate estimates listed in Table 2A and Table 2B are not likely to be an underestimate of the actual emission rates.

A POI concentration for each significant contaminant emitted from the Facility was calculated based on the calculated emission rates and the output from the AERMOD dispersion model with the results presented in Table 4.



The POI concentrations listed in Table 4 were compared against criteria listed in the Ministry publication, "Air Contaminants Benchmarks (ACB) List: Standards, Guidelines, and Screening Levels for Assessing Point of Impingement Concentrations of Air Contaminants", version 2.0, dated April 2018.

All the contaminants that have limits in the ACB list are below their corresponding MECP POI Limit.


This ESDM Report demonstrates that the Facility can operate in compliance with O. Reg. 419/05 using the proposed operating scenarios.

# Figures





Map Projection: Transverse Mercator  
Horizontal Datum: North American 1983  
Grid: NAD 1983 UTM Zone 17N




**ESCARPMENT RENEWABLES**  
**424 SOBYE ROAD, GRIMSBY, ONTARIO**  
**EMISSION SUMMARY AND DISPERSION**  
**MODELLING REPORT**

Project No. 11226032  
Date Oct 26, 2021

**SITE LOCATION MAP**

**FIGURE 1**



**Legend**



- Site Boundary
- 1 KM Radius

**Town of Grimsby Zoning By-law (By-law 14-45)**

- Agricultural
- Specialty Crop

**Township of West Lincoln Zoning By-Law No. 2017-70**

- Agricultural
- Environmental Conservation
- Environmental Protection



Map Projection: Transverse Mercator  
 Horizontal Datum: North American 1983  
 Grid: NAD 1983 UTM Zone 17N

**ESCAPMENT RENEWABLES**  
**424 SOBYE ROAD, GRIMSBY, ONTARIO**  
**EMISSION SUMMARY AND DISPERSION**  
**MODELLING REPORT**

Project No. 11226032  
 Revision No. -  
 Date Oct 26, 2021

**LAND USE ZONING PLAN**

**FIGURE 2**

Q:\GIS\PROJECTS\11226032\Layouts\202110\_ESDMR\11226032\_202110\_ESDMR\_GIS002.mxd  
 Print date: 26 Oct 2021 - 11:54

Data source: Township of West Lincoln Zoning By-Law No. 2017-70, Town of Grimsby Zoning By-law (By-law 14-45), Google Earth Imagery, 07/08/2018



**SITE LEGEND**

- PARKING SPACE TAGS
- BARRIER FREE PARKING SPACE
- TREE / PLANTING
- PROPERTY LINE
- ZONING SETBACKS
- GRAVEL
- EXISTING BUILDING
- PROPOSED BUILDING
- RIP-RAP
- SWM POND
- EXTERIOR DOOR / B.F. ENTRANCE
- UNOBSTRUCTED FIRE FIGHTER ACCESS DOOR/WINDOW/PANEL
- OVERHEAD DOOR
- TRUCK ROUTE
- FENCE LINE
- SOD / GRASS
- CONCRETE
- ASPHALT
- RECLAIMED ASPHALT
- FARM FIELD

**ZONING:**  
 A - AGRICULTURAL ZONE (REFER TO ZONING INFO TABLE FOR DETAILS)

**OFF-STREET PARKING: (AS PER ZBL SECTION 5.1)**

**EXISTING:**  
 PUMP AND PAST. BUILDING = 532m<sup>2</sup> x 1 SPACE / 90m<sup>2</sup> = 6 SPACES  
 SEPARATION BUILDING = 60m<sup>2</sup> x 1 SPACE / 90m<sup>2</sup> = 1 SPACES  
 EXISTING BUILDINGS = 101m<sup>2</sup> x 1 SPACE / 28m<sup>2</sup> = 4 SPACES  
 TOTAL FOR EXISTING = 11 SPACES

**PROPOSED:**  
 OFFICE = 74m<sup>2</sup> x 1 SPACE / 28m<sup>2</sup> = 3 SPACES  
 PRE-PROCESS BUILDING = 2 230m<sup>2</sup> x 1 SPACE / 90m<sup>2</sup> = 25 SPACES  
 BOILER & HEAT BUILDING = 300m<sup>2</sup> x 1 SPACE / 90m<sup>2</sup> = 4 SPACES  
 PUMP BUILDING #2 = 250m<sup>2</sup> x 1 SPACE / 90m<sup>2</sup> = 3 SPACES  
 TOTAL PROPOSED REQUIRED = 35 SPACES  
 TOTAL PROPOSED PROVIDED = 48 SPACES

**BARRIER FREE (AS PER ZBL SECTION 5.13):**  
 TOTAL REQUIRED PARKING SPACES (1 PER 20 SPACES)  
 (11 EXISTING + 36 PROPOSED) x 1 SPACE / 20 SPACES = 3 SPACES  
 THEREFORE, REQ'D NO. OF BARRIER FREE SPACES = 3 SPACES




OVERALL TOTAL PROVIDED ON SITE = 46 SPACES  
 - INCLUDING BARRIER FREE

**OFF-STREET LOADING SPACES: (AS PER ZBL SECTION 5.15)**  
 REQUIRED LOADING SPACES (AS PER ZBL SECTION 5.15)  
 GROSS FLOOR AREA (2.351 to 7.900m<sup>2</sup>) = 2 SPACE  
 TOTAL REQUIRED = 2 SPACE  
 TOTAL PROPOSED = 2 SPACE


**SITE PLAN NOTES:**

- FIRE ROUTE ACCESS REQUIRES FIRE PERSONNEL ACCESS AS REQUIRED BY OBC.
- FIRE ROUTE TO BE POSTED AND DESIGNATED UNDER MUNICIPAL BY-LAW DESIGN REQUIREMENTS AS FOLLOWS:
  - MIN. 6m WIDE
  - 12m CENTRE LINE TURNING RADIUS
  - MAX. 8% SLOPE
- FIRE ROUTE SIGNS MUST BE STANDARD OF APPLICABLE MUNICIPALITY AND ARE TO BE PLACED AS FOLLOWS:
  - INTERVALS OF NOT LESS THAN 15.2m (50')
  - NOT MORE THAN 45.7m (150') ALONG THE DESIGNATED FIRE ROUTE
  - AT A HEIGHT OF NOT LESS THAN 1.8m (6')
- ANY SITE FENCING TO BE CONFIRMED WITH OWNER PRIOR TO CONSTRUCTION
- STANDARD BUMP BLOCKS TO BE INSTALLED FOR PARKING SPOTS ON GRAVEL SURFACES. PAINTED LINES TO BE INSTALLED FOR PARKING SPOTS ON PAVED SURFACES
- YARD LIGHTING LOCATION AND ORIENTATION TO BE INSTALLED TO NOT INTERFERE WITH TRAFFIC ON COUNTY ROADS PLUS MINIMIZE INTERFERENCE ON NEIGHBORING PROPERTIES.
- PROPERTY LINES ARE APPROXIMATE AND MAY NEED TO BE CONFIRMED BY AN OLS.

ZONING BY-LAW INFORMATION TABLE			
	ZONING BY-LAW	EXISTING	PROPOSED
LOT AREA (MIN.)	400 000 m <sup>2</sup>	105 026 m <sup>2</sup>	105 026 m <sup>2</sup>
LOT FRONTAGE (MIN.)	183 m	380 m	380 m
FRONT YARD SETBACK	15 m	30 m	22.3 m
EAST SIDE YARD SETBACK	15 m	175.4 m	106.2 m
WEST SIDE YARD SETBACK	15 m	97.7 m	37.1 m
REAR YARD SETBACK	15 m	102 m	77.3 m
LOT DEPTH (MIN.)	NO PROVISIONS	226.3 m	226.3 m
BUILDING FLOOR AREA	NO PROVISIONS	N/A	3 546 m <sup>2</sup>
GROSS FLOOR AREA	NO PROVISIONS	N/A	3 546 m <sup>2</sup>
LOT COVERAGE (ALL BLDGS)	20% (MAX.)	N/A	3.4%
LOT COVERAGE (ACCESSORY)	NO PROVISIONS	0%	7.1%
BUILDING HEIGHT (MAX.)	NO PROVISIONS	N/A	14 m
NUMBER OF PARKING SPACES	44	8	47
BARRIER FREE SPACES	3	0	3
NUMBER OF LOADING SPACES	1	3	4
LANDSCAPED AREA	NO PROVISIONS	N/A	74 396 m <sup>2</sup>
GRANULAR AREA	NO PROVISIONS	N/A	8 336 m <sup>2</sup>
PAVED AREA	NO PROVISIONS	N/A	11 271 m <sup>2</sup>




**NOTES:**  
 1. ALL DIMENSIONS ARE IN MILLIMETERS.  
 2. SIGN TO CONFORM TO ALL APPLICABLE BY-LAWS AND GAATES ILLUSTRATED TECHNICAL GUIDE TO THE ACCESSIBILITY STANDARD FOR DESIGN OF PUBLIC SPACES.  
 EXACT SIZE TO BE CONFIRMED BY GC / SUPPLIER.  
 3. OPTIONAL MOUNTING ON BUILDING OR POLE.



**NOTES:**  
 PLEASE READ NOTE PAGE AT BEGINNING OF DRAWING SET FOR ALL NOTES REGARDING THIS PROJECT

NO.	DATE	DESCRIPTION

**NOTES:**  
 1. OWNER: ESCARPMENT RENEWABLES  
 2. LEGAL DESCRIPTION: PART OF LOT 1 CONCESSION 6 GEOGRAPHIC TOWNSHIP OF GRIMSBY TOWN OF GRIMSBY COUNTY OF LINCOLN  
 3. SITE GRADING, SERVING AND EROSION & SEDIMENT CONTROL PLAN PROVIDED BY GRIT ENGINEERING INC. REFER TO PROJECT No. GE22-0178-1 DRAWING No. C300 & C500




PROFESSIONAL ENGINEER'S SEAL  
**STONECREST ENGINEERING INC.**  
 EST. 1995  
 440 Wright Blvd Unit #2, Stratford, ON, N4Z 1H3  
 519-625-8025 - info@stonecrestengineering.com

CONTRACTOR TO CHECK ALL DIMENSIONS AND ELEVATIONS AND REPORT ANY DISCREPANCIES TO THE ENGINEER BEFORE PROCEEDING WITH THE WORK  
 DO NOT SCALE THE DRAWINGS

**CLIENT:** ESCARPMENT RENEWABLES  
**LOCATION:** 424 SOBYE ROAD, BEAMSVILLE, ON  
**PROJECT NAME:** PRE-PROCESS BUILDING  
**PROJECT STATUS AND VERSION:** CONCEPT DRAWINGS

**DESIGNED BY:** T.L./M.W. **PRINT DATE:** 2024.02.01  
**PAGE DESCRIPTION:** SITE LAYOUT  
**SCALE:** AS NOTED  
**FILE:** 8016-1  
**PAGE NUMBER:**

BRANDON WARTMAN, TOWN OF GRIMSBY




ESCARPMENT RENEWABLES  
 442 SOBYE ROAD, GRIMSBY, ONTARIO  
 EMISSION SUMMARY AND  
 DISPERSION MODELLING REPORT  
**PROCESS FLOW DIAGRAM**  
**WASTE RECEIVING AND PROCESSING**

Project No. 11226032  
 Date January 2022

**FIGURE 4A**


Filename: N:\CA\Waterloo\Projects\66211226032\Digital\_Design\ACAD\Figures\RPT-ESDM\11226032-GHD-0000-RPT-EN-0102\_WA-ESDM.dwg  
 Plot Date: 18 January 2022 9:29 AM



ESCARPMENT RENEWABLES  
 442 SOBYE ROAD, GRIMSBY,  
 ONTARIO EMISSION SUMMARY AND  
 DISPERSION MODELLING REPORT  
 PROCESS FLOW DIAGRAM  
 DIGESTION

Project No. 11226032  
 Date January 2022

FIGURE 4B



ESCARPMENT RENEWABLES  
 442 SOBYE ROAD, GRIMSBY, ONTARIO  
 EMISSION SUMMARY AND  
 DISPERSION MODELLING REPORT  
**PROCESS FLOW DIAGRAM**  
**DIGESTATE AND BIOGAS MANAGEMENT**

Project No. 11226032  
 Date January 2022

**FIGURE 4C**

# Tables

**Table 1**  
**Sources and Contaminants Identification Table**  
**Escarpment Renewables**  
**Grimsby, Ontario**

Source ID	Source Description	Location	Expected Contaminants	Significant (Y/N)	Rationale
S1	CHP Engines/Turbines	Outdoors	Products of Combustion, Sulphur Dioxide, TRS	Y/N	Some of the contaminants are insignificant. Refer to Appendix C and Table C.1
S2	Closed Flare	Outdoors	Products of Combustion, Sulphur Dioxide, TRS	Y/N	
S3	Biofilter Stack	Organics Pre-Processing Building	Ammonia, Hydrogen Sulphide, Odour	Y	Some of the contaminants are insignificant. Refer to Appendix C and Table C.1
S4	Boiler	Boiler/Heat Distribution Building	Products of Propane Combustion	Y/N	
S5	Biogas Upgrade Tail Gas	RNG Upgrading Facility	Carbon Dioxide, Methane	Y/N	Some of the contaminants are insignificant. Refer to Appendix C and Table C.1
S6	Digestate Loading Displacement Air	Outdoors	Odour	Y	
S7a	Grit Removal Building 1	Grit Removal Building	Odour	Y	Some of the contaminants are insignificant. Refer to Appendix C and Table C.1
S7b	Grit Removal Building 2	Grit Removal Building	Odour	Y	
S7c	Grit Removal Building 3	Grit Removal Building	Odour	Y	
S8	Emergency Generator	Outdoors	Products of Diesel Combustion	Y/N	Some of the contaminants are insignificant. Refer to Appendix C and Table C.1
A1	Receiving Tank #1 Displacement Air	Receiving Tanks - Outdoors	Odour	Y	
A2	Receiving Tank #2 Displacement Air	Receiving Tanks - Outdoors	Odour	Y	Not listed in Table 7-2 or 7-3 of Section 7.4 of the ESDM Procedure Document
A3	Receiving Tank #3 Displacement Air Roads, Parking Lots	Receiving Tanks - Outdoors Outdoors	Odour Dust	Y N	



**Table 2A**  
**Source Summary Table - Sorted by Source**  
**Escarpment Renewables**  
**Grimsby, Ontario**

Source ID	Source Type	Description	Point Source Data							Contaminant	CAS No.	Emission Data					
			Stack Flow Rate (m <sup>3</sup> /s)	Stack Exit Gas Temperature (C)	Stack Inner Diameter (m)	Stack Height Above Grade (m)	Stack Height Above Roof (m)	Exhaust Orientation	Source Coordinates			Maximum Emission Rate (g/s) or (OU/m <sup>2</sup> -s)	Averaging Period (hours)	Emission Estimation Technique	Emission Data Quality	% of Overall Emissions (%)	
									X (m)								Y (m)
S1	Point	CHP Engines/Turbines	0.60	150	0.15	9	6	Vertical	618823.2	4778286.86	Nitrogen Oxides	10102-44-0	1.67E-02	1-hr, 24-hr	EF	AA	4%
S1	Point	CHP Engines/Turbines	0.60	150	0.15	9	6	Vertical	618823.2	4778286.86	Particulate Matter	NA-PM	6.31E-03	24-hr	EF	AA	4%
S1	Point	CHP Engines/Turbines	0.60	150	0.15	9	6	Vertical	618823.2	4778286.86	Carbon Monoxide	630-08-0	1.95E-02	1/2-hr	EF	AA	3%
S1	Point	CHP Engines/Turbines	0.60	150	0.15	9	6	Vertical	618823.2	4778286.86	Sulphur Dioxide	7446-09-5	1.17E-03	1-hr, Annual	EF	AA	4%
S1	Point	CHP Engines/Turbines	0.60	150	0.15	9	6	Vertical	618823.2	4778286.86	TRS	NA-02	2.69E-05	10-minute	EF	AA	4%
S2	Point	Closed Flare	0.82	981	2.64	12.3	-	Vertical	618945.0257	4778186.179	Nitrogen Oxides	10102-44-0	3.73E-01	1-hr, 24-hr	EF	AA	87%
S2	Point	Closed Flare	0.82	981	2.64	12.3	-	Vertical	618945.0257	4778186.179	Particulate Matter	NA-PM	1.41E-01	24-hr	EF	AA	87%
S2	Point	Closed Flare	0.82	981	2.64	12.3	-	Vertical	618945.0257	4778186.179	Carbon Monoxide	630-08-0	4.36E-01	1/2-hr	EF	AA	64%
S2	Point	Closed Flare	0.82	981	2.64	12.3	-	Vertical	618945.0257	4778186.179	Sulphur Dioxide	7446-09-5	2.61E-02	1-hr, Annual	EF	AA	94%
S2	Point	Closed Flare	0.82	981	2.64	12.3	-	Vertical	618945.0257	4778186.179	TRS	NA-02	5.99E-04	10-minute	EF	AA	96%
S3	Point	Biofilter Stack	21.75	25	1.47	20	17	Vertical	618744.3731	4778198.364	Odour	NA-01	2.26E+04	10-minute	EC	A	91%
S3	Point	Biofilter Stack	21.75	25	1.47	20	17	Vertical	618744.3731	4778198.364	Ammonia	7664-41-7	3.03E-02	24-hr	EC	A	100%
S3	Point	Biofilter Stack	21.75	25	1.47	20	17	Vertical	618744.3731	4778198.364	Hydrogen Sulphide	7783-06-4	3.03E-02	10-minute, 24-hr	EC	A	100%
S4	Point	Boiler	0.36	150	0.15	3.5	-	Vertical	618821.73	4778239.017	Nitrogen Oxides	10102-44-0	4.14E-02	1-hr, 24-hr	EF	M	10%
S4	Point	Boiler	0.36	150	0.15	3.5	-	Vertical	618821.73	4778239.017	Particulate Matter	NA-PM	3.14E-03	24-hr	EF	M	2%
S4	Point	Boiler	0.36	150	0.15	3.5	-	Vertical	618821.73	4778239.017	Carbon Monoxide	630-08-0	3.47E-02	1/2-hr	EF	M	5%
S5	Point	Biogas Upgrade Tail Gas	25.70	25	1.28	5	2	Vertical	618945.3893	4778213.216	Carbon Dioxide	124-38-9	3.34E+02	24-hr	EF	A	100%
S6	Point	Digestate Loading Displacement Air	0.03	25	0.30	4	-	Capped	618926.2748	4778187.167	Odour	NA-01	7.69E+01	10-minute	EC	A	<1%
S7a	Point	Grit Removal Building 1	0.94	Ambient	0.50	2.5	-	Horizontal	618836.71	4778201.4	Odour	NA-01	6.42E+02	10-minute	EC	A	3%
S7b	Point	Grit Removal Building 2	0.94	Ambient	0.50	2.5	-	Horizontal	618861.3713	4778259.922	Odour	NA-01	6.42E+02	10-minute	EC	A	3%
S7c	Point	Grit Removal Building 3	0.94	Ambient	0.50	2.5	-	Horizontal	618883.1453	4778255.913	Odour	NA-01	6.42E+02	10-minute	EC	A	3%
S8	Point	Emergency Generator	0.73	500	0.15	1.83	-	Vertical	618841.516	4778283.622	Nitrogen Oxides	10102-44-0 (Emergency)	2.22E-01	1-hr, 24-hr	EF	M	100%
S8	Point	Emergency Generator	0.73	500	0.15	1.83	-	Vertical	618841.516	4778283.622	Particulate Matter	NA-PM	1.11E-02	24-hr	EF	M	7%
S8	Point	Emergency Generator	0.73	500	0.15	1.83	-	Vertical	618841.516	4778283.622	Carbon Monoxide	630-08-0	1.94E-01	1/2-hr	EF	M	28%
S8	Point	Emergency Generator	0.73	500	0.15	1.83	-	Vertical	618841.516	4778283.622	Sulphur Dioxide	7446-09-5	4.25E-04	1-hr, Annual	EF	M	2%
A1	Area Circle	Receiving Tank #1 Displacement Air	-	-	-	0.3	-	-	618788.9	4778210.06	Odour	NA-01	8.02E+01	10-minute	EC	A	<1%
A2	Area Circle	Receiving Tank #2 Displacement Air	-	-	-	0.3	-	-	618800.03	4778206.98	Odour	NA-01	8.02E+01	10-minute	EC	A	<1%
A3	Area Circle	Receiving Tank #3 Displacement Air	-	-	-	0.3	-	-	618811.12	4778209.47	Odour	NA-01	8.02E+01	10-minute	EC	A	<1%

## Notes:

EC - Engineering Calculation  
EF - Emission Factor  
AA - Above Average  
A - Average  
M - Marginal

**Table 2B**  
**Source Summary Table - Sorted by Contaminant**  
**Escarpment Renewables**  
**Grimsby, Ontario**

Contaminant	CAS No.	Source ID	Source Type	Description	Point Source Data						Emission Data						
					Stack Flow Rate (m <sup>3</sup> /s)	Stack Exit Gas Temperature (C)	Stack Inner Diameter (m)	Stack Height Above Grade (m)	Stack Height Above Roof (m)	Exhaust Orientation	Source Coordinates		Maximum Emission Rate (g/s) or (OU/m <sup>2</sup> -s)	Averaging Period (hours)	Emission Estimation Technique	Emission Data Quality	% of Overall Emissions (%)
											X (m)	Y (m)					
Ammonia	7664-41-7	S3	Point	Biofilter Stack	21.75	25	1.47	20	17	Vertical	618744.3731	4778198.364	3.03E-02	24-hr	EC	A	100%
Carbon Dioxide	124-38-9	S5	Point	Biogas Upgrade Tail Gas	25.70	25	1.28	5	2	Vertical	618945.3893	4778213.216	3.34E+02	24-hr	EF	A	100%
Carbon Monoxide	630-08-0	S1	Point	CHP Engines/Turbines	0.60	150	0.15	9	6	Vertical	618823.2	4778286.86	1.95E-02	1/2-hr	EF	AA	3%
Carbon Monoxide	630-08-0	S2	Point	Closed Flare	0.82	981	2.64	12.3	-	Vertical	618945.0257	4778186.179	4.36E-01	1/2-hr	EF	AA	64%
Carbon Monoxide	630-08-0	S4	Point	Boiler	0.36	150	0.15	3.5	-	Vertical	618821.73	4778239.017	3.47E-02	1/2-hr	EF	M	5%
Carbon Monoxide	630-08-0	S8	Point	Emergency Generator	0.73	500	0.15	1.83	-	Vertical	618841.516	4778283.622	1.94E-01	1/2-hr	EF	M	28%
Hydrogen Sulphide	7783-06-4	S3	Point	Biofilter Stack	21.75	25	1.47	20	17	Vertical	618744.3731	4778198.364	3.03E-02	10-minute, 24-hr	EC	A	100%
Nitrogen Oxides	10102-44-0	S1	Point	CHP Engines/Turbines	0.60	150	0.15	9	6	Vertical	618823.2	4778286.86	1.67E-02	1-hr, 24-hr	EF	AA	4%
Nitrogen Oxides	10102-44-0	S2	Point	Closed Flare	0.82	981	2.64	12.3	-	Vertical	618945.0257	4778186.179	3.73E-01	1-hr, 24-hr	EF	AA	87%
Nitrogen Oxides	10102-44-0	S4	Point	Boiler	0.36	150	0.15	3.5	-	Vertical	618821.73	4778239.017	4.14E-02	1-hr, 24-hr	EF	M	10%
Nitrogen Oxides	10102-44-0 (Emergency)	S8	Point	Emergency Generator	0.73	500	0.15	1.83	-	Vertical	618841.516	4778283.622	2.22E-01	1-hr, 24-hr	EF	M	100%
Odour	NA-01	S3	Point	Biofilter Stack	21.75	25	1.47	20	17	Vertical	618744.3731	4778198.364	2.26E+04	10-minute	EC	A	91%
Odour	NA-01	S6	Point	Digestate Loading Displacement Air	0.03	25	0.30	4	-	Capped	618926.2748	4778187.167	7.69E+01	10-minute	EC	A	<1%
Odour	NA-01	S7a	Point	Grit Removal Building 1	0.94	Ambient	0.50	2.5	-	Horizontal	618836.71	4778201.4	6.42E+02	10-minute	EC	A	3%
Odour	NA-01	S7b	Point	Grit Removal Building 2	0.94	Ambient	0.50	2.5	-	Horizontal	618861.3713	4778259.922	6.42E+02	10-minute	EC	A	3%
Odour	NA-01	S7c	Point	Grit Removal Building 3	0.94	Ambient	0.50	2.5	-	Horizontal	618883.1453	4778255.913	6.42E+02	10-minute	EC	A	3%
Odour	NA-01	A1	Area Circle	Receiving Tank #1 Displacement Air	-	-	-	0.3	-	-	618788.9	4778210.06	8.02E+01	10-minute	EC	A	<1%
Odour	NA-01	A2	Area Circle	Receiving Tank #2 Displacement Air	-	-	-	0.3	-	-	618800.03	4778206.98	8.02E+01	10-minute	EC	A	<1%
Odour	NA-01	A3	Area Circle	Receiving Tank #3 Displacement Air	-	-	-	0.3	-	-	618811.12	4778209.47	8.02E+01	10-minute	EC	A	<1%
Particulate Matter	NA-PM	S1	Point	CHP Engines/Turbines	0.60	150	0.15	9	6	Vertical	618823.2	4778286.86	6.31E-03	24-hr	EF	AA	4%
Particulate Matter	NA-PM	S2	Point	Closed Flare	0.82	981	2.64	12.3	-	Vertical	618945.0257	4778186.179	1.41E-01	24-hr	EF	AA	87%
Particulate Matter	NA-PM	S4	Point	Boiler	0.36	150	0.15	3.5	-	Vertical	618821.73	4778239.017	3.14E-03	24-hr	EF	M	2%
Particulate Matter	NA-PM	S8	Point	Emergency Generator	0.73	500	0.15	1.83	-	Vertical	618841.516	4778283.622	1.11E-02	24-hr	EF	M	7%
Sulphur Dioxide	7446-09-5	S1	Point	CHP Engines/Turbines	0.60	150	0.15	9	6	Vertical	618823.2	4778286.86	1.17E-03	1-hr, Annual	EF	AA	4%
Sulphur Dioxide	7446-09-5	S2	Point	Closed Flare	0.82	981	2.64	12.3	-	Vertical	618945.0257	4778186.179	2.61E-02	1-hr, Annual	EF	AA	94%
Sulphur Dioxide	7446-09-5	S8	Point	Emergency Generator	0.73	500	0.15	1.83	-	Vertical	618841.516	4778283.622	4.25E-04	1-hr, Annual	EF	M	2%
TRS	NA-02	S1	Point	CHP Engines/Turbines	0.60	150	0.15	9	6	Vertical	618823.2	4778286.86	2.69E-05	10-minute	EF	AA	4%
TRS	NA-02	S2	Point	Closed Flare	0.82	981	2.64	12.3	-	Vertical	618945.0257	4778186.179	5.99E-04	10-minute	EF	AA	96%

## Notes:

EC - Engineering Calculation  
EF - Emission Factor  
AA - Above Average  
A - Average  
M - Marginal

Table 3

**Dispersion Modelling Input Summary Table  
Escarpment Renewables  
Grimsby, Ontario**

<b>Relevant Section of the Regulation</b>	<b>Section Title</b>	<b>Description of How the Approved Dispersion Model was Used</b>
Section 8	Negligible Sources	Sources and contaminants that were considered negligible were explicitly identified, and therefore were not modelled, in accordance with s.8 of O. Reg. 419. See Table 1 - Sources and Contaminants Identification Table and Appendix B of the ESDM Report for more information
Section 9	Same Structure Contamination	Not applicable as the Escarpment Renewables is the only tenant occupying the site, and does not have a child care facility, health care facility, seniors' residence, long-term care facility or an educational facility located at the Facility
Section 10	Operating Conditions	All equipment was assumed to be operating at the maximum production rates at the same time. See Section 4.1 and Appendix A of the ESDM Report.
Section 11	Source of Contaminant Emission Rate	The emission rate for each significant contaminant emitted from a significant source was estimated, the methodology for the calculation is documented in Table 2 - Source Summary Table. See Section 4.1 and Section 4.2 and Appendix A of the ESDM Report for more information.
Section 12	Combined Effect of Assumptions for Operating Conditions and Emission Rates	The operating conditions were estimated in accordance with s.10(1) and 1 and S.11 (1) 1 of O. Reg. 419 and are therefore considered to result in the highest concentrations at POI that the Facility is capable of for the contaminants emitted. See Section 4.1 and Section 4.2 of the ESDM Report.
Section 13	Meteorological Conditions	MECP provided meteorological data
Section 14	Area of Modelling Coverage	The modelling coverage used correspond to the receptor grid specified in Section 14 (1) of O. Reg. 419.
Section 15	Stack Height	Please refer to Table 2.
Section 16	Terrain Data	Terrain Data was obtained from the Ontario MECP and was processed using AERMAP.
Section 17	Averaging Periods	The averaging periods required under Schedule 3 were used. For odour the hourly averaging period was converted to a 10-min average.

Table 4

**Emission Summary Table  
Escarpment Renewables  
Grimsby, Ontario**

Contaminant	CAS No.	Total Facility Emission Rate (g/s) or (OU*m <sup>3</sup> /s)	Air Dispersion Model Used	Max. POI Concentration (OU/m <sup>3</sup> ) or (µg/m <sup>3</sup> )	Averaging Period	MECP Screening Limit <sup>(2)</sup> (OU/m <sup>3</sup> ) or (µg/m <sup>3</sup> )	Limiting Effect	Benchmark Category	Percentage of MECP POI Limit
Ammonia	7664-41-7	3.03E-02	AERMOD v.19191	0.579	24-hr	100	Health	B1	<1%
Carbon Monoxide	630-08-0	6.85E-01	AERMOD v.19191	455.458	0.5-hr	6,000	Health	B1	8%
Carbon Dioxide	124-38-9	3.34E+02	AERMOD v.19191	58880.674	24-hr	255,800	Health	B2	23%
Hydrogen Sulphide	7783-06-4	3.03E-02	AERMOD v.19191	4.136	10-minute	13	Health	B1	32%
Hydrogen Sulphide	7783-06-4	3.03E-02	AERMOD v.19191	0.579	24-hr	7	Odour	B1	8%
Nitrogen Oxides	10102-44-0	4.31E-01	AERMOD v.19191	272.809	1-hr	400	Health	B1	68%
Nitrogen Oxides	10102-44-0	4.31E-01	AERMOD v.19191	57.613	24-hr	200	Health	B1	29%
Nitrogen Oxides	10102-44-0 (Emergency)	2.22E-01	AERMOD v.19191	511.822	0.5-hr	1,880	Health	Emergency	27%
Odour - Receptor	NA-01	2.48E+04	AERMOD v.19191	- <sup>(4)</sup>	10-minute	-	Odour	-	- <sup>(4)</sup>
Particulate Matter	NA-PM	1.61E-01	AERMOD v.19191	21.675	24-hr	120	Visibility	B1	18%
Sulphur Dioxide (Effective July	7446-09-5	2.77E-02	AERMOD v.19191	14.782	1-hr	100 (3)	Health & Vegetation	B1	15%
Sulphur Dioxide (Effective July	7446-09-5	2.77E-02	AERMOD v.19191	0.618	annual	10 (3)	Health & Vegetation	B1	6%
Total Reduced Sulphur	NA-02	6.26E-04	AERMOD v.19191	0.556	10-min	13	Odour	B1	4%

## Notes:

NA - Not applicable

(1) The 1-hr maximum concentration was converted to a 10-min average using a conversion factor of 1.65 as specified in the ADMGO, MECP guidance document.

(2) Criteria listed in the MECP Air Contaminants Benchmarks (ACB) List: Standards, Guidelines, and Screening Levels for Assessing POI Concentrations of Air Contaminants dated April 2018

(3) Proposed Sulphur Dioxide Limits to be implemented by 2020 as per the MECP document "Ontario Air Standards For Sulphur Dioxide (SO<sub>2</sub>)" dated March 2018

(4) Odour concentration is such that it will not result in odour complaints at sensitive receptors.

B1 - Benchmark 1 - Exceedence of a Benchmark 1 concentration triggers specific actions under the Regulation.

B2 - Benchmark 2 - Exceedence of a Benchmark 2 concentration triggers a toxicological assessment to determine the likelihood of adverse effect.

# Appendices

# **Appendix A**

**Existing Renewable Energy Approval**

**Content Copy Of Original**



Ministry of the Environment, Conservation and Parks  
Ministère de l'Environnement, de la Protection de la nature et des Parcs

**AMENDMENT TO RENEWABLE ENERGY APPROVAL  
NUMBER 8541-9HSGG3  
Issue Date: April 22, 2020**

1414229 Ontario Limited operating as Escarpment Renewables  
180 Renfrew Drive, Unit 130  
Markham, Ontario  
L3R 9Z2

**Site Location:** Grimsby Energy Inc. Anaerobic Digester  
424 Sobie Rd  
Grimsby Town, Regional Municipality of Niagara  
L3M 4E7

*You are hereby notified that I have amended Approval No. 8541-9HSGG3 issued on October 1, 2014 for a Class 3 anaerobic digestion facility , as follows:*

**A. The Company name and address has been changed:**

FROM: Grimsby Energy Incorporated  
231 Roberts Rd  
Grimsby, Ontario  
L3M 5N2

TO: 1414229 Ontario Limited operating as Escarpment Renewables  
180 Renfrew Drive, Unit 130  
Markham, Ontario  
L3R 9Z2

**B. The definitions of the "Application" and "Company" of the Approval are deleted and replaced by the following:**

4. "Application" means the application for a Renewable Energy Approval dated February 26, 2013, signed by James Detenbeck, President, Grimsby Energy Inc., and all supporting documentation submitted with the application, including amended documentation submitted up to September 2, 2014; and as further amended by the application for an amendment to the Renewable Energy Approval dated June 26, 2017, signed by Gerhard Klammer, CEO, PurEnergy Resources Inc., and all supporting documentation submitted with the application, including amended documentation submitted up to November 17, 2017; and as further amended by the application for an amendment to the Renewable Energy Approval dated October 18, 2019, signed by Jud Whiteside, President, and all supporting documentation submitted with the application, including amended documentation submitted up to April 1, 2020.

10. "Company" means 1414229 Ontario Limited operating as Escarpment Renewables and includes its successors and assignees;

**All other Terms and Conditions of the Approval remain the same.**

**This Notice shall constitute part of the approval issued under Approval No. 8541-9HSGG3 dated October 1, 2014**

*In accordance with Section 139 of the Environmental Protection Act, within 15 days after the service of this notice, you may by further written notice served upon the Director, the Environmental Review Tribunal and the Minister of the Environment, Conservation and Parks, require a hearing by the Tribunal.*

*In accordance with Section 47 of the Environmental Bill of Rights, 1993, the Minister of the Environment, Conservation and Parks will place notice of your request for a hearing on the Environmental Registry.*

*Section 142 of the Environmental Protection Act provides that the notice requiring the hearing shall state:*

- a. The portions of the renewable energy approval or each term or condition in the renewable energy approval in respect of which the hearing is required, and;
- b. The grounds on which you intend to rely at the hearing in relation to each portion appealed.

*The signed and dated notice requiring the hearing should also include:*

1. The name of the appellant;
2. The address of the appellant;
3. The renewable energy approval number;
4. The date of the renewable energy approval;
5. The name of the Director;
6. The municipality or municipalities within which the project is to be engaged in;

*This notice must be served upon:*

**The Secretary\*  
Environmental Review  
Tribunal  
655 Bay Street, 15th Floor  
Toronto, Ontario  
M5G 1E5**

**AND**

**The Minister of the  
Environment, Conservation  
and Parks  
777 Bay Street, 5th Floor  
Toronto, Ontario  
M7A 2J3**

**AND**

**The Director  
Section 47.5, *Environmental  
Protection Act*  
Ministry of the Environment,  
Conservation and Parks  
135 St. Clair Avenue West, 1st Floor  
Toronto, Ontario  
M4V 1P5**

**\* Further information on the Environmental Review Tribunal's requirements for an appeal can be obtained directly from the Tribunal at: Tel: (416) 212-6349, Fax: (416) 326-5370 or [www.ert.gov.on.ca](http://www.ert.gov.on.ca)**



*Under Section 142.1 of the Environmental Protection Act, residents of Ontario may require a hearing by the Environmental Review Tribunal within 15 days after the day on which notice of this decision is published in the Environmental Registry. By accessing the Environmental Registry at <https://ero.ontario.ca/>, you can determine when this period ends.*

*Approval for the above noted renewable energy project is issued to you under Section 47.5 of the Environmental Protection Act subject to the terms and conditions outlined above.*

DATED AT TORONTO this 22nd day of April, 2020

Mohsen Keyvani, P.Eng.  
Director  
Section 47.5, *Environmental Protection Act*

JG/  
c: District Manager, MECP Niagara  
Christine McLeod, Miller Waste Systems Inc.

# **Appendix B**

## **Supporting Calculation**

# Appendix B Supporting Calculations Escarpment Renewables

## Usage Rates

The usage rates found in Table B.1 correspond to the operating conditions that would result in maximum emission rate in accordance with s.10 and s.11 of O. Reg. 419/05.

## List of Combustion Equipment

A list of combustion equipment and their associated ratings are found in Table B.2.

## Emission Calculations

**Source:** S1 and S2 - Digester Gas Combustion

**Methodology:** Emission Factor (EF)

The estimated maximum emission rate for nitrogen oxides (NOx), Particulate Matter and Carbon Monoxide were determined based on the USEPA AP-42 emission factors from Chapter 2.4, emission factors for digester gas combustion in flares.

The estimated maximum emission rate for sulphur dioxide (SO<sub>2</sub>) was determined based on an emission factor calculation methodology from the document entitled "Air Quality Emissions and Impact, Milbank Community Foundation dba Midwest Dairy Institute". A hydrogen sulphide content of 10 parts per million (ppm) was assumed and is reflective of typical digester gas composition. An AP-42 Conversion factor obtained by dividing the molecular weight of hydrogen sulphide by a value of 385.1 was used to convert ppm to lb/MMft<sup>3</sup>. The calculated emission factor was multiplied by the maximum heat input rating to determine an emission rate. Emission estimates from S1 are provided in Table B.3 and the emission estimates from S2 are provided in Table B.4.

Hydrogen Sulphide Content =	10 ppm
AP-42 Conversion Factor (ppm to lbs/MMft <sup>3</sup> ) =	0.088 lbs/MMft <sup>3</sup>
Weight fraction of sulphur in hydrogen sulphide =	0.9408 lb S/lb H <sub>2</sub> S
Weight fraction of sulphur in sulphur dioxide =	0.5 lb S/lb SO <sub>2</sub>
Heat Content of Digester Gas =	614 MMBtus/MMft <sup>3</sup>

The USEPA quotes these emission factor as having a quality rating of "A".

**Sample Calculation:** Sulphur Dioxide emissions from CHP (S1)

$$EF = 10 \text{ ppm} \times \frac{0.088 \text{ lb H}_2\text{S}}{\text{MMft}^3} \times \frac{0.9408 \text{ SO}_2}{\text{lb H}_2\text{S}} \times \frac{\text{MMft}^3}{614 \text{ MMBTU}}$$

$$EF = 0.0027 \frac{\text{lb SO}_2}{\text{MMBTU}}$$

$$ER = 0.0027 \frac{lb SO_2}{MMBTU} \times \frac{3,412,000 BTU}{hr} \times \frac{MMBTU}{1,000,000 BTU} \times \frac{hr}{3600 sec} \times \frac{kg}{2.2 lbs} \times \frac{1000 g}{kg}$$

$$ER = 1.17 \times 10^{-3} \frac{g}{s}$$

**Sample Calculation:** Nitrogen Oxide emissions from CHP (S1)

$$ER = \frac{3,412,000 BTU}{hr} \times 631 \frac{kg}{10^6 m^3} \times \frac{ft^3}{614 BTU} \times \frac{1 m^3}{35.28 ft^3} \times \frac{1000g}{kg} \times \frac{hr}{3600 sec} \times 60.7\% methane$$

$$ER = 1.67 \times 10^{-2} \frac{g}{s}$$

**Data Quality:** Above Average

Section 9.2.3 of the ESDM Procedure Document titled "Average Data Quality" Emission Estimating Techniques includes emission estimates that are developed from tests on a reasonable number of facilities where the source category population is sufficiently specific to minimize variability.

Section 9.2.2 of the ESDM Procedure Document titled "Above Average Data Quality" Emission Estimating Techniques includes emission estimates with a USEPA AP-42 emission factor quality rating of "A" or "B".

**Operating Condition, Individual Maximum Rates of Production:**

The emission rate calculation for these sources are based on each piece of combustion equipment operating simultaneously at its maximum firing rate.

**Source:** S4 – Boiler

**Methodology:** Emission Factor (EF)

The emissions from the natural gas/propane fueled generator have been calculated based on USEPA AP-42 Chapter 1.4, Table 1.4-1 and Chapter 1.5, Table 1.5-1 respectively. The estimated emissions from the boiler are presented in Table B.5.

**Sample Calculation:** Carbon Monoxide emissions from Natural Gas Burning Boiler (S4)

$$ER = \frac{3,353,996 BTU}{hr} \times 1,344 \frac{1 kg NOx}{k10^6 m^3} \times \frac{1000 g}{kg} \times \frac{1 ft^3}{1,020 BTU} \times \frac{0.0283 m^3}{ft^3} \times \frac{1 hr}{3600 sec}$$

$$ER = 2.61 \times 10^{-2} \frac{g}{s}$$

**Data Quality:** Marginal

Section 9.2.4 of the ESDM Procedure Document titled "Marginal Data Quality" Emission Estimating Techniques, includes emission factors with a rating of "D".

**Operating Condition, Individual Maximum Rates of Production:**

The emission estimates for this source is based on the boiler operating at its maximum firing rate.

**Source:** S8 – Emergency Generator

**Methodology:** Emission Factor (EF)

The emissions from the diesel-fueled generator have been calculated based on US EPA Tier 3 standards for "Nonroad Compression-Ignition Engines: Exhaust Emission Standards" (EPA-420-B-16-022, March 2016). The sulphur dioxide emissions were estimated using a typical fuel consumption rate and sulphur content in diesel. The estimated emissions from the generators are presented in Table B.6.

**Sample Calculation:** Nitrogen Oxide emissions from Emergency Generator (S8)

$$ER = 200 \text{ kW} \times 4 \frac{\text{g}}{\text{kW} \cdot \text{hr}} \times \frac{1 \text{ hr}}{3600 \text{ sec}}$$

$$ER = 0.22 \frac{\text{g}}{\text{s}}$$

**Sample Calculation:** Sulphur Dioxide emissions from Emergency Generator (S8)

$$ER = 51 \frac{\text{kg}}{\text{hr}} \times 15 \frac{\text{mg}}{\text{kg}} \times \frac{1 \text{ g}}{1000 \text{ mg}} \times \frac{1 \text{ hr}}{3600 \text{ sec}}$$

$$ER = 4.25 \times 10^{-4} \frac{\text{g}}{\text{s}}$$

**Data Quality:** Marginal

Section 9.2.4 of the ESDM Procedure Document titled "Marginal Data Quality" Emission Estimating Techniques, includes emission factors with a rating of "D", and calculations where the scientific/technical integrity of the approach is uncertain.

**Operating Condition, Individual Maximum Rates of Production:**

The emission estimates for this source is based on the emergency generator operating at its maximum firing rate.

**Source:** A1, A2, A3, S3, S6, S7a, S7b, S7c – Odour, Ammonia, and Hydrogen Sulphide Emissions

**Methodology:** Emission Factor (EF)

The odour detection threshold emission factor (EF) must be converted to an odour emission rate (OU/s). The source flow rate (m<sup>3</sup>/s) and the odour detection threshold emission factor (OU/s) were used to estimate the emissions. The odour concentration value was based on the document entitled "Odor Threshold Emission Factors for Common WWTP Processes" from St. Croix Sensory Inc., dated April 2008.

The estimated emissions from the processes are presented in Table B.7.

**Sample Calculation:** Odour emissions from the Receiving Tank #1 Displacement Air (A1)

$$ER = ODT \times Q$$

$$ER = 7,000 \times 0.0115 \frac{\text{m}^3}{\text{s}}$$

$$ER = 80.2 \frac{\text{OU m}^3}{\text{s}}$$

Where:

ER = Emission rate of compound (OU m<sup>3</sup>/s or g/s)

ODT = Odour concentration of compound (OU/m<sup>3</sup> or g/ m<sup>3</sup>)

Q = aerated air flow rate (m<sup>3</sup>/s)

**Data Quality:** Average

Section 9.2.3 of the ESDM Procedure Document titled "Average Data Quality" Emission Estimating Techniques includes emission factor calculations with USEPA emission factor quality rating of "C".

**Operating Condition, Individual Maximum Rates of Production:**

The emission rate calculations for these sources are based on maximum operating conditions and published emission factors specific to these processes.

**Source:** S5 – Tail Gas Emissions

**Methodology:** Engineering Calculation (EC)

The Biogas Upgrade Facility will emit a tail gas of carbon dioxide and methane. The source flow rate was used to calculate a contaminant flow rate based on the design values of 40% of the biogas being carbon dioxide and 60% being methane with 98.5% of this being recovered. Based on the compound densities their maximum emission rates were calculated.

The estimated emissions from the tail gas are presented in Table B.8.

**Sample Calculation:** Methane emissions from the Biogas Upgrade Tail Gas (S5)

$$ER = 1,542 \frac{m^3}{hr} \times 60\% \text{ methane} \times (100\% - 98.5\% \text{ recovered methane}) \times 0.621 \frac{kg}{m^3} \times 1000 \frac{g}{kg} \times \frac{hr}{3,600 s}$$

$$ER = 2.39 \frac{g}{s}$$

**Data Quality:** Average

Section 9.2.3 of the ESDM Procedure Document titled "Average Data Quality" Emission Estimating Techniques includes Engineering Calculations.

**Operating Condition, Individual Maximum Rates of Production:**

The emission rate calculations for this source are based on maximum operating conditions.

Table B.1

**Product Usage Rates  
Escarpment Renewables  
Grimsby, Ontario**

<b>Source Designation</b>	<b>Description</b>	<b>Maximum Processing Rate</b>
S1	CHP Engines/Turbines	1,000.00 kW
S2	Flare	104,700.00 ft <sup>3</sup> /hour
S3	Biofilter Stack	1,879,344.00 m <sup>3</sup> /day
S4	Boiler	983.00 kW
S5	Biogas Upgrade Tail Gas	1,542.00 m <sup>3</sup> /hr
S6	Digestate Loading Displacement Air	384.10 m <sup>3</sup> /day
S7a	Grit Removal Building 1	0.94 m <sup>3</sup> /s
S7b	Grit Removal Building 2	0.94 m <sup>3</sup> /s
S7c	Grit Removal Building 3	0.94 m <sup>3</sup> /s
S8	Emergency Diesel Generator	200.00 kW
A1	Receiving Tank #1 Displacement Air	55.01 m <sup>3</sup> /day
A2	Receiving Tank #2 Displacement Air	55.01 m <sup>3</sup> /day
A3	Receiving Tank #3 Displacement Air	55.01 m <sup>3</sup> /day

Table B.2

**List of Combustion Equipment  
Escarpment Renewables  
Grimsby, Ontario**

<b>Source ID</b>	<b>Description</b>	<b>Ratings (kW)</b>	<b>Ratings (BTU/hr)</b>
S1	CHP Engines/Turbines	1,000	3,412,000
S2	Closed Flare	22,304	76,100,000
S4	Standby Boiler Exhaust 983 kW	983	3,353,996
S8	Standby Diesel Generator	200	682,400



**Table B.3**

**Estimated Emissions from use of CHP  
Escarpment Renewables  
Grimsby, Ontario**

**Maximum CHP (S1) Heat Input Rating (Digester Gas):** 3,412,000 Btu/hr

<b>Compound</b>	<b>CAS No.</b>	<b>USEPA AP-42 Emission Factor - Biogas (kg/10<sup>6</sup>m<sup>3</sup>) Methane</b>	<b>Estimated Maximum Emission Rate (g/s)<sup>(1)</sup></b>
Nitrogen Dioxide	10102-44-0	631	1.67E-02
Particulate Matter	NA-PM	238	6.31E-03
Carbon Monoxide	630-08-0	737	1.95E-02

Flare Operating on Digester Gas:

Hydrogen Sulphide Content<sup>(2)</sup> = 10 ppm  
 AP-42 Conversion Factor (ppm to lbs/MMft<sup>3</sup>)<sup>(3)</sup> = 0.088 lbs/MMft<sup>3</sup>  
 Weight fraction of sulphur in hydrogen sulphide = 0.9408 lb S / lb H<sub>2</sub>S  
 Weight fraction of sulphur in sulphur dioxide = 0.5 lb S / lb SO<sub>2</sub>  
 Heat Content of Digester Gas = 614 MMBtus / MMft<sup>3</sup>

<b>Compound</b>	<b>Digester Gas Emission Factor<sup>(4)</sup> (lbs. SO<sub>2</sub> / MMBtu)</b>	<b>Conversion Efficiency<sup>(5)</sup> (%)</b>	<b>Estimated Maximum Emission Rate<sup>(6)</sup> (g/s)</b>
Sulphur Dioxide	0.0027		1.17E-03
Total Reduced Sulphur		97.7	2.69E-05

Notes:

- (1) Based on a digester gas heating value of 614 BTU/ft<sup>3</sup>, methane concentration of 60.7%, and the USEPA AP-42 Chapter 2.4 Table 2.4-4 emission factors for digester gas combustion in a Flare.
- (2) Hydrogen Sulphide content based on typical digester gas composition
- (3) AP-42 Conversion Factor is calculated by dividing the molecular weight of hydrogen sulphide by a value of 385.1.
- (4) The emission factor calculation is based on a document entitled "Air Quality Emissions and Impact, Milbank Community Foundation dba Midwest Dairy Institute, Milbank, South Dakota"
- (5) AP-42 Chapter 2.4 control efficiency for a flare operating on biogas converting hydrogen sulphide into sulphur dioxide is 97.7%.
- (6) As a conservative estimate the biogas has not been adjusted for air : fuel ratio.

**Table B.4**

**Estimated Emissions from use of Digester Gas Flare  
Escarpment Renewables  
Grimsby, Ontario**

**Maximum Flare (S2) Heat Input Rating (Digester Gas):** 76,100,000 Btu/hr

<b>Compound</b>	<b>CAS No.</b>	<b>USEPA AP-42 Emission Factor - Biogas (kg/10<sup>6</sup>m<sup>3</sup>) Methane</b>	<b>Estimated Maximum Emission Rate (g/s)<sup>(1)</sup></b>
Nitrogen Dioxide	10102-44-0	631	3.73E-01
Particulate Matter	NA-PM	238	1.41E-01
Carbon Monoxide	630-08-0	737	4.36E-01

Flare Operating on Digester Gas:

Hydrogen Sulphide Content<sup>(2)</sup> = 10 ppm  
 AP-42 Conversion Factor (ppm to lbs/MMft<sup>3</sup>)<sup>(3)</sup> = 0.088 lbs/MMft<sup>3</sup>  
 Weight fraction of sulphur in hydrogen sulphide = 0.9408 lb S / lb H<sub>2</sub>S  
 Weight fraction of sulphur in sulphur dioxide = 0.5 lb S / lb SO<sub>2</sub>  
 Heat Content of Digester Gas = 614 MMBtus / MMft<sup>3</sup>

<b>Compound</b>	<b>Digester Gas Emission Factor<sup>(4)</sup> (lbs. SO<sub>2</sub> / MMBtu)</b>	<b>Conversion Efficiency<sup>(5)</sup> (%)</b>	<b>Estimated Maximum Emission Rate<sup>(6)</sup> (g/s)</b>
Sulphur Dioxide	0.0027		2.61E-02
Total Reduced Sulphur		97.7	5.99E-04

Notes:

- (1) Based on a digester gas heating value of 614 BTU/ft<sup>3</sup>, methane concentration of 60.7%, and the USEPA AP-42 Chapter 2.4 emission factors for digester gas combustion in a Flare.
- (2) Hydrogen Sulphide content based on typical digester gas composition
- (3) AP-42 Conversion Factor is calculated by dividing the molecular weight of hydrogen sulphide by a value of 385.1.
- (4) The emission factor calculation is based on a document entitled "Air Quality Emissions and Impact, Milbank Community Foundation dba Midwest Dairy Institute, Milbank, South Dakota"
- (5) AP-42 Chapter 2.4 control efficiency for a flare operating on biogas converting hydrogen sulphide into sulphur dioxide is 97.7%.
- (6) As a conservative estimate the biogas has not been adjusted for air : fuel ratio.

**Table B.5**

**Estimated Combustion Products Emissions from Boiler  
Escarpment Renewables  
Grimsby, Ontario**

<b>Maximum Boiler (S4) Heat Input Rating: 3,353,996</b>		<b>BTU/hr</b>			
<b>Compound</b>	<b>CAS No.</b>	<b>USEPA AP-42 Emission Factor - Natural Gas (kg/10<sup>6</sup>m<sup>3</sup>)</b>	<b>USEPA AP-42 Emission Factor - Propane (kg/10<sup>6</sup>m<sup>3</sup>)</b>	<b>Natural Gas (Alternate) Estimated Maximum Emission Rate (g/s)<sup>(1)</sup></b>	<b>Propane Estimated Maximum Emission Rate (g/s)<sup>(2)</sup></b>
Carbon Monoxide	630-08-0	1344	1008	3.47E-02	2.61E-02
Nitrogen Oxides	10102-44-0	1600	1560	4.14E-02	4.03E-02
Particulate Matter	NA-PM	122	84	3.14E-03	2.17E-03

- Notes:
- (1) Based on the maximum facility heat input rating, a natural gas heating value of 1,020 BTU/ft<sup>3</sup> and USEPA AP-42 Chapter 1.4 emission factors for natural gas combustion in commercial boilers (<100 MM BTU).
  - (2) Based on the maximum facility heat input rating, a propane heating value of 1,020 BTU/ft<sup>3</sup> and USEPA AP-42 Chapter 1.5 emission factors for propane combustion in commercial boilers (<100 MM BTU).
  - (3) The maximum value between the two estimated emission rates (per pollutant) was chosen as input for AERMOD.

Table B.6

**Estimated Maximum Diesel Combustion Products  
Escarpment Renewables  
Grimsby, Ontario**

**Maximum Emergency Generator (S8) Heat Input Rating:                      200                      kW**

Source ID	Compound	CAS No.	Tier 3 Emission Factor - Compression Ignition <sup>(2)</sup> (g/kW-hr)	Estimated Maximum Emission Rate (g/s)
S8	Nitrogen Oxides	10102-44-0 (Emergency)	4.00E+00 (3)	2.22E-01
	Carbon Monoxide	630-08-0	3.50E+00	1.94E-01
	Particulate Matter	NA-PM	2.00E-01	1.11E-02
	Sulphur Dioxide	7446-09-5	-	4.25E-04

**Estimating SO<sub>2</sub> emissions:**

Fuel Consumption	60	L/hr
	51	kg/hr
Sulphur in Diesel	15	mg/kg
Sulphur consumption rate	2.13E-04	g/s
SO <sub>2</sub> Emission Rate	4.25E-04	g/s

Notes:

(1) The generator is expected to adhere to Tier 3 rating of emissions as per US EPA guidelines.

(2) Emission factors taken from US EPA "Nonroad Compression-Ignition Engines: Exhaust Emission Standards" (EPA-420-B-16-022, March 2016)

(3) The NMHC + NO<sub>x</sub> emission factor from (2) is chosen to conservatively represent total NO<sub>x</sub> emissions.

(4) The SO<sub>2</sub> emission rate is estimated based on sulphur content in diesel (as per Sulphur in Diesel Fuel Regulations SOR/2002-254), and typical fuel consumption rate of a 200 kW generator at full load.

Table B.7

**Estimated Odour and Ammonia and Hydrogen Sulphide Emissions  
Escarpment Renewables  
Grimsby, Ontario**

<b>Source ID</b>	<b>Description</b>	<b>Compound</b>	<b>CAS No.</b>	<b>Flowrate (m<sup>3</sup>/s)</b>	<b>Source Concentration <sup>(1)</sup> (ou/m<sup>3</sup>) or (g/m<sup>3</sup>)</b>	<b>Estimated Maximum Emission Rate (ou m<sup>3</sup>/s) or (g/s)</b>
A1	Receiving Tank #1 Displacement Air	Odour	NA-01	0.0115 (2)	7,000	80.2
A2	Receiving Tank #2 Displacement Air	Odour	NA-01	0.0115 (2)	7,000	80.2
A3	Receiving Tank #3 Displacement Air	Odour	NA-01	0.0115 (2)	7,000	80.2
S3	Biofilter Stack	Odour	NA-01	21.75	1,038	22,578
		Ammonia	7664-41-7		0.00139 (3)	0.0303
		Hydrogen Sulphide	7783-06-4		0.001 (4)	0.0303
S6	Digestate Loading Displacement Air	Odour	NA-01	0.030 (5)	2,600	77
S7a	Grit Removal Building 1	Odour	NA-01	0.9438	680	6.42E+02
S7b	Grit Removal Building 2	Odour	NA-01	0.9438	680	6.42E+02
S7c	Grit Removal Building 3	Odour	NA-01	0.9438	680	6.42E+02

## Notes:

(1) Odour concentrations based on "Odor Threshold Emission Factors for Common WWTP Processes" from St. Croix Sensory Inc., April 2008 unless otherwise stated.

(2) Based on a fill time of 10 minutes per delivery. Maximum of 8 deliveries per day.

(3) Ammonia content (6 ppm) based on typical tank head gas composition

(4) Hydrogen Sulphide content (1 ppm) based on typical tank head gas composition

(5) Based on a fill time of 15 minutes per delivery. Maximum of 15 deliveries per day.

Table B.8

**Biogas Upgrade Tail Gas Emission Calculations  
Escarpment Renewables  
Grimsby, Ontario**

<b>Source ID</b>	<b>Description</b>	<b>Compound</b>	<b>CAS No.</b>	<b>Flowrate (m<sup>3</sup>/h)</b>	<b>Contaminant Flow Rate <sup>(1)</sup> (m<sup>3</sup>/h)</b>	<b>Density (kg/m<sup>3</sup>)</b>	<b>Estimated Maximum Emission Rate (g/s)</b>
S5	Biogas Upgrade Tail Gas	Carbon Dioxide	124-38-9	1,542	617	1.95	3.34E+02
		Methane	74-82-8	1,542	14	0.62	2.39E+00

Note:

(1) Biogas methane content is 60% of which 98.5% is recovered.

# **Appendix C**

**Supporting Information for  
Assessment of Negligibility**

# Appendix C Supporting Information for Assessment of Negligibility Escarpment Renewables

Sources were screened for negligibility using the following screening protocols listed in the ESDM Procedure Document:

- Combustion of natural gas and propane (Section 7.1.1.)
- Identifying significant contaminants using an emission threshold (Section 7.1.2)
- Specific examples of sources that emit contaminants in negligible amounts (Section 7.2.2 and Table B-3)

## ***Combustion of Natural Gas and Propane***

As per Section 7.1.1 of the ESDM Procedure Document contaminants other than NO<sub>x</sub> are generally considered negligible from this type of source. Therefore, only NO<sub>x</sub> has been assessed for the following list of equipment listed in Table B.2.

## ***Identifying Significant Contaminants using an Emission Threshold:***

Section 7.1.2 of the ESDM Procedure Document states that contaminants that are emitted from a specific facility may be identified as negligible when they are below emissions thresholds that are developed using the following formula:

$$\text{Emission Threshold (g/s)} = \frac{0.5 \times \text{MECP POI Limit } (\mu\text{g/m}^3)}{\text{Dispersion Factor } (\mu\text{g/m}^3 \text{ per g/s emission})}$$

All facility emissions of contaminants with an MECP POI limit were assessed against the appropriate emission threshold based on the appropriate 1-hour urban dispersion factor of 8,700  $\mu\text{g/m}^3$  per g/s 20 m from the property boundary. A number of contaminants are deemed to be emitted in negligible amounts, as indicated in Table C.1.

## ***Specific Examples of Sources that Emit Contaminants in Negligible Amounts***

Table B-3 of the ESDM Report Procedure Document and O. Reg. 524/98 lists sources that can be considered to be insignificant. The following sources at the Facility are listed in either Table B-3 or O. Reg. 524/98:

- General exhausts, sources such as building exhausts, building ventilation, building intake, change rooms, cafeteria, release valves, etc.
- Roads and parking lot (NAICS code not listed in Tables 7-2 and 7-3 of Section 7.4 of the ESDM Report Procedure Document)



**Table C.1**

**Assessment of Significance  
Escarpment Renewables  
Grimsby, Ontario**

<b>Contaminant</b>	<b>CAS #</b>	<b>Emission Rate (g/s) or (OU/s)</b>	<b>MECP POI Limit <sup>(1)</sup> (µg/m<sup>3</sup>)</b>	<b>Averaging Period</b>	<b>Limiting Effect</b>	<b>Benchmark Category</b>	<b>Emission Threshold <sup>(2)</sup> (g/s)</b>	<b>Significant? (Yes/No)</b>
Ammonia	7664-41-7	3.03E-02	100	24-hr	Health	B1	1.40E-02	Yes
Carbon Dioxide	124-38-9	3.34E+02	255,800	24-hr	Health	B2	3.58E+01	Yes
Carbon Monoxide	630-08-0	6.85E-01	6,000	1/2-hr	Health	B1	2.84E-01	Yes
Hydrogen Sulphide	7783-06-4	3.03E-02	13	10-minute	Odour	B1	4.52E-04	Yes
Hydrogen Sulphide	7783-06-4	3.03E-02	7	24-hr	Health	B1	9.80E-04	Yes
Methane	74-82-8	2.39E+00	37,330	24-hr	Health	B2	5.22E+00	No
Nitrogen Oxides	10102-44-0	4.31E-01	400	1-hr	Health	B1	2.30E-02	Yes
Nitrogen Oxides	10102-44-0	4.31E-01	200	24-hr	Health	B1	2.80E-02	Yes
Nitrogen Oxides	10102-44-0 (Emergency)	2.22E-01	1,800	1/2-hr	Emergency	Emergency	8.52E-02	Yes
Particulate Matter	NA-PM	1.61E-01	120	24-hr	Visibility	B1	1.68E-02	Yes
Sulphur Dioxide (Effective until July 1, 2023)	7446-09-5	2.77E-02	690	1-hr	Health & Vegetation	B1	3.97E-02	No
Sulphur Dioxide (Effective until July 1, 2023)	7446-09-5	2.77E-02	275	24-hr	Health & Vegetation	B1	3.85E-02	No
Sulphur Dioxide (Effective July 1, 2023)	7446-09-5	2.77E-02	100	1-hr	Health & Vegetation	B1	5.75E-03	Yes
Sulphur Dioxide (Effective July 1, 2023)	7446-09-5	2.77E-02	10	Annual	Health & Vegetation	B1	7.30E-03	Yes
Total Reduced Sulphur	NA-02	6.26E-04	13	10-minute	Odour	B1	4.52E-04	Yes
Total Reduced Sulphur	NA-02	6.26E-04	7	24-hr	Health	B1	9.80E-04	No

Notes:

(1) MECP POI Limit listed on the "Air Contaminants Benchmarks (ACB) List: Standards, Guidelines and Screening Levels for Assessing Point of Impingement Concentrations of Air Contaminants" publication dated April 2018.

(2) Emission Threshold based on the following default urban dispersion factors from Table B-1 of the ESDM Report Procedure Document:

10-minute	14,368	(µg/m <sup>3</sup> )/(g/s)
1/2-hr	10,563	(µg/m <sup>3</sup> )/(g/s)
1-hr	8,700	(µg/m <sup>3</sup> )/(g/s)
24-hr	3,573	(µg/m <sup>3</sup> )/(g/s)
30-day	1,379	(µg/m <sup>3</sup> )/(g/s)
Annual	685	(µg/m <sup>3</sup> )/(g/s)

B1 - Benchmark 1 - Exceedence of a Benchmark 1 concentration triggers specific actions under the Regulation

B2 - Benchmark 2 - Exceedence of a Benchmark 2 concentration triggers a toxicological assessment to determine the likelihood of adverse effect.

# **Appendix D**

**Dispersion Modelling Input**

Table D.1

**AERMOD Dispersion Modelling Input Parameters  
Escarpment Renewables  
Grimsby, Ontario**

Source ID	Description	Stack Velocity (m/s)	Exhaust Temperature (K)	Exhaust Diameter (m)	Stack Height Above Grade (m)	Exhaust Orientation	UTM Source Coordinates	
							x (m)	y (m)
S1	CHP Engines/Turbines	33.95	423.15	0.15	9.00	VERTICAL	618823.20	4778286.86
S2	Closed Flare	0.15	1254.15	2.64	12.30	VERTICAL	618945.03	4778186.18
S3	Biofilter Stack	12.83	298.15	1.47	20.00	VERTICAL	618744.37	4778198.36
S4	Boiler	20.00	423.15	0.15	3.50	VERTICAL	618821.73	4778239.02
S5	Biogas Upgrade Tail Gas	20.00	298.15	1.28	5.00	VERTICAL	618945.39	4778213.22
S6	Digestate Loading Displacement Air	0.42	298.15	0.30	4.00	CAPPED	618926.27	4778187.17
S7A	Grit Removal Building 1	4.81	298.15	0.50	2.50	HORIZONTAL	618836.71	4778201.40
S7B	Grit Removal Building 2	4.81	298.15	0.50	2.50	HORIZONTAL	618861.37	4778259.92
S7C	Grit Removal Building 3	4.81	298.15	0.50	2.50	HORIZONTAL	618883.15	4778255.91
S8	Emergency Generator	40.00	773.15	0.15	1.83	VERTICAL	618841.52	4778283.62
A1	Receiving Tank #1 Displacement Air	-	-	5.32	0.30	-	618788.90	4778210.06
A2	Receiving Tank #2 Displacement Air	-	-	5.32	0.30	-	618800.03	4778206.98
A3	Receiving Tank #3 Displacement Air	-	-	5.32	0.30	-	618811.12	4778209.47



[ghd.com](http://ghd.com)

→ **The Power of Commitment**

# **Appendix B**

## **Odour Report**





# **Odour Study Report**

## **Grimsby Anaerobic Digestion Site**

**ESCARPMENT RENEWABLES**

29 July 2024

<b>Project name</b>		ESCARPMENT-Grimsby AD Permitting					
<b>Document title</b>		Odour Study Report   Grimsby Anaerobic Digestion Site					
<b>Project number</b>		11226032-RPT-5					
<b>File name</b>		11226032-RPT-5-Odour Study Report-Final					
Status Code	Revision	Author	Reviewer		Approved for issue		
			Name	Signature	Name	Signature	Date
S3	00	Punith Nallathamby	Matthew Griffin		Matthew Griffin		
S4	01	Punith Nallathamby	Matthew Griffin		Matthew Griffin		Nov. 19, 2023
S4	02	Punith Nallathamby	Matthew Griffin		Matthew Griffin		July 29, 2024

**GHD**

Contact: Matthew Griffin, Engineering Leader | GHD

455 Phillip Street, Unit 100A

Waterloo, Ontario N2L 3X2, Canada

T +1 519 884 0510 | F +1 519 884 0525 | E info-northamerica@ghd.com | [ghd.com](https://www.ghd.com)

© GHD 2024

This document is and shall remain the property of GHD. The document may only be used for the purpose for which it was commissioned and in accordance with the Terms of Engagement for the commission. Unauthorised use of this document in any form whatsoever is prohibited.

# Executive summary

This Odour Study Report has been prepared in accordance with Table 1 of Ontario Regulation 359/09. A summary of where information is contained in this report as it relates to these requirements is provided below.

*Table E.1 Ontario Regulation 359/09 Compliance Summary*

<b>Requirements</b>	<b>Location in Report</b>
Set out the following information in respect of the renewable energy project:	
1. The significant process and fugitive sources of odour discharge from the renewable energy generation facility.	Section 3
2. Any negative environmental effects that may result from the odour discharge mentioned in paragraph 1 at all odour receptors.	Section 3
3. The technical methods that are expected to be employed to mitigate any negative environmental effects mentioned in paragraph 2 and the negative environmental effects that are expected to result if the technical methods are employed.	Section 4 and 5



# Contents

<b>1. Introduction</b>	<b>1</b>
1.1 Purpose of this Report	1
<b>2. Background</b>	<b>1</b>
2.1 Surrounding Land Use	2
<b>3. Sources of Odour</b>	<b>2</b>
3.1 Odour Generation Variables	2
<b>4. Odour Abatement Measures</b>	<b>3</b>
4.1 Generation of Biogas	3
4.2 Unloading of Organic Material	3
4.3 Organic Separation, Pre-Processing, and Storage	3
4.4 Fugitive Emissions	3
4.5 Digestate Loading Activities	4
4.6 Biofilter	4
4.6.1 Inorganic Media Biofilter	4
4.6.2 Negative Pressure Ventilation	5
4.7 Flare	6
<b>5. Operation of Odour Abatement Measures</b>	<b>6</b>
<b>6. Ongoing Site Monitoring</b>	<b>6</b>
<b>7. Complaints Response</b>	<b>7</b>
<b>8. Conclusions</b>	<b>7</b>

## Figure index

Figure 1            Odour Points of Reception

# 1. Introduction

## 1.1 Purpose of this Report

This report was prepared to fulfil the Renewable Energy Approval (REA) requirements as set out in Ontario Regulation 359/09. The report summarizes the operations and odour abatement measures planned for the Escarpment Renewables Anaerobic Digester (AD) facility at 424 Soby Road in Grimsby, Ontario (Site). Escarpment Renewables currently operates under REA No. 8541-9HSGG3, as amended. The project is a Class 3 AD with a name plate capacity of 1 Megawatt (MW).

Escarpment Renewables intends to complete a Site expansion along with additional Site improvements. This includes acceptance of new waste types and increased waste tonnage, along with building new infrastructure on Site to manage additional waste processing requirements. The proposed Site expansion will have effects on the AD facility's design, capacity, and processes.

The AD facility plans on processing up to 159,000 tonnes of organics annually to generate biogas. The biogas is combusted in a combined heat and power (CHP) system to produce 1 MW of electrical energy. Long-term, sustainable renewable energy generation and diversion of organic materials from landfills will be ensured through the responsible and profitable operation of the AD facility.

Air dispersion modelling has been performed for the significant sources of odour at the Site as outlined in the Emission Summary and Air Dispersion Modelling (ESDM) report. As per the MECP guidelines the Site was deemed to meet the odour standards. Odour emissions from the Site are an indication of a loss in biogas production potential. The AD facility will be designed and operated to prevent generation of odour as much as possible to maximize biogas production.

## 2. Background

The Site consists of an organics processing facility, which will be capable of receiving and processing up to 159,000 tonnes of organic waste per year by AD. The existing waste storage bunkers will be decommissioned. A new organics pre-processing building will be constructed with all the necessary equipment to receive, temporarily store, and process solid organic material for digestion. Liquid receiving tanks are located near the existing pump and pasteurization building and will continue to receive liquid organic material for processing. The AD facility, which is currently operational, will be expanded with additional digester tanks and additional processing equipment. Digestate management currently consists of two storage tanks which will remain. Two additional digestate storage tanks will be constructed. The existing biogas management area consists of a CHP engine, flare, and biogas storage area. The Site will continue to utilize biogas in the existing CHP. The existing temporary biogas storage will be decommissioned in favour of storing biogas in double membrane roof systems on the new digestate storage tanks. Biogas will also be upgraded to renewable natural gas (RNG) for temporary storage on Site in tube trailers prior to transportation off Site. The existing administration buildings, which consist of an office and staff building will remain. Air treatment will be managed by a new air treatment system that manages potentially odour-impacted air generated within the organics pre-processing building. There is also a stormwater management ponds located at the south end of the Site, which will be unchanged. The Site access consists of a gravel road which will be realigned to make space for additional tanks and equipment.

The Site is committed to controlling odour from its operations to mitigate any negative environmental impacts that may result from odour discharge at the Site.

The project expansion will be constructed on lands owned by Escarpment Renewables, which owns and operates the Site. The Site is located on the northwestern 4.8 hectares (ha) of a 10.5 ha property located on the south side of

Sobye Road approximately 300 metres (m) east of Park Road South. The proposed expansion will further develop the 10.5 ha property to utilize a total of approximately 6 ha.

A detailed description of the project expansion can be found in the Project Description Report.

## 2.1 Surrounding Land Use

The surrounding area is mostly zoned for agricultural purposes. In the immediate vicinity are a number of poultry and cattle farms. Immediately to the west of the subject property at the southeast corner of Sobye and Park Roads is a closed landfill site owned by the Region of Niagara. This site was closed in 1995. This area is zoned for Agricultural use. To the north is a radio transmission tower field. This area is zoned SC(H), Specialty Crop with a Holding designation.

To the east is undeveloped farmland and a poultry farm that is in the agricultural use zone. The lands to the south of the property are classified as Significant Woodlands, with some wetlands, and contain a small watercourse. This area is zoned for agricultural use with a holding designation, and also has an additional permitted use as a riding stable. The lands to the south also contain areas zoned Environmental Conservation (EC) and Hazard which restricts development in these areas.

The nearest receptor to the Site is a farmhouse located on the west side of Park Road south of Sobye Road. This home is located approximately 400 m from the western property line and is separated from the project Site by the closed landfill which is approximately 8 m above grade.

## 3. Sources of Odour

The following sources at the Site have been identified as potential odour sources:

- Generation of Biogas, Digesters, and Digestate Tanks – Biogas is generated in Digestion Tanks when organic materials at the AD facility undergo anaerobic digestion
- Unloading of Organic Material – Solid and liquid organic material is transported on Site and is unloaded in the organics pre-processing building (solids) or the receiving tanks (liquids)
- Organic Separation, Preprocessing, and Storage – Once the organics are unloaded at the AD facility, they undergo some separation and pre-processing in the new organics processing building
- Fugitive Building Emissions – Fugitive odour emissions resulting from unloading and preprocessing could be released from the new organics processing building and the pump and pasteurization building if there is not adequate negative pressure in the building
- Digestate Loading to be Shipped Off Site – The liquid digestate will be collected by a hauling company. The digestate will be pumped into trucks that will park beside the RNG Facility for loading. The solid digestate will be separated out and stored in the digestate separation buildings before being moved to the pump and pasteurization building to be loaded on trucks
- Biofilter – The biofilter is used to treat the air that is used for the building ventilation in the unloading and processing areas
- Flare – the back-up flare is used to combust excess biogas during times when the CHP and RNG Facility are not operational, or biogas production exceeds the demands of the engine and RNG Facility

### 3.1 Odour Generation Variables

Odour varies greatly based on the feedstocks received at an AD facility. There may be some variability associated with the quantity of odour generated from the organic materials at the Site. The odour emissions from this Site have been conservatively estimated. Variables that can affect the generation of odour from the Site include: the level of

decomposition of the organic materials, types of materials at the Site, the flowrate to the biofilter, the operation of the biofilter and the length of time the doors are open. The Site will be operating to minimize odour and will consider these variables in its operations.

## **4. Odour Abatement Measures**

### **4.1 Generation of Biogas**

Biogas is created in the the digesters and the digestate tanks. The digesters and digestate tanks are sealed with double membrane covers. All the biogas from these AD process tanks is combusted in the CHP unit and RNG Facility. If the CHP unit and RNG Facility is incapacitated for any reason or more biogas is generated than can be consumed by the CHP unit and RNG Facility the automated backup flare will combust the biogas. Combustion of the biogas eliminates odour in the biogas. This reduces the potential for odours being emitted from the Site during the actual AD process.

### **4.2 Unloading of Organic Material**

Odours are potentially generated from the incoming organic material, depending on the type of material, as it is unloaded and stored before it is pumped into the sealed AD process tanks. Odours from the unloading will be reduced by minimizing the amount of time that feedstock material is stored prior to addition to the AD process. Fresher material has less potential for odour and greater biogas potential.

The material will also be transported on Site using covered trailers or tanker trucks. The doors at the AD facility will close quickly once the truck is inside the AD facility to minimize the potential release of odours from overhead doors. Unloading of all trucks that are bringing unprocessed organics will be done indoors in negative pressure unloading areas. All air that is vented from the building will be treated with a Biofilter as described in Section 4.6. The building ventilation calculation is also provided in Section 4.6.2.

Liquid materials will be received directly into the outdoor receiving tanks. The receiving tanks will be closed when not receiving material.

### **4.3 Organic Separation, Pre-Processing, and Storage**

Odours are potentially generated from the organic materials as it is separated, pre-processed, and stored before it is pumped into the sealed AD process tanks. The AD facility will be designed and operated to manage all potential odours generated as part of the pre and post-processing steps of the AD process. The Site will have enclosed storage tanks for liquid organic materials. These tanks will be vented to the atmosphere, having negligible odour emissions through breathing losses. Maximum odour emissions from these tanks are expected during the loading process, when the headspace is displaced and exhausted. The operations occurring in the building may be regarded as fugitive sources of emissions. However, the building will be under adequate negative pressure to ensure that all air from the processing activities is vented through the biofilter. Preprocessing and organic solids separation and storage will be done indoors directly under exhaust hoods that create localized negative pressure zones with two to five air exchanges per hour. All air that is vented from these exhausts will be treated with a biofilter, as described in Section 4.6.

### **4.4 Fugitive Emissions**

The building will be kept under negative pressure when the doors are closed so that there will be no fugitive emissions from the building. This negative pressure will be maintained from the draw of air through the building by the biofilter. Air will be drawn into the building using controlled air intake louvers. Although the negative pressure may be lost

during the opening and closing of doors, it is expected that the biofilter fan will provide adequate ventilation. No fugitive emissions are expected to be emitted to the environment as the louvers will close when the doors are open and the intake ventilation air will be drawn through the open doors. When the doors are closed, the louvers will open once more permitting air to enter the building to create the negative pressure once again.

There will be no outdoor waste storage at the Site. All organic material will be transferred and stored indoors. The storage tanks at the Site will be enclosed. During storage tank filling, the headspace of air displaced will be vented.

It is not expected that the storm water management ponds will be a significant source of odour, as it will only collect runoff (i.e., rainwater) from the Site.

## 4.5 Digestate Loading Activities

A third-party hauler will collect the digestate at the Site and will ship it off Site to be used as a soil amendment or fertilizer. The truck will arrive on Site and will be filled with digestate by pumping it directly from the digestate storage into a tanker. During the filling, the air in the empty truck will be displaced and exhausted.

## 4.6 Biofilter

The biofilter will be used to treat the air that is exhausted from the pre-processing building, from activities including: truck loading and unloading, and organics pre-processing. There will be insignificant fugitive emissions from the building because the building will be under negative pressure when the doors are closed. There will be no outdoor waste storage at the Site. All organic material will be transferred and stored indoors. The inorganic media biofilters planned for the Site will have the following key features:

- 85% odour removal efficiency (manufacturer guaranteed performance rating)
- Sized and configured to provide redundancy to allow maintenance and servicing on one module while still providing treatment capacity on remaining modules by maintaining an inventory of parts, altering the flow rate to the biofilter, or by using the air as combustion intake air for the engines
- Inorganic filter media depth of 1.83 m
- Biofilter will have an empty bed residence time of approximately 34-seconds
- Temperature and humidity of incoming air controlled for optimum biofilter performance
- Permanent inorganic filter material with 10-year warranty to reduce media replacement downtime
- Operator friendly automated controls compatible with Site control system

### 4.6.1 Inorganic Media Biofilter

Inorganic biofilters have been used in waste processing applications and are being utilized more often as regulations impose more rigid standards on odour emissions. In general, inorganic systems:

- Have a higher capital cost than organic systems
- Require less maintenance
- Have lower operating costs

A prime advantage of inorganic biofilters compared against organic media biofilters, is the lower total pressure drop and the deeper allowable media depth as a result. Typically, an inorganic system employs a media depth of up to 2 m, that can decrease the footprint requirements by half as compared to an organic system. Additionally, the empty bed retention time for these systems are also generally lower (typically 30 to 35 seconds). Inorganic media systems offer less frequent media refreshment cycles. Some vendors offer warranties to support a 10-year life cycle for the media. Much less frequent removal schedules imply less overall maintenance, system shutdowns for media removal, and greater consistency in odour abatement performance. Additionally, odour removal efficiencies are generally higher and

more consistent for inorganic systems. Of note, inorganic systems have low background odour profile and thus, the theoretical maximum removal efficiency.

Escarpment Renewables recognizes that inorganic systems require attention to inlet air. Hydrogen sulphide and ammonia concentrations must be below critical operating levels, or must be removed if they are above prior to exposure of process air to the media. Humidification is critical, and while inorganic systems generally allow for pre-humidification without surface irrigation, the level of humidity must be ensured at near saturation conditions for the media to be effective. A 28 m high stack is included in the biofilter design in order to achieve good dispersion of potential emissions.

## 4.6.2 Negative Pressure Ventilation

The following calculation has been performed to demonstrate the ventilation/air exchanges that will take place in the building based on the various processing equipment that will be operated. This air volume will be treated by the biofilter prior to discharge to the atmosphere. The air volume calculation has been performed based on the maximum odour generation potential in the summer. The actual air exchanges will vary depending on the process and environmental conditions.

A ventilation system will be provided to maintain negative pressure in the organics pre-processing building. To minimize air volumes requiring treatment, air will be cascaded from areas with lower odour potential to areas with higher odour potential, with air ultimately being drawn from the waste receiving area and into a biofilter. Electrical, control, and administrative rooms will have separate air handling systems that are not connected to the biofilter. Odourous air will not be generated in these rooms and they will be maintained under positive pressure.

The air ventilation calculation includes:

- The volume of air to be ventilated from the shop or storage at an air exchange rate of approximately two exchanges per hour
- The volume of air exhausted from Processing and Residuals Area and Waste Receiving Area at a rate of approximately five exchanges per hour

### Estimated Flow Rate Requirements

#### *Building Volumes*

Shop/Storage – 2,282 cubic metres (m<sup>3</sup>)

Processing and Residuals Area – 7,816 m<sup>3</sup>

Waste Receiving Area – 15,661 m<sup>3</sup>

**Total Volume: 25,760 m<sup>3</sup>**

#### *Air Exchanges*

Shop/Storage – (2,282 x 2 exchanges per hour) = 4,564 m<sup>3</sup>/hr

Processing and Residuals Area – (7,816 x 5 exchanges per hour) = 39,082 m<sup>3</sup>/hr

Waste Receiving Area – (15,661 x 5 exchanges per hour) = 78,306 m<sup>3</sup>/hr

#### *Volume from Previous Rooms*

Shop/Storage – 0 m<sup>3</sup>/hr

Processing and Residuals Area – 4,564 m<sup>3</sup>/hr

Waste Receiving Area – 39,082 m<sup>3</sup>/hr

#### *Additional Air Intake Required*

Shop/Storage – (4,564 – 0) = 4,564 m<sup>3</sup>/hr

Processing and Residuals Area –  $(39,082 - 4,564) = 34,518 \text{ m}^3/\text{hr}$

Waste Receiving Area –  $(78,306 - 39,082) = 39,224 \text{ m}^3/\text{hr}$

**Total flow to biofilter = 78,306 m<sup>3</sup>/hr**

The maximum flow rate to the biofilter is 78,306 m<sup>3</sup>/hr. This flow rate will ensure adequate negative pressure.

## 4.7 Flare

Escarpment Renewables will have an automated back-up flare in the event of bio-gas production in excess of the capacity of the CHP unit and RNG Facility. The flare will combust the biogas or RNG. Combustion of the biogas eliminates odour in the biogas.

# 5. Operation of Odour Abatement Measures

Escarpment Renewables understands that proper operation and maintenance of the odour abatement measures is essential to the success of the Site, not only to comply with regulatory obligations and to avoid conflicts with neighbors, but also to ensure the continued profitability of the Site. Less biogas translates directly to less renewable energy generation and is therefore a loss of revenue for Escarpment Renewables.

Where possible, Escarpment Renewables will source equipment from local suppliers to ensure that the supplier will be able to assist with the installation, start-up, maintenance, and repair of the equipment in a timely fashion. Where equipment cannot be purchased locally, the necessary training will be provided to Escarpment Renewables staff either on Site or at the supplier's location.

Proper operation of the AD facility, including the odour abatement measures, will result in a AD facility that will not have a negative impact on the neighborhood in which it is installed.

# 6. Ongoing Site Monitoring

The Site will be inspected on a daily basis to ensure that odours are not a problem. If odours are detected, the following steps will be put in place progressively until the odour is mitigated:

- Confirm all odour mitigation procedures and best practices are followed
- Ensure that the Process Building is maintained under negative pressure
- Inspect outdoor facilities for spills or standing water
- Inspect all piping, pumps, tanks, and other exposed equipment for cracks, leaks, etc.

The Site will maintain spare parts on Site so that in the case of malfunction or maintenance, the repairs can be completed in a timely manner.

## 7. Complaints Response

Escarpment Renewables design and operating procedures have been developed with the intention of minimizing negative impacts to the surrounding community. However, in the event that complaints regarding the operation of the Site are received, Escarpment Renewables will handle the complaints as follows:

- Escarpment Renewables has an existing complaint log that includes the following information:
  - Weather conditions (wind strength, wind direction, temperature, precipitation)
  - Contact information of the complaint
  - Details of the nature and severity of the complaint
  - Location, time, and date where the problem occurred and any other person to witness or be involved with the event
  - Time, date, and name of Escarpment Renewables/Township/Regional employee who received complaint
  - Any unusual events or activities that were occurring on Site that may have attributed or caused the event which resulted in the complaint
  - Any other information pertinent to the specific complaint
- Coordinate complaint response with MECP staff where there is an exceedance of the MECP legislation limits or a term or condition of the Renewable Energy Approval
- Cooperate with the MECP on voluntary or mandatory compliance instruments and record actions taken in this regard
- Provide complainant with feedback about the problem and how it was rectified, within seven days of the complaint. If the issue cannot be rectified within seven days, Escarpment Renewables will continue to provide the complainant with weekly updates of mitigative actions being taken until the issue is resolved

## 8. Conclusions


Odour modelling has been performed for the significant sources of odour at the Site. As per the Technical Bulletin “Methodology for Modelling Assessments of Contaminants With 10-Minute Average Standards and Guidelines for Odour under O. Reg. 419/05” dated September 2016; a frequency of exceedance analysis was conducted, and for each modelled year the frequency of exceedance was found to be less than 0.5%; hence the Site is deemed to meet the standard.





**Legend**

- Sensitive Receptor Location
- Site Boundary
- 1 KM Radius



Map Projection: Transverse Mercator  
 Horizontal Datum: North American 1983  
 Grid: NAD 1983 UTM Zone 17N

**ESCARPMENT RENEWABLES**  
 424 SOBYE ROAD, GRIMSBY, ONTARIO  
 ODOUR STUDY REPORT

Project No. 11226032  
 Revision No. 4  
 Date Nov 23, 2021

**ODOUR POINTS OF RECEPTION**

**FIGURE 1**

Q:\268\PROJECTS\11226032\11226032\_001111\_03R11226032\_001111\_03R\_C001.mxd  
 Print date: 23 Nov 2021 - 12:52

Data source: Township of West Lincoln Zoning By-Law No. 2011-F70, Town of Grimsby Zoning By-Law (By-Law 14-03), Google Earth Imagery 07/06/2018



# **Appendix C**

**Acoustic Assessment report**



# **Acoustic Assessment Report**

**424 Soby Road, Grimsby,  
Ontario**

Escarpment Renewables

August 26, 2024

## Company Name

Escarpment Renewables

## Company Address

Unit Number	Street Number 424	Street Name Sobye Road	PO Box
City/Town Grimsby	Province Ontario		Postal Code L3M 0K8
Location of Facility 424 Sobye Road, Grimsby, Ontario			

The attached Acoustic Assessment Report was prepared in accordance with the guidance in the ministry document "Information to be Submitted for Approval of Stationary Sources of Sound" (NPC-233) dated October 1995 and the minimum required information identified in the check-list on the reverse of this sheet has been submitted.

## Company Contact

Company Contact


Peter Lee

Last Name Lee	First Name Peter	Middle Initial
Title Site Engineer	Telephone Number 289-455-5001	
Signature		Date (yyyy/mm/dd) 2023/11/24

## Technical Contact

Technical Contact

Michael Masschaele

Last Name Masschaele	First Name Michael	Middle Initial
Representing GHD	Telephone Number 519-580-3842	
Signature 		Date (yyyy/mm/dd) 2023/11/08

	Required Information	Submitted	Explanation/Reference
<b>1.0</b>	<b>Introduction (Project Background and Overview)</b>	<input checked="" type="checkbox"/> Yes	<a href="#">Section 1</a>
<b>2.0</b>	<b>Facility Description</b>		
	2.1 Operating hours of Facility and significant Noise Sources	<input checked="" type="checkbox"/> Yes	<a href="#">Section 1</a>
	2.2 Site Plan identifying all significant Noise Sources	<input checked="" type="checkbox"/> Yes	<a href="#">Figure 1</a>
<b>3.0</b>	<b>Noise Source Summary</b>		
	3.1 Noise Source Summary Table	<input checked="" type="checkbox"/> Yes	<a href="#">Table 1</a>
	3.2 Source noise emissions specifications	<input checked="" type="checkbox"/> Yes	<a href="#">Table 1/Appendix C</a>
	3.3 Source power/capacity ratings	<input checked="" type="checkbox"/> Yes	<a href="#">Table 1</a>
	3.4 Noise control equipment description and acoustical specifications	<input checked="" type="checkbox"/> Yes	<a href="#">Table 1/Section 5</a>
<b>4.0</b>	<b>Point of Reception Noise Impact Calculations</b>		
	4.1 Point of Reception Noise Impact Table	<input checked="" type="checkbox"/> Yes	<a href="#">Table 2</a>
	4.2 Point(s) of Reception (POR) list and description	<input checked="" type="checkbox"/> Yes	<a href="#">Section 3</a>
	4.3 Land-use Zoning Plan	<input checked="" type="checkbox"/> Yes	<a href="#">Appendix A</a>
	4.4 Scaled Area Location Plan	<input checked="" type="checkbox"/> Yes	<a href="#">Figure 2/3</a>
	4.5 Procedure used to assess noise impacts at each POR	<input checked="" type="checkbox"/> Yes	<a href="#">Cadna A/ISO 9613-2</a>
	4.6 List of parameters/assumptions used in calculations	<input checked="" type="checkbox"/> Yes	<a href="#">Section 5</a>
<b>5.0</b>	<b>Acoustic Assessment Summary</b>		
	5.1 Acoustic Assessment Summary Table	<input checked="" type="checkbox"/> Yes	<a href="#">Table 3</a>
	5.2 Rationale for selecting applicable noise guideline limits	<input checked="" type="checkbox"/> Yes	<a href="#">Section 5</a>
	5.3 Predictable Worst Case Impacts Operating Scenario	<input checked="" type="checkbox"/> Yes	<a href="#">Section 5</a>
<b>6.0</b>	<b>Conclusions</b>		
	6.1 Statement of compliance with the selected noise performance limits	<input checked="" type="checkbox"/> Yes	<a href="#">Section 6</a>
<b>7.0</b>	<b>Appendices (Provide details such as)</b>		
	Listing of Insignificant Noise Sources	<input checked="" type="checkbox"/> Yes	<a href="#">Appendix B</a>
	Manufacturer's Noise Specifications	<input checked="" type="checkbox"/> Yes	<a href="#">Section 4/Appendix C</a>
	Calculations	<input checked="" type="checkbox"/> Yes	<a href="#">Appendix E/Cadna A</a>
	Instrumentation	<input checked="" type="checkbox"/> Yes	<a href="#">Section 4</a>
	Meteorology during Sound Level Measurements	<input checked="" type="checkbox"/> Yes	<a href="#">Section 4</a>
	Raw Data from Measurements	<input checked="" type="checkbox"/> Yes	<a href="#">Appendix C</a>
	Drawings (Facility / Equipment)	<input checked="" type="checkbox"/> Yes	<a href="#">Figure 1</a>

**GHD**

455 Phillip Street, Unit 100A

Waterloo, Ontario N2L 3X2, Canada

T +1 519 884 0510 | F +1 519 884 0525 | E info-northamerica@ghd.com | **ghd.com**

<b>Printed date</b>	2024-26-07 5:00:00 PM
<b>Last saved date</b>	July 26, 2024
<b>File name</b>	https://projects-northamerica.ghd.com/sites/na06_02/propmillergrimsby/ProjectDocs/8.11226032-RPT-13-Acoustic Assessment Report-Grimsby - (Final R2).docx
<b>Author</b>	Sam East
<b>Project manager</b>	Jason Wilson
<b>Client name</b>	Escarpment Renewables
<b>Project name</b>	ESCARPMENT-Grimsby AD Permitting
<b>Document title</b>	Acoustic Assessment Report   424 Soby Road, Grimsby, Ontario
<b>Revision version</b>	Rev [00]
<b>Project number</b>	11226032-RPT-13-Rev2

**Document status**

Status Code	Revision	Author	Reviewer		Approved for issue		
			Name	Signature	Name	Signature	Date
S0	DRAFT	Sam East	Michael Masschaele				
S4	FINAL	Sam East	Michael Masschaele		Michael Masschaele		Jan.25/22
S4	FINAL	Sam East	Michael Masschaele		Michael Masschaele		May 10/22
S4	FINAL	Sam East	Michael Masschaele	<i>Michael Masschaele</i>	Michael Masschaele	<i>Michael Masschaele</i>	Nov.8/23
S4	FINAL	Sam East	Michael Masschaele	<i>Michael Masschaele</i>	Michael Masschaele	<i>Michael Masschaele</i>	Aug.26, 2024

© GHD 2023

This document is and shall remain the property of GHD. The document may only be used for the purpose for which it was commissioned and in accordance with the Terms of Engagement for the commission. Unauthorised use of this document in any form whatsoever is prohibited.

# Executive Summary

GHD was retained by Escarpment Renewables (Escarpment) to assess the environmental sound emissions for the anaerobic digester facility (Facility) located at 424 Soby Road, Grimsby, Ontario (Site). This Acoustic Assessment Report (AAR) is required in support of the Facility's amendment application to the Ministry of the Environment, Conservation and Parks (MECP) existing Renewable Energy Approval (REA).

The analysis indicates that the cumulative sound emissions of the Facility meet the sound level limits established in accordance with NPC-300 at the nearest residences during the predictable worst-case hour upon implementation of a Noise Abatement Plan.

This report is subject to, and must be read in conjunction with, the limitations set out in Section 1.2 and the assumptions and qualifications contained throughout the Report.



# Contents

<b>1.</b>	<b>Introduction</b>	<b>1</b>
1.1	Purpose of this Report	1
<b>2.</b>	<b>Noise Source Summary</b>	<b>1</b>
<b>3.</b>	<b>Point of Reception Summary</b>	<b>2</b>
<b>4.</b>	<b>Sound Level Data</b>	<b>3</b>
4.1	Short Term Steady State Sound Level Measurements	3
4.2	Manufacturer or Previously Published Sound Level Data	3
4.3	Indoor Noise Sources	4
4.3.1	Organic Processing Building – Open Bay Doors	5
<b>5.</b>	<b>Assessment Criteria</b>	<b>5</b>
5.1	Sound Level Limits for Stationary Noise Sources	5
5.1.1	MECP Standard Limits	5
5.1.2	Sound Level Limits for Emergency Equipment	7
5.2	Impact Assessment	7
5.2.1	Steady State Sound Levels	7
5.2.2	Emergency Equipment Sound Levels	8
5.2.3	Noise Abatement Action Plan	8
5.2.4	Proposed Noise Abatement Required for Compliance	8
5.2.4.1	Existing Physical Noise Abatement Measures	8
5.2.4.2	Existing Operational Noise Controls	8
5.2.4.3	Required Physical Noise Abatement Measures	8
5.2.4.4	Required Operational Noise Controls	9
5.2.5	Noise Abatement Implementation Schedule	9
<b>6.</b>	<b>Conclusions</b>	<b>9</b>

## Figure Index

Figure 1	Site and Noise Source Location Plan
Figure 2	Point-of-Reception Location Plan
Figure 3A	Noise Contour Plot 1.5 M Above Grade – Attenuated – Nighttime
Figure 3B	Noise Contour Plot 4.5 M Above Grade – Attenuated – Nighttime
Figure 4	Berm Location Plan

## Table Index

Table 1	Noise Source Summary	
Table 2a	Point of Reception Unattenuated Noise Impact Steady State and Emergency Sound Levels	
Table 2b	Point of Reception Attenuated Noise Impact Steady State and Emergency Sound Levels	
Table 3	Acoustic Assessment Summary – Steady State Sound Levels	
Table 5.1	MECP Minimum Exclusionary Sound Level Limits for Steady Sound	6
Table 5.2	Applicable Minimum MECP Sound Level Limits for Steady State Sound	6

## Appendices

Appendix A	Land Use Zoning Plan
Appendix B	Summary of Insignificant Noise Sources
Appendix C	Noise Source Sound Level Summary
Appendix D	Manufacturer Specifications and Preliminary Drawings
Appendix E	CadnaA Sample Calculation

# 1. Introduction

## 1.1 Purpose of this Report

GHD has prepared an updated Acoustic Assessment Report (AAR) for the Escarpment Renewables facility (Facility) located at 424 Soby Road, Grimsby, Ontario. This AAR has been prepared to support the Facility's Renewable Energy Approval (REA) amendment application to the Ministry of the Environment, Conservation and Parks (MECP). The Facility currently operates under REA (Air & Noise) No. 8541-9HSGG3 that was originally dated February 16, 2012 and was most recently amended April 22, 2020. The updates to the Facility and its acoustic assessment are as follows:

- Updated aerial imagery
- New sound measurements taken of all existing equipment (S1 – S8, S17 – S19)
- Evaluation of a proposed Site expansion including a new organic processing building, a renewable natural gas (RNG) upgrading facility with virtual injection, and additional biogas digestion/storage tanks (S10 – S16)

Escarpment operates an anaerobic digester (AD) for the purposes of power generation from biogas harvested from biodegradable waste. The proposed expansion will expand the capabilities of the Facility to include the generation of RNG. This RNG will be shipped through a 'virtual pipeline' (i.e., by truck) to an injection site for direct injection into an existing natural gas pipeline. The Facility operates up to 24 hours per day, 7 days per week and 52 weeks per year under the North American Industry Classification System (NAICS) Code 562210 – "Waste Treatment and Disposal".

This AAR provides an evaluation of the potential noise impacts at the sensitive receptors located nearest to the Facility. The AAR was prepared consistent with the following MECP guidance:

- NPC-103, "Procedures", August 1978
- NPC-233, "Information to be Submitted for Approval of Stationary Sources of Sound", October 1995
- "Basic Comprehensive Certificates of Approval (Air), User Guide, Appendix A - Supporting Information for an Acoustic Assessment Report or Vibration Assessment Report Required by a Basic Comprehensive CofA prepared by the Environmental Assessment and Approvals Branch, Version 2.1, March 2011"
- NPC-300, "Environmental Noise Guideline, Stationary and Transportation Sources – Approval and Planning", August 2013

The Facility is located on Agricultural zoned land. The land immediately surrounding the Facility in all directions and all sensitive receptors are also zoned Agricultural. The land north of the Facility is a subset of agricultural zoning called Specialty Crop which does not permit residential development on existing lots zoned specialty crop per the Town of Grimsby By-Law No. 14-45. As a result, this land does not include any vacant lot receptors. A zoning map and zoning definitions are provided in Appendix A. A site plan is provided on Figure 1. The Facility is in an Acoustical Class 3 area defined by NPC-300 as rural areas with an acoustical environment that is dominated by natural sounds having little or no road traffic. Topographical changes in terrain surrounding the Facility are reflected in the acoustic model.

## 2. Noise Source Summary

This AAR focuses on the sound emissions from the significant noise sources identified at the Facility with the potential to adversely impact the sensitive receptors. The significant noise sources are identified in the Noise Source Summary Table 1 and the locations are identified on Figure 1.

For clarity, modelling IDs are consistent with the Emission Summary Dispersion Modelling (ESDM) report. Noise-only sources have been identified using an alternate naming method.

As mentioned in Section 4 of this report, GHD has modelled all the significant proposed noise sources associated with the Facility expansion based on provided manufacturer specifications or sound level data that is considered representative of the equipment based on size and power rating. Prior to finalization of equipment selections, equipment specifications (including sound level data) should be reviewed to ensure they are within the "not-to-exceed" sound levels specified in this AAR.

Onsite transport truck activities for shipping and receiving is summarized below:

Type of Vehicle	Day 7 AM- 7 PM (Trips/hour)	Evening 7 PM- 11 PM (Trips /hour)	Night 11 PM- 7 AM (Trips /hour)
All Truck Traffic (Processing Area, Liquid Loading, RNG, Residuals, Digestate)	10	3	3

These modelled truck traffic volumes are greater than what is stipulated in the design and operations report. This has been done to account for the occasional hour where higher than expected truck traffic may occur and to allow for future growth and expansion of the Facility.

In addition to the steady-state noise sources associated with regular operations, the Facility has one emergency generator (source Emg\_1) which is tested monthly for routine maintenance during daytime hours only, for up to 1 hour.

The Facility is not a source of impulse noise or vibration.<sup>1</sup>

The significant equipment sources are all either trucking related activities, rooftop equipment, or outdoor equipment located beside the building. The Facility does not have any significant interior noise sources resulting in breakout noise anywhere from the building other than the bay doors modelled. The existing buildings at the Facility are made of standard industrial construction materials. The other noise sources at the Facility have not been included since they are considered insignificant contributors to the overall Facility noise level at the sensitive receptors. A summary of insignificant noise sources is provided in Table B.1 of Appendix B.

### 3. Point of Reception Summary

The identification of appropriate sensitive point(s)-of-reception (POR) is necessary to conduct the AAR for the Facility. A POR is any point on the premises of a person where sound, originating from other than those premises, is received. The POR may be located on permanent or seasonal residences, nursing/retirement homes, rental residences, hospitals, campgrounds, schools, or places of worship.

The objective of this AAR is to determine the predictable worst-case 1-hour equivalent sound level (1-hour Leq) at the worst-case PORs. The worst-case PORs are defined as the sensitive receptors with the greatest potential exposure to the Facility noise sources due to proximity and direct line-of-sight exposure. The worst-case sensitive POR(s) are:

- POR1 – nearest façade of a two-storey residence on Park Road South approximately 400 m west of the site (4.5 metres [m] above grade [AG])
- POR2 – nearest façade of a two-storey residence on Soby Road approximately 450 m west of the site (4.5 m AG)
- POR3 – nearest façade of a two-storey residence on Soby Road approximately 500 m west of the site (4.5 m AG)

<sup>1</sup> Assessment of vibration if applicable is assessed according to NPC-207.

- POR4 – nearest façade of a one-storey residence on Soby Road approximately 500 m east of the site (1.5 m AG)
- POR5 – nearest façade of a two-storey residence on Mud Street East approximately 800 m south of the site (4.5 m AG)
- POR6 - nearest façade of a one-storey residence on Park Road South approximately 500 m northwest of the site (1.5 m AG)

The location of the worst-case PORs are identified on Figure 2.

In accordance with NPC-300 all PORs locations within 500 m of the Facility were considered including the planes of windows which were assessed for daytime and night time noise limits. In addition, the ground level amenity areas, within 30 m of each POR, were also evaluated for daytime noise limits; however, the noise impact at the worst-case and most exposed PORs are presented herein. GHD also evaluated the zoning surrounding the Facility to identify any potential vacant lots that permit a residential build and has included all relevant PORs.

## **4. Sound Level Data**

### **4.1 Short Term Steady State Sound Level Measurements**

Short-term sound level measurements of the existing equipment and operations were necessary in order to assess the worst-case potential noise impact at the PORs.

Short-term sound level measurements were taken using a Larson Davis LxT System inclusive of a Type 1 Precision Sound Level Meter (SLM), (Serial Number 001181); and a 50-mm (1/2-inch) free field condenser microphone Model 4189 (Serial Number 318571). The SLM was calibrated and checked at 114 decibels (dBA) before and after each measurement period using a Larson Davis CAL200 Acoustic Calibrator (Serial Number 2477782).

The sound descriptor used in the impact evaluation for the Facility noise sources is the 1-hour Leq, which is a time weighted energy average of the source. The Leq sound measurements consisted of short-term readings taken over an observation time of 15-second intervals with the detector in slow response using A-weighting, such that the sound levels are reported in units of dBA. All measurements were recorded and stored in the SLM. In accordance with NPC-103 "Procedures", August 1978 (NPC-103), at least three measurements were taken for each of the Facility noise sources.

Sound level measurements were taken at a reference distance depending on the height of the sources being measured and proximity to other noise sources. The location and reference distance were selected to ensure that the reference measurement was a valid representation of the dominant sources being measured. The measurement location was selected in order to measure the sound emitted in the direction of the worst-case exposure in line with the nearby sensitive receptors wherever possible and/or to minimize the influence of other noise sources and directivity issues.

Sound level measurements were conducted on June 21, 2021. Meteorological conditions consisted of low winds (<20 km/hr), low humidity, and minimal precipitation during the time measurements were conducted.

### **4.2 Manufacturer or Previously Published Sound Level Data**

Estimated sound levels for the proposed equipment is based on GHD noise source library or client supplied manufacturer specifications were used to evaluate the worst-case potential environmental noise impact based on the equipment lists, design data and equipment ratings and design concept available at the time that this AAR was being prepared.

The quantitative sound power level and sound pressure level data documented in this AAR for the proposed equipment must be considered the maximum allowable design values that cannot be exceeded. If any of the proposed noise sources are tonal in character (i.e., prominent or discrete tone, whine, screech and/or hum), a 5 dB tonality penalty should be subtracted from the sound power level and sound pressure level data documented in this AAR, as required under NPC-104. The published reference sound level data or manufacturer specifications used in this assessment are presented in Appendix D.

Where no octave band data was available for equipment sound level, the impact was estimated using the single sound power level for the 500 Hz octave band, as outlined in ISO 9132-2, "Acoustics – Attenuation of Sound During Propagation Outdoors – Part 2: General Methods of Calculation, 1996" (ISO 9613-2).

The following assumptions and noise control measures were used to complete the assessment:

- Equipment list, locations and specifications were based on the development concept and figures/information provided by Escarpment Renewables.
- **RNG Facility Inlet Compressor (S15)** is assumed to be a 75-horsepower (hp) 1,800-revolution per minute (RPM) compressor. Sound levels for a 75-hp compressor referenced from Hoover and Keith Noise Control for Buildings and Manufacturing Plants, Electric Motors, Table 7-12:

<b>Octave Band (Hz)</b>	31.5	63	125	250	500	1000	2000	4000	8000	LwA
<b>Sound Power Level (dB)</b>	92.0	87.0	87.0	86.0	89.0	92.0	92.0	90.0	87.0	108.6

This is a maximum allowable sound level limit.

- **RNG Facility Outlet Compressor (S12A & S12B)** - There will be 2 duplex compressor units to compressor the renewable natural gas before storing it in a transport truck. These compressors will have a sound power level of 105.5 dBA (equivalent to 85 dBA at 10 feet) as stipulated by the vendor supplying the equipment:

<b>Octave Band (Hz)</b>	31.5	63	125	250	500	1000	2000	4000	8000	LwA
<b>Sound Power Level (dB)</b>	99.9	94.9	94.9	93.9	96.9	99.9	99.9	97.9	94.9	105.5

- **RNG Facility Chillers (S13A & S13B)** – There will be 2 chiller units associated with the operations of the RNG Facility. These chillers will have a sound power level of 91.6 dBA (equivalent to 63 dBA at 33 feet) as provided by the manufacture and included in Appendix D:

<b>Octave Band (Hz)</b>	31.5	63	125	250	500	1000	2000	4000	8000	LwA
<b>Sound Power Level (dB)</b>	85.6	102.7	97.7	93.0	88.9	85.7	81.4	74.5	68.3	91.6

- **Organic Processing Turbo Separators (Indoor Noise Source S16A - S16F)** -There will be 2 turbo separators inside the organic processing facility for the purposes of processing and sorting incoming waste. These separators will have a sound power level of 101.3 dBA (equivalent to 90 dB at 5 feet) as provided by the manufacture and included in Appendix D:

<b>Octave Band (Hz)</b>	31.5	63	125	250	500	1000	2000	4000	8000	LwA
<b>Sound Power Level (dB)</b>	50.5	67.7	81.7	91.5	92.9	96.1	97	91	83.1	101.3

The noise data is provided in Appendix C and summarized in Table C.1 with drawings and specifications provided in Appendix D.

## 4.3 Indoor Noise Sources

Mechanical equipment and processes inside the buildings transmit sound to the environment through the building shell (i.e., walls and roof), as well as through ventilation openings and doorways. The amount of noise that passes through the building shell depends on the building's sound transmission loss characteristics as defined by the materials used and the workmanship of the wall and roof construction.

For this assessment, GHD has used the preliminary construction details provided for the building walls and roofs to determine if the proposed construction would require an evaluation of the noise emitted from building wall/roof element. Based on a review of the wall/roof elements and the separation distance to the nearest residential areas, the proposed construction materials are considered to have enough mass (concrete block/high density wall panels) to ensure that there would be no breakout noise through the building structure for most buildings.

For remaining buildings with potential noise emissions from the building or ventilation points GHD has used estimated standard industrial construction materials for these buildings' walls and roofs as detailed. Building walls and roofs will be constructed using typical sandwich-type flat insulated metal panel construction which is assumed to be conservative.

Any windows and/or door openings can be assumed to be closed at most times as the buildings are under negative pressure.

### 4.3.1 Organic Processing Building – Open Bay Doors

The organic processing building includes the following indoor noise sources:

- Two Turbo Separators (101.3 dBA)
- Five Idling Trucks (99.5 dBA)
- One Front End Loader (109.5 dBA)

Despite the fact that the building is under negative pressure meaning the bay doors will be kept closed most of the time, they have been modelled as open for a conservative evaluation and to give the Facility flexibility in operations if necessary.

The sound power level data assigned for all indoor equipment was used to calculate the indoor noise potential for the buildings. Noise coming through the open bay doors were modelled as vertical area sources. GHD expects that the Facility will provide GHD with updated equipment selections and specifications following final selection of any proposed equipment to confirm that the noise levels meet the maximum not to exceed noise criteria as specified in this AAR by proper selection or equivalent noise mitigation measures.

A detailed summary of sound power levels in full octave band centre frequencies for the indoor equipment is presented in Table C.1 of Appendix C.

## 5. Assessment Criteria

Assessment criteria may be determined for a POR based on the MECP's minimum exclusionary sound level limits, as presented in Table B 1 of NPC-300, in comparison to the background sound levels experienced in the area. The "background sound level" is defined as the sound level present in the environment that is produced by noise sources other than those from the Facility and would include traffic sound levels and sound from neighbouring industrial/commercial activity. The higher of the two assessment criteria is selected for purpose of assessment.

### 5.1 Sound Level Limits for Stationary Noise Sources

#### 5.1.1 MECP Standard Limits

NPC-300 defines stationary noise sources as sound from all sources that are normally operated within the property lines of a facility. The noise impact from stationary sources is evaluated based on operations during a predictable worst-case hour. Stationary noise assessment criteria are generally determined based on the MECP's minimum exclusionary sound level limits, as presented in NPC-300, in comparison to the background sound levels experienced in the area.

Limits are provided for two main types of noise sources:

- Non-impulsive, "continuous" noise sources such as ventilation fans, mechanical equipment, and vehicles while moving within the property boundary of an industry. Continuous noise is measured using 1-hour average sound exposures (Leq (1-hr) values), in dBA.
- Impulsive noise, which is a "banging" type noise characterized by rapid sound level rise time and decay. Impulsive noise is measured using a logarithmic mean (average) level (LLM) of the impulses in a one-hour period, in dBAI.

The guideline requires an assessment at, and provides separate guideline limits for:

- Outdoor points of reception (e.g., back yards, communal outdoor amenity areas).
- Façade points of reception such as the plane of windows on the outdoor façade which connect onto noise sensitive spaces, such as living rooms, dens, eat-in kitchens, dining rooms and bedrooms.

### Acoustical Area Classification

Under the MECP Publication NPC-300 guidelines, noise sensitive receptors are defined using receptor area classifications. The receptor areas are classified as either:

- Class 1 – Urban areas
- Class 2 – Suburban / semi-rural areas
- Class 3 – Rural areas
- Class 4 – Infill areas (Subject to Municipal Planning Approval for New Developments)

Depending on the receptor area classification, different guideline limits apply. Classes 1, 2, and 3 were included in the predecessor guidelines to Publication NPC-300. The Class 4 area, intended to allow for infill and redevelopment, whilst still protecting residences from undue noise.

Tables 5.1 and 5.2 below summarizes the MECP's minimum exclusionary sound level limits for based on the Acoustical Class of the project area, which are expressed in terms of 1-hour equivalent sound levels (1-hour Leq):

**Table 5.1** MECP Minimum Exclusionary Sound Level Limits for Steady Sound

Time of Day	Class 1 Sound Level Limits (dBA)		Class 2 Sound Level Limits (dBA)		Class 3 Sound Level Limits (dBA)		Class 4 Sound Level Limits (dBA)	
	Plane of Window	Outdoor POR	Plane of Window	Outdoor POR	Plane of Window	Outdoor POR	Plane of Window	Outdoor POR
07:00 – 19:00 (Day)	50	50	50	50	45	45	60	55
19:00 – 23:00 (Even)	50	50	50	45	40	40	60	55
23:00 – 07:00 (Night)	45	NA	45	NA	40	NA	55	NA

Class 3 noise limits appropriate for this project have been shaded for reference.

**Table 5.2** Applicable Minimum MECP Sound Level Limits for Steady State Sound

POR ID	POR Description	Sound Level Limits (dBA)		
		Day (7am – 7pm)	Evening (7pm – 11pm)	Night (11pm – 7am)
POR-01	Worst-case plane of window on east façade, 2 <sup>nd</sup> floor (4.5 m AG)	45	40	40
POR-02	Worst-case plane of window on east façade, 2 <sup>nd</sup> floor (4.5 m AG)	45	40	40
POR-03	Worst-case plane of window on south façade, 2 <sup>nd</sup> floor (4.5 m AG)	45	40	40
POR-04	Worst-case plane of window on south façade, 1 <sup>st</sup> floor (1.5 m AG)	45	40	40



POR ID	POR Description	Sound Level Limits (dBA)		
		Day (7am – 7pm)	Evening (7pm – 11pm)	Night (11pm – 7am)
POR-04_O	Outdoor receptor at western property line of POR4 (1.5 m AG)	45	40	NA
POR-05	Worst-case plane of window on north façade, 2 <sup>nd</sup> floor (4.5 m AG)	45	40	40
POR-06	Worst-case plane of window on east façade, 1 <sup>st</sup> floor (1.5 m AG)	45	40	40
POR-06_O	Outdoor receptor at eastern property line of POR6 (1.5 m AG)	45	40	NA

The lowest sound levels generally occur at the ground floor level (1.5 m AG) and increase with height due to increased line of sight exposure to the roadways. GHD has presented the lowest noise limit relative to the worst-case Facility noise impact based on line-of-sight and exposure to the applicable receptor.

## 5.1.2 Sound Level Limits for Emergency Equipment

In accordance with NPC-300 the sound level limits for emergency equipment operating in non-emergency situations, such as testing or maintenance of such equipment, are 5 dB greater than the sound level limits otherwise applicable to stationary sources. The sound level limits for emergency equipment were evaluated separately from the continuous stationary noise sources to reflect this difference.

Emergency equipment noise from maintenance activities is expected to occur approximately once a week for up to an hour during the daytime.

## 5.2 Impact Assessment

### 5.2.1 Steady State Sound Levels

The worst-case assessment of steady-state noise sources at the selected points-of-reception was based on measured sound pressure levels. Cadna A Acoustical Modelling Software (Cadna A), version 2021, was used to model the potential impacts of the significant noise sources. Cadna A calculates sound level emissions based on the ISO 9613-2 standard "Acoustics – Attenuation of Sound during Propagation Outdoors".

A sample calculation for the worst-case POR is provided in Appendix E.

The worst-case cumulative Facility-wide attenuated sound levels estimated at the receptors included attenuation affects due to geometric divergence, atmospheric attenuation, barriers/berms, ground absorption and directivity, as applicable for all significant noise sources. Off-site buildings were input as intervening structures.

CadnaA modelling assumptions used in this AAR included:

- **Noise Sources:** All sources were modelled using the 1/1 octave band data
- **Reflection Order:** A maximum reflection order of 2 was used to evaluate indirect noise impact from one reflecting surface
- **Ground Absorption:** Ground absorption coefficients of 0.25 for asphalt and 1.0 for grass were used to model ground absorption around the Site and adjacent properties
- **Time-Weighted Adjustment:** Time-weighted adjustments for sources that do not operate continuously are summarized in Table C.1
- **Receptor Elevation:** POR receptor heights were modelled appropriately to represent the worst-case elevation as detailed in Section 4
- **Tonality:** A +5 dBA adjustment was applied for tonal sources if applicable

- **Building Surfaces:** The buildings are modelled as reflective surfaces
- **Terrain:** The surrounding area was modelled based on site specific topography
- **Foliage:** No attenuation due to foliage was included to be conservative

The unattenuated steady state sound levels estimated at the PORs is summarized in Table 2a. Since the unattenuated sound levels estimated at some of the PORs do not meet the limits for steady state noise sources, an appropriate noise control program must be specified to mitigate the Facility's significant noise sources to appropriate levels.

The existing and mitigated sound levels estimated at the PORs are summarized in Table 3 and graphically in Figure 3.

## 5.2.2 Emergency Equipment Sound Levels

The worst-case assessment of the emergency equipment operating for maintenance and testing purposes at the selected PORs were estimated based on the emergency generator operating continuously during a daytime hour.

The emergency equipment noise impacts at the PORs are summarized in Table 3.

## 5.2.3 Noise Abatement Action Plan

Due to the complex nature of this Facility, with numerous environmental noise sources near residential dwellings, the potentially significant noise source list may not be exhaustive as presented in this AAR. GHD has identified the existing dominant noise sources, however these dominant noise sources can "mask" other significant noise sources that are uncovered after the dominant noise sources have been abated. GHD expects that follow-up site visit(s) following the installation of noise controls will be necessary to confirm noise control performance and off-site noise reduction and that other significant environmental noise sources may be identified based on this analysis.

## 5.2.4 Proposed Noise Abatement Required for Compliance

The steady-state sound levels (attenuated 1-hour Leqs) estimated at the PORs after installation of noise controls, was based on the following noise abatement plan.

### 5.2.4.1 Existing Physical Noise Abatement Measures

There are currently no onsite noise abatement measures in place on any existing equipment.

### 5.2.4.2 Existing Operational Noise Controls


There are currently no operational or administrative controls undertaken by Escarpment in the operation of the Facility with the expressed purpose of reducing noise impacts.

### 5.2.4.3 Required Physical Noise Abatement Measures

#### ***Development of a New Earthen Berm/Embankment (Berm #1)***

The berm will be located on the eastern side of the Facility to mitigate noise mainly from the RNG upgrading facility in the direction of POR4. The base of the berm must be 95 m long by roughly 18 m wide, reaching to a height of 4.5 m. It must maintain a width of at least 3 m at 4.5 m high. Note that the required width could be lower in the event that the sidewalls of the berm can be constructed at a steeper angle to achieve the necessary height and top width. The

following sketch (not to scale) provides an approximate cross-section profile of the proposed berm. The location footprint and dimensions are shown in Figure 4.



#### 5.2.4.4 Required Operational Noise Controls

GHD's evaluation indicates that the implementation of any operational or administrative controls will not be required to demonstrate compliance during operation of the Facility.

#### 5.2.5 Noise Abatement Implementation Schedule


Escarpment Renewables will implement the noise abatement prior to the commencement of the RNG upgrading facility operations. After this phase of noise abatement is completed, Escarpment Renewables will reassess the Facility's noise levels and update the AAR.

## 6. Conclusions

The Facility-wide noise levels estimated at the points-of-reception after the implementation of the noise abatement program are below the minimum MECP sound level limits, as summarized in Table 3.

GHD recommends that the Facility ensures that any future equipment contribute less than 30 dBA at the applicable point(s)-of-reception.

This is based on accepted standard engineering practices where sound levels that are a minimum of 15 dBA lower than another sound level will not have an impact on the overall noise level. Therefore, based on the MECP exclusionary sound level limit of 45 dBA a source contributing 30 dBA or less would be considered insignificant.



Source: Google Satellite



ACOUSTIC ASSESSMENT REPORT  
 ESCARPMENT RENEWABLES  
 424 SOBYE ROAD, GRIMSBY, ONTARIO  
 NOISE SOURCE LOCATION PLAN

11226032  
 25.11.2021

FIGURE 1



Source: Google Satellite




ACOUSTIC ASSESSMENT REPORT  
 ESCARPMENT RENEWABLES  
 424 SOBYE ROAD, GRIMSBY, ONTARIO

POINT OF RECEPTION LOCATION PLAN

11226032  
 25.11.2021

FIGURE 2



Source: Google Satellite



**Legend**

- > 40 dBA
- > 45 dBA




ACOUSTIC ASSESSMENT REPORT  
 ESCARPMENT RENEWABLES  
 424 SOBYE ROAD, GRIMSBY, ONTARIO

NOISE CONTOUR PLOT (Steady State Mitigated, Night, 1.5 m A.G.)

11226032  
 02.11.2023

FIGURE 3A



Source: Google Satellite



**Legend**

- > 40 dBA
- > 45 dBA




ACOUSTIC ASSESSMENT REPORT  
 ESCARPMENT RENEWABLES  
 424 SOBYE ROAD, GRIMSBY ONTARIO

NOISE CONTOUR PLOT (Steady State Mitigated, Night, 4.5 m A.G.)

11226032  
 02.11.2023

FIGURE 3B



Source: Google Satellite



ACOUSTIC ASSESSMENT REPORT  
 ESCARPMENT RENEWABLES  
 424 SOBYE ROAD, GRIMSBY, ONTARIO

NOISE MITIGATION BERM LOCATION PLAN

11226032  
 02.11.2023

FIGURE 4



Table 1

**Noise Source Summary**  
**Escarpment Renewables**  
**424 Sobie Road, Beamsville, Ontario**

Cadna A ID	Source Description	Sound Power Level <sup>1</sup> (dBA)	Source Characteristics <sup>2</sup>	Source Location <sup>3</sup>	Noise Control Measures <sup>4</sup>	Source Type
<b>Steady State Sources</b>						
FR1	Fork Lift Route	109.5	S	O	U	Line
S01	Ventilation Exhaust	97.3	S	O	U	Point
S03A	Digester Tank Axial Agitator	84.6	S	O	U	Point
S03B	Digester Tank Axial Agitator	84.6	S	O	U	Point
S03C	Digester Tank Axial Agitator	84.6	S	O	U	Point
S03D	Digester Tank Axial Agitator	84.6	S	O	U	Point
S04A	Agitator Motor (High Pitch)	96.4	S	O	U	Point
S04B	Agitator Motor (High Pitch)	96.4	S	O	U	Point
S04C	Agitator Motor (High Pitch)	96.4	S	O	U	Point
S04D	Agitator Motor (High Pitch)	96.4	S	O	U	Point
S05A	Digester Tank Axial Agitator	84.6	S	O	U	Point
S05B	Digester Tank Axial Agitator	84.6	S	O	U	Point
S05C	Digester Tank Axial Agitator	84.6	S	O	U	Point
S05D	Digester Tank Axial Agitator	84.6	S	O	U	Point
S05E	Digester Tank Axial Agitator	84.6	S	O	U	Point
S05F	Digester Tank Axial Agitator	84.6	S	O	U	Point
S05G	Digester Tank Axial Agitator	84.6	S	O	U	Point
S05H	Digester Tank Axial Agitator	84.6	S	O	U	Point
S06A	Side Wall Ventilation Fan	91.0	S	O	U	Point
S06B	Side Wall Ventilation Fan	91.0	S	O	U	Point
S07	CHP Unit	103.2	S	O	U	Point
S08	Side Wall Ventilation Fan	89.4	S	O	U	Point
S09	Truck Idle on Weight Scale	99.5	S	O	U	Point
S10	Flare	99.0	S	O	U	Point
S11	Truck Idle on Weight Scale	99.5	S	O	U	Point
S12A	RNG Facility Compressor Outlet	105.5	S	O	B	Point
S12B	RNG Facility Compressor Outlet	105.5	S	O	B	Point
S13A	Chiller	91.6	S	O	B	Point
S13B	Chiller	91.6	S	O	B	Point
S14A	RNG Compressor Truck Idling	99.5	S	O	U	Point
S14B	RNG Compressor Truck Idling	99.5	S	O	U	Point
S15	RNG Facility Compressor Inlet	108.6	S	O	B	Point
S16A	Organic Processing Building Bay Door (Open)	98.2	S	O	U	Vertical Area
S16B	Organic Processing Building Bay Door (Open)	98.2	S	O	U	Vertical Area
S16C	Organic Processing Building Bay Door (Open)	98.2	S	O	U	Vertical Area
S16D	Organic Processing Building Bay Door (Open)	98.2	S	O	U	Vertical Area
S16E	Organic Processing Building Bay Door (Open)	98.2	S	O	U	Vertical Area
S16F	Organic Processing Building Bay Door (Open)	98.2	S	O	U	Vertical Area
S17A	Pump Building Bay Door (Open)	76.0	S	O	U	Vertical Area
S17B	Pump Building Bay Door (Open)	76.0	S	O	U	Vertical Area
S18	Pump Building Bay Door (Open)	71.4	S	O	U	Vertical Area
S19	Skimmer Building Bay Door (Open)	71.4	S	O	U	Vertical Area
TR1	Truck Route	109.9	S	O	U	Line
<b>Emergency Sources</b>						
Emg_1	Emergency Generator (200 kW)	112.6	S	O	U	Point

## Notes:

<sup>1</sup> Sound Power Level (PWL) in dBA, excludes +5 dBA total penalty if applicable.

<sup>2</sup> Sound characteristics:

- S – Steady
- Q – Quasi-steady impulsive
- I – Impulsive
- B – Buzzing
- T – Tonal
- C – Cyclic

<sup>3</sup> Source location:

- O – Outside of building
- I – Inside of building

<sup>4</sup> Noise control measures:

- S – Silencer, acoustic louvre, muffler
- A – Acoustic lining, plenum
- B – Barrier, berm, screening
- L – Lagging
- E – Acoustic enclosure
- O – Other
- U – Uncontrolled
- AC – Administrative control

Table 2a  
Point of Reception Noise Impact – Unmitigated  
Escarpment Renewables  
424 Sobie Road, Beamsville, Ontario

Cadna A ID	Source Description	Park Road Two-Storey Residential Facade POR1			Sobie Road Two-Storey Residential Facade POR2			Sobie Road Two-Storey Residential Facade POR3			Sobie Road One-Storey Residential Facade POR4			Outdoor Sobie Road One-Storey Residential POR4_O			Mud Street Two-Storey Residential Facade POR5			Park Road One-Storey Residential Facade POR6			Outdoor Park Road One-Storey Residential POR6_O										
		Distance (m)	Partial Sound Levels <sup>1</sup> (dBA)		Night 11pm-7am	Distance (m)	Partial Sound Levels <sup>1</sup> (dBA)		Night 11pm-7am	Distance (m)	Partial Sound Levels <sup>1</sup> (dBA)		Night 11pm-7am	Distance (m)	Partial Sound Levels <sup>1</sup> (dBA)		Night 11pm-7am	Distance (m)	Partial Sound Levels <sup>1</sup> (dBA)		Night 11pm-7am	Distance (m)	Partial Sound Levels <sup>1</sup> (dBA)		Night 11pm-7am								
			Day 7am-7pm	Evening 7pm-11pm			Day 7am-7pm	Evening 7pm-11pm			Day 7am-7pm	Evening 7pm-11pm			Day 7am-7pm	Evening 7pm-11pm			Day 7am-7pm	Evening 7pm-11pm			Day 7am-7pm	Evening 7pm-11pm		Day 7am-7pm	Evening 7pm-11pm						
<b>Steady State Noise Impact</b>																																	
FR1	Fork L/R Route	457	26.4	26.4	26.4	514	24.2	24.2	24.2	578	23.4	23.4	23.4	661	23.7	23.7	23.7	643	24.0	24.0	24.0	846	9.9	9.9	9.9	572	18.9	18.9	18.9	569	18.7	18.7	18.7
S01	Ventilation Exhaust	555	25.5	25.5	25.5	587	26.8	26.8	26.8	640	26.0	26.0	26.0	691	7.5	7.5	7.5	653	8.4	8.4	8.4	940	0.8	0.8	0.8	576	30.0	30.0	30.0	564	30.3	30.3	30.3
S03A	Digester Tank Axial Agitator	544	—	—	—	598	—	—	—	659	—	—	—	679	—	—	—	661	—	—	—	865	—	—	—	626	—	—	—	617	—	—	—
S03B	Digester Tank Axial Agitator	581	—	—	—	612	1.3	1.3	1.3	670	0.9	0.9	0.9	662	—	—	—	644	—	—	—	875	—	—	—	629	4.9	4.9	4.9	619	5.0	5.0	5.0
S03C	Digester Tank Axial Agitator	583	—	—	—	610	2.0	2.0	2.0	667	1.1	1.1	1.1	662	—	—	—	644	—	—	—	887	—	—	—	621	5.0	5.0	5.0	610	4.0	4.0	4.0
S03D	Digester Tank Axial Agitator	553	—	—	—	595	2.0	2.0	2.0	652	3.0	3.0	3.0	675	5.8	5.8	5.8	656	4.2	4.2	4.2	904	—	—	—	602	4.1	4.1	4.1	592	4.2	4.2	4.2
S04A	Agitator Motor (High Pitch)	526	—	—	—	581	—	—	—	642	—	—	—	696	10.7	10.7	10.7	678	10.6	10.6	10.6	868	—	—	—	614	—	—	—	606	—	—	—
S04B	Agitator Motor (High Pitch)	521	5.8	5.8	5.8	578	5.4	5.4	5.4	639	4.6	4.6	4.6	701	11.6	11.6	11.6	683	11.5	11.5	11.5	865	—	—	—	613	1.5	1.5	1.5	605	7.6	7.6	7.6
S04C	Agitator Motor (High Pitch)	516	4.7	4.7	4.7	573	7.9	7.9	7.9	634	2.0	2.0	2.0	706	11.6	11.6	11.6	688	11.4	11.4	11.4	866	—	—	—	609	—	—	—	602	—	—	—
S04D	Agitator Motor (High Pitch)	511	1.8	1.8	1.8	567	6.3	6.3	6.3	629	10.9	10.9	10.9	711	11.3	11.3	11.3	693	11.2	11.2	11.2	868	—	—	—	605	—	—	—	598	—	—	—
S05A	Digester Tank Axial Agitator	587	0.8	0.8	0.8	620	4.8	4.8	4.8	673	3.9	3.9	3.9	648	3.5	3.5	3.5	630	5.9	5.9	5.9	933	—	—	—	605	3.9	3.9	3.9	592	4.1	4.1	4.1
S05B	Digester Tank Axial Agitator	595	0.7	0.7	0.7	630	4.7	4.7	4.7	683	3.8	3.8	3.8	638	3.6	3.6	3.6	620	6.1	6.1	6.1	926	—	—	—	616	3.7	3.7	3.7	602	4.0	4.0	4.0
S05C	Digester Tank Axial Agitator	611	0.4	0.4	0.4	645	4.5	4.5	4.5	697	3.6	3.6	3.6	624	3.8	3.8	3.8	605	3.8	3.8	3.8	930	—	—	—	625	3.5	3.5	3.5	611	3.8	3.8	3.8
S05D	Digester Tank Axial Agitator	616	0.3	0.3	0.3	652	4.4	4.4	4.4	705	3.5	3.5	3.5	617	3.9	3.9	3.9	599	6.4	6.4	6.4	921	—	—	—	635	3.4	3.4	3.4	620	3.6	3.6	3.6
S05E	Digester Tank Axial Agitator	569	1.2	1.2	1.2	604	5.1	5.1	5.1	656	4.2	4.2	4.2	604	3.2	3.2	3.2	647	5.6	5.6	5.6	926	—	—	—	636	4.1	4.1	4.1	594	4.4	4.4	4.4
S05F	Digester Tank Axial Agitator	572	1.1	1.1	1.1	604	5.1	5.1	5.1	656	4.2	4.2	4.2	604	3.2	3.2	3.2	647	5.6	5.6	5.6	940	—	—	—	635	3.4	3.4	3.4	620	3.6	3.6	3.6
S05G	Digester Tank Axial Agitator	613	0.4	0.4	0.4	655	4.3	4.3	4.3	710	3.4	3.4	3.4	615	4.0	4.0	4.0	596	4.3	4.3	4.3	938	—	—	—	649	3.3	3.3	3.3	636	3.5	3.5	3.5
S05H	Digester Tank Axial Agitator	610	0.4	0.4	0.4	650	4.4	4.4	4.4	704	3.5	3.5	3.5	619	3.9	3.9	3.9	601	6.4	6.4	6.4	906	—	—	—	640	3.4	3.4	3.4	627	3.6	3.6	3.6
S06A	Side Wall Ventilation Fan	526	6.0	6.0	6.0	580	2.9	2.9	2.9	641	2.9	2.9	2.9	697	9.9	9.9	9.9	679	9.7	9.7	9.7	869	3.1	3.1	3.1	612	2.0	2.0	2.0	604	2.0	2.0	2.0
S06B	Side Wall Ventilation Fan	527	5.7	5.7	5.7	581	1.9	1.9	1.9	642	1.5	1.5	1.5	696	4.9	4.9	4.9	678	4.9	4.9	4.9	870	0.6	0.6	0.6	612	0.8	0.8	0.8	604	1.0	1.0	1.0
S07	ChP Line	541	31.3	31.3	31.3	573	35.1	35.1	35.1	625	34.1	34.1	34.1	696	19.5	19.5	19.5	677	19.9	19.9	19.9	943	8.6	8.6	8.6	565	32.5	32.5	32.5	553	32.7	32.7	32.7
S08	Side Wall Ventilation Fan	544	8.3	8.3	8.3	596	8.4	8.4	8.4	656	14.6	14.6	14.6	679	11.3	11.3	11.3	661	11.4	11.4	11.4	872	—	—	—	621	6.0	6.0	6.0	612	5.9	5.9	5.9
S09	Truck Idle on Weight Scale	486	23.8	—	—	518	27.4	—	—	573	26.3	—	—	750	5.8	—	—	732	7.1	—	—	950	—	—	—	526	30.5	—	—	517	30.7	—	—
S10	Flare	653	22.4	22.4	22.4	716	26.0	26.0	26.0	774	25.2	25.2	25.2	859	25.3	25.3	25.3	841	25.7	25.7	25.7	1051	6.2	6.2	6.2	719	20.8	20.8	20.8	706	23.0	23.0	23.0
S11	Truck Idle on Weight Scale	678	22.5	—	—	721	13.2	—	—	775	11.0	—	—	948	28.5	—	—	930	28.9	—	—	1191	4.3	—	—	704	12.1	—	—	689	12.3	—	—
S12A	RNG Facility Compressor Outlet	654	16.7	16.7	16.7	703	19.8	19.8	19.8	760	21.4	21.4	21.4	869	35.9	35.9	35.9	851	36.3	36.3	36.3	1051	12.1	12.1	12.1	703	16.2	16.2	16.2	689	16.5	16.5	16.5
S12B	RNG Facility Compressor Outlet	658	17.5	17.5	17.5	708	21.0	21.0	21.0	765	22.8	22.8	22.8	865	35.9	35.9	35.9	846	36.3	36.3	36.3	1051	12.0	12.0	12.0	707	16.9	16.9	16.9	693	17.3	17.3	17.3
S13A	Chiller	688	12.3	12.3	12.3	714	18.1	18.1	18.1	769	14.0	14.0	14.0	857	23.3	23.3	23.3	839	23.7	23.7	23.7	1051	3.5	3.5	3.5	704	11.3	11.3	11.3	689	11.3	11.3	11.3
S13B	Chiller	689	18.1	18.1	18.1	713	15.7	15.7	15.7	768	12.5	12.5	12.5	857	23.3	23.3	23.3	839	23.7	23.7	23.7	1051	3.4	3.4	3.4	700	10.9	10.9	10.9	686	11.1	11.1	11.1
S14A	RNG Compressor Truck Idling	659	15.0	15.0	15.0	711	14.5	14.5	14.5	769	14.4	14.4	14.4	864	31.2	31.2	31.2	846	31.6	31.6	31.6	1051	7.8	7.8	7.8	713	13.6	13.6	13.6	700	13.6	13.6	13.6
S14B	RNG Compressor Truck Idling	651	13.5	13.5	13.5	703	12.5	12.5	12.5	761	12.0	12.0	12.0	853	31.2	31.2	31.2	833	31.6	31.6	31.6	1051	8.2	8.2	8.2	707	12.2	12.2	12.2	694	13.0	13.0	13.0
S15	RNG Facility Compressor Inlet	656	16.9	16.9	16.9	696	19.6	19.6	19.6	750	18.5	18.5	18.5	853	39.4	39.4	39.4	834	41.5	41.5	41.5	1000	14.8	14.8	14.8	680	15.8	15.8	15.8	665	16.2	16.2	16.2
S16A	Organic Processing Building Bay Door (Open)	452	26.0	26.0	26.0	512	27.0	27.0	27.0	576	26.1	26.1	26.1	771	5.0	5.0	5.0	753	5.2	5.2	5.2	976	2.3	2.3	2.3	570	25.5	25.5	25.5	567	25.6	25.6	25.6
S16B	Organic Processing Building Bay Door (Open)	453	26.1	26.1	26.1	511	27.0	27.0	27.0	574	26.2	26.2	26.2	770	4.2	4.2	4.2	752	4.4	4.4	4.4	983	2.2	2.2	2.2	565	25.6	25.6	25.6	561	25.7	25.7	25.7
S16C	Organic Processing Building Bay Door (Open)	456	26.2	26.2	26.2	508	27.1	27.1	27.1	570	26.2	26.2	26.2	768	4.4	4.4	4.4	750	4.6	4.6	4.6	989	2.1	2.1	2.1	554	25.8	25.8	25.8	549	27.2	27.2	27.2
S16D	Organic Processing Building Bay Door (Open)	458	26.2	26.2	26.2	507	27.2	27.2	27.2	568	26.3	26.3	26.3	767	4.6	4.6	4.6	749	4.8	4.8	4.8	905	2.0	2.0	2.0	549	26.4	26.4	26.4	543	27.6	27.6	27.6
S16E	Organic Processing Building Bay Door (Open)	459	26.2	26.2	26.2																												

Table 2b  
Point of Reception Noise Impact – Mitigated  
Escargot Renewables  
424 Sobie Road, Beamsville, Ontario

Cadna A ID	Source Description	Park Road Two-Storey Residential Facade									Sobie Road Two-Storey Residential Facade									Sobie Road One-Storey Residential Facade									Outdoor Sobie Road One-Storey Residential									Mud Street Two-Storey Residential Facade									Park Road One-Storey Residential Facade									Outdoor Park Road One-Storey Residential								
		POB1			POB2			POB3			POB4			POB5			POB6			POB7			POB8			POB9			POB10			POB11			POB12			POB13			POB14			POB15																				
		Distance (m)	Day 7am-7pm	Evening 7pm-11pm	Night 11pm-7am	Distance (m)	Day 7am-7pm	Evening 7pm-11pm	Night 11pm-7am	Distance (m)	Day 7am-7pm	Evening 7pm-11pm	Night 11pm-7am	Distance (m)	Day 7am-7pm	Evening 7pm-11pm	Night 11pm-7am	Distance (m)	Day 7am-7pm	Evening 7pm-11pm	Night 11pm-7am	Distance (m)	Day 7am-7pm	Evening 7pm-11pm	Night 11pm-7am	Distance (m)	Day 7am-7pm	Evening 7pm-11pm	Night 11pm-7am	Distance (m)	Day 7am-7pm	Evening 7pm-11pm	Night 11pm-7am	Distance (m)	Day 7am-7pm	Evening 7pm-11pm	Night 11pm-7am																											
<b>Steady State Noise Impact</b>																																																																
FRT1	Fork Lift Route	457	26.4	26.4	26.4	514	24.2	24.2	24.2	578	23.4	23.4	23.4	661	21.9	21.9	21.9	643	22.0	22.0	22.0	846	9.9	9.9	9.9	572	18.9	18.9	18.9	569	18.7	18.7	18.7	569	18.7	18.7	18.7																											
S01	Ventilation Exhaust	555	25.5	25.5	25.5	587	26.8	26.8	26.8	640	26.0	26.0	26.0	681	4.7	4.7	4.7	663	7.9	7.9	7.9	840	0.8	0.8	0.8	576	30.0	30.0	30.0	564	30.3	30.3	30.3	564	30.3	30.3	30.3																											
S03A	Digester Tank Axial Agitator	544	—	—	—	598	—	—	—	659	—	—	—	679	—	—	—	665	—	—	—	865	—	—	—	628	—	—	—	617	—	—	—	617	—	—	—																											
S03B	Digester Tank Axial Agitator	561	—	—	—	612	1.3	1.3	1.3	670	0.9	0.9	0.9	662	—	—	—	644	—	—	—	875	—	—	—	629	4.9	4.9	4.9	619	5.0	5.0	5.0	619	5.0	5.0	5.0																											
S03C	Digester Tank Axial Agitator	563	—	—	—	610	2.0	2.0	2.0	667	1.1	1.1	1.1	662	—	—	—	644	—	—	—	887	—	—	—	621	5.0	5.0	5.0	610	4.0	4.0	4.0	610	4.0	4.0	4.0																											
S03D	Digester Tank Axial Agitator	553	—	—	—	595	2.0	2.0	2.0	652	3.0	3.0	3.0	675	0.2	0.2	0.2	656	—	—	—	904	—	—	—	602	4.1	4.1	4.1	592	4.2	4.2	4.2	592	4.2	4.2	4.2																											
S04A	Agitator Motor (High Pitch)	526	—	—	—	581	—	—	—	642	—	—	—	696	9.2	9.2	9.2	678	9.2	9.2	9.2	868	—	—	—	614	—	—	—	606	—	—	—	606	—	—	—																											
S04B	Agitator Motor (High Pitch)	521	5.8	5.8	5.8	578	5.4	5.4	5.4	639	4.6	4.6	4.6	701	9.2	9.2	9.2	683	9.2	9.2	9.2	865	—	—	—	613	1.5	1.5	1.5	605	7.6	7.6	7.6	605	7.6	7.6	7.6																											
S04C	Agitator Motor (High Pitch)	516	4.7	4.7	4.7	573	7.9	7.9	7.9	634	2.0	2.0	2.0	706	9.3	9.3	9.3	688	9.3	9.3	9.3	866	—	—	—	609	—	—	—	602	—	—	—	602	—	—	—																											
S04D	Agitator Motor (High Pitch)	511	1.8	1.8	1.8	567	6.3	6.3	6.3	629	10.9	10.9	10.9	711	9.3	9.3	9.3	693	9.4	9.4	9.4	868	—	—	—	605	—	—	—	598	—	—	—	598	—	—	—																											
S05A	Digester Tank Axial Agitator	587	0.8	0.8	0.8	620	4.8	4.8	4.8	673	3.9	3.9	3.9	648	3.5	3.5	3.5	630	5.9	5.9	5.9	830	—	—	—	605	3.9	3.9	3.9	592	4.1	4.1	4.1	592	4.1	4.1	4.1																											
S05B	Digester Tank Axial Agitator	595	0.7	0.7	0.7	630	4.7	4.7	4.7	683	3.8	3.8	3.8	638	3.6	3.6	3.6	600	6.1	6.1	6.1	826	—	—	—	616	3.7	3.7	3.7	602	4.0	4.0	4.0	602	4.0	4.0	4.0																											
S05C	Digester Tank Axial Agitator	611	0.4	0.4	0.4	645	4.5	4.5	4.5	697	3.6	3.6	3.6	624	3.8	3.8	3.8	605	6.3	6.3	6.3	830	—	—	—	625	3.5	3.5	3.5	611	3.8	3.8	3.8	611	3.8	3.8	3.8																											
S05D	Digester Tank Axial Agitator	616	0.3	0.3	0.3	652	4.4	4.4	4.4	705	3.5	3.5	3.5	617	3.9	3.9	3.9	599	6.4	6.4	6.4	821	—	—	—	636	3.4	3.4	3.4	620	3.6	3.6	3.6	620	3.6	3.6	3.6																											
S05E	Digester Tank Axial Agitator	569	1.2	1.2	1.2	604	5.1	5.1	5.1	658	4.2	4.2	4.2	664	3.2	3.2	3.2	646	5.6	5.6	5.6	828	—	—	—	606	4.1	4.1	4.1	584	4.4	4.4	4.4	584	4.4	4.4	4.4																											
S05F	Digester Tank Axial Agitator	572	1.1	1.1	1.1	604	5.1	5.1	5.1	656	4.2	4.2	4.2	665	3.2	3.2	3.2	647	5.6	5.6	5.6	840	—	—	—	609	4.2	4.2	4.2	576	4.5	4.5	4.5	576	4.5	4.5	4.5																											
S05G	Digester Tank Axial Agitator	613	0.4	0.4	0.4	655	4.3	4.3	4.3	710	3.4	3.4	3.4	615	4.0	4.0	4.0	596	4.3	4.3	4.3	808	—	—	—	649	3.3	3.3	3.3	606	3.5	3.5	3.5	606	3.5	3.5	3.5																											
S05H	Digester Tank Axial Agitator	610	0.4	0.4	0.4	650	4.4	4.4	4.4	704	3.5	3.5	3.5	619	3.9	3.9	3.9	601	6.4	6.4	6.4	808	—	—	—	640	3.4	3.4	3.4	627	3.6	3.6	3.6	627	3.6	3.6	3.6																											
S06A	Side Wall Ventilation Fan	526	6.0	6.0	6.0	580	2.9	2.9	2.9	641	2.9	2.9	2.9	697	8.3	8.3	8.3	679	8.2	8.2	8.2	869	3.1	3.1	3.1	612	1.9	1.9	1.9	604	2.0	2.0	2.0	604	2.0	2.0	2.0																											
S06B	Side Wall Ventilation Fan	527	5.7	5.7	5.7	581	1.9	1.9	1.9	642	1.5	1.5	1.5	696	1.4	1.4	1.4	678	1.5	1.5	1.5	870	0.6	0.6	0.6	612	0.8	0.8	0.8	604	1.0	1.0	1.0	604	1.0	1.0	1.0																											
S07	ChP Unit	541	31.3	31.3	31.3	573	35.1	35.1	35.1	625	34.1	34.1	34.1	696	18.0	18.0	18.0	677	19.1	19.1	19.1	943	8.6	8.6	8.6	565	32.5	32.5	32.5	563	32.7	32.7	32.7	563	32.7	32.7	32.7																											
S08	Side Wall Ventilation Fan	544	8.3	8.3	8.3	596	8.4	8.4	8.4	656	14.6	14.6	14.6	679	10.2	10.2	10.2	681	10.3	10.3	10.3	872	—	—	—	621	6.0	6.0	6.0	612	5.9	5.9	5.9	612	5.9	5.9	5.9																											
S09	Truck Idle on Weight Scale	486	23.8	—	—	518	27.4	—	—	573	26.3	—	—	750	4.8	—	—	732	6.8	—	—	950	—	—	—	526	30.5	—	—	517	30.7	—	—	517	30.7	—	—																											
S10	Flare	663	22.4	22.4	22.4	716	26.0	26.0	26.0	774	25.2	25.2	25.2	679	25.3	25.3	25.3	541	25.7	25.7	25.7	851	6.2	6.2	6.2	719	20.8	20.8	20.8	706	23.0	23.0	23.0	706	23.0	23.0	23.0																											
S11	Truck Idle on Weight Scale	678	22.5	—	—	721	13.2	—	—	775	11.0	—	—	548	22.0	—	—	530	22.2	—	—	891	4.3	—	—	704	12.1	—	—	689	12.3	—	—	689	12.3	—	—																											
S12A	RNG Facility Compressor Outlet	654	16.7	16.7	16.7	703	19.8	19.8	19.8	760	21.4	21.4	21.4	569	30.6	30.6	30.6	551	30.8	30.8	30.8	863	12.1	12.1	12.1	703	16.2	16.2	16.2	689	16.5	16.5	16.5	689	16.5	16.5	16.5																											
S12B	RNG Facility Compressor Outlet	658	17.5	17.5	17.5	708	21.0	21.0	21.0	765	22.8	22.8	22.8	565	30.4	30.4	30.4	546	30.6	30.6	30.6	862	12.0	12.0	12.0	707	16.9	16.9	16.9	693	17.3	17.3	17.3	693	17.3	17.3	17.3																											
S13A	Chiller	668	12.3	12.3	12.3	714	18.1	18.1	18.1	769	14.0	14.0	14.0	557	19.4	19.4	19.4	539	19.7	19.7	19.7	874	3.5	3.5	3.5	713	11.3	11.3	11.3	689	11.3	11.3	11.3	689	11.3	11.3	11.3																											
S13B	Chiller	669	18.1	18.1	18.1	713	15.7	15.7	15.7	768	13.5	13.5	13.5	557	19.3	19.3	19.3	538	19.6	19.6	19.6	865	3.4	3.4	3.4	700	10.9	10.9	10.9	686	11.1	11.1	11.1	686	11.1	11.1	11.1																											
S14A	RNG Compressor Truck Idling	659	15.0	15.0	15.0	711	14.5	14.5	14.5	769	14.4	14.4	14.4	564	25.6	25.6	25.6	546	25.8	25.8	25.8	858	7.8	7.8	7.8	704	13.6	13.6	13.6	700	13.6	13.6	13.6	700	13.6	13.6	13.6																											
S14B	RNG Compressor Truck Idling	651	13.5	13.5	13.5	703	12.5	12.5	12.5	761	12.0	12.0	12.0	572	26.0	26.0	26.0	553	26.2	26.2	26.2	862	8.2	8.2	8.2	707	12.2	12.2	12.2	684	13.0	13.0	13.0	684	13.0	13.0	13.0																											
S15	RNG Facility Compressor Inlet	656	16.9	16.9	16.9	696	16.6	16.6	16.6	750	18.5	18.5	18.5	573	32.9	32.9	32.9	554	34.5	34.5	34.5	900	14.8	14.8	14.8	680	15.8	15.8	15.8	665	16.2	16.2	16.2	665	16.2	16.2	16.2																											
S16A	Organic Processing Building Bay Door (Open)	452	26.0	26.0	26.0	512	27.0	27.0	27.0	576	26.1	26.1	26.1	771	4.7	4.7	4																																															

**Table 3**  
**Acoustic Assessment Summary**  
**Escarpment Renewables**  
**424 Sobie Road, Beamsville, Ontario**

Point of Reception ID	Point of Reception Description	Time of Day	Unmitigated Sound Levels (L <sub>EQ</sub> ) (dBA)	Mitigated Sound Levels (L <sub>EQ</sub> ) (dBA)	Performance Limit <sup>1</sup> (L <sub>EQ</sub> ) (dBA)	Compliance with Performance Limit (Yes/No)	Class Number	Verified by Acoustic Audit
<b>Steady State Noise Impact</b>								
POR1	Park Road Two-Storey Residential Facade	07:00–19:00	39	39	45	Yes	Class 3	No
		19:00–23:00	38	38	40	Yes	Class 3	No
		23:00–07:00	38	38	40	Yes	Class 3	No
POR2	Sobie Road Two-Storey Residential Facade	07:00–19:00	40	40	45	Yes	Class 3	No
		19:00–23:00	39	39	40	Yes	Class 3	No
		23:00–07:00	39	39	40	Yes	Class 3	No
POR3	Sobie Road Two-Storey Residential Facade	07:00–19:00	39	39	45	Yes	Class 3	No
		19:00–23:00	38	38	40	Yes	Class 3	No
		23:00–07:00	38	38	40	Yes	Class 3	No
POR4	Sobie Road One-Storey Residential Facade	07:00–19:00	44	39	45	Yes	Class 3	No
		19:00–23:00	43	38	40	Yes	Class 3	No
		23:00–07:00	43	38	40	Yes	Class 3	No
POR4_O	Outdoor Sobie Road One-Storey Residential	07:00–19:00	45	39	45	Yes	Class 3	No
		19:00–23:00	44	39	40	Yes	Class 3	No
POR5	Mud Street Two-Storey Residential Facade	07:00–19:00	22	22	45	Yes	Class 3	No
		19:00–23:00	21	21	40	Yes	Class 3	No
		23:00–07:00	21	21	40	Yes	Class 3	No
POR6	Park Road One-Storey Residential Facade	07:00–19:00	39	39	45	Yes	Class 3	No
		19:00–23:00	38	38	40	Yes	Class 3	No
		23:00–07:00	38	38	40	Yes	Class 3	No
POR6_O	Outdoor Park Road One-Storey Residential	07:00–19:00	40	40	45	Yes	Class 3	No
		19:00–23:00	39	39	40	Yes	Class 3	No
<b>Emergency Noise Impact</b>								
POR1	Park Road Two-Storey Residential Facade	07:00–19:00	42	42	50	Yes	Class 3	No
POR2	Sobie Road Two-Storey Residential Facade	07:00–19:00	42	42	50	Yes	Class 3	No
POR3	Sobie Road Two-Storey Residential Facade	07:00–19:00	43	43	50	Yes	Class 3	No
POR4	Sobie Road One-Storey Residential Facade	07:00–19:00	34	34	50	Yes	Class 3	No
POR4_O	Outdoor Sobie Road One-Storey Residential	07:00–19:00	34	34	50	Yes	Class 3	No
POR5	Mud Street Two-Storey Residential Facade	07:00–19:00	16	16	50	Yes	Class 3	No
POR6	Park Road One-Storey Residential Facade	07:00–19:00	43	43	50	Yes	Class 3	No
POR6_O	Outdoor Park Road One-Storey Residential	07:00–19:00	43	43	50	Yes	Class 3	No


Note:

<sup>1</sup> Minimum MECP sound level limits as defined in NPC-300.

# Appendices

# **Appendix A**

## **Land Use Zoning Plan**



**Legend**

- Site Boundary
- Town of Grimsby Zoning By-law (By-law 14-45)**
- Agricultural
- Specialty Crop
- Township of West Lincoln Zoning By-Law No. 2017-70**
- Agricultural
- Environmental Conservation
- Environmental Protection
- Waste Management Facility Assessment Area

<p>Paper Size ANSI B</p> <p>0 90 180 270 360</p> <p>Meters</p> <p>Map Projection: Transverse Mercator Horizontal Datum: North American 1983 Grid: NAD 1983 UTM Zone 17N</p>			<p>ESCAPMENT RENEWABLES 424 SOBIE ROAD, BEAMSVILLE, ONTARIO ACOUSTIC ASSESSMENT REPORT</p>	<p>Project No. 11226032 Revision No. - Date Nov 24, 2021</p>
<p><b>LAND USE ZONING PLAN</b></p>			<p><b>FIGURE A.1</b></p>	

Q:\GIS\PROJECTS\11226032\layouts\202111\_AAR\11226032\_202111\_AAR\_GIS001.mxd  
Print date: 24 Nov 2021 - 10:13  
Data source: Township of West Lincoln Zoning By-Law No. 2017-70, Town of Grimsby Zoning By-law (By-law 14-45), Google Earth Imagery, 07/08/2018

# **Appendix B**

## **Summary of Insignificant Noise Sources**



**Table B.1**

**Insignificant Noise Source Summary  
Escarpment Renewables  
424 Sobie Road, Beamsville, Ontario**

<b>Source ID</b>	<b>Source Description</b>	<b>Comments</b>
S20	Submersive Agitators on Storage Tanks	Observed to be inaudible
S21	Rooftop HVAC Units	Estimated to be < 25 dBA at the nearest POR
S22	Pumps in basement of pastuerization building	

# **Appendix C**

## **Noise Source Sound Level Summary**

**Table C.1**  
**Noise Source Sound Level Summary**  
**Escarpment Renewables**  
**424 Sobie Road, Beamsville, Ontario**

Cadna A ID	Noise Source Description		1/1 Octave Band Data								Unadjusted Total Sound Power Level	Tonal Penalty Assessment	Height Absolute	Operating Time Day/Even/Night	Vehicle Volumes Day/Even/Night	Speed Reference/Comments		
			32	63	125	250	500	1000	2000	4000							8000	
			PWL (dB)	A-weighted correction	PWL (dBA)	PWL (dB)	A-weighted correction	PWL (dBA)	PWL (dB)	A-weighted correction							PWL (dBA)	PWL (dB)
FR1	Fork Lift Route	PWL (dB)	31.0	117.0	112.0	105.0	107.0	104.0	103.0	100.0	91.0	119.0				Referenced from UK Department for Environment, Food and Rural Affairs (Defra) Noise Database for Construction Noise document 15 Transport Truck Route - 26ton 235kw - DEFRA Table 1(c)#16		
		A-weighted correction	-39.4	-26.2	-16.1	-8.6	-3.2	0.0	1.2	1.0	-1.1							
		PWL (dBA)	—	90.8	95.9	96.4	103.8	104.0	104.2	101.0	89.9	<b>109.9</b>	No	0	193.0		—	
S01	Ventilation Exhaust	PWL (dB)	100.6	94.8	101.2	99.0	92.9	93.2	87.1	81.6	74.9	106.1						
		A-weighted correction	-39.4	-26.2	-16.1	-8.6	-3.2	0.0	1.2	1.0	-1.1							
		PWL (dBA)	61.2	68.6	85.1	90.4	89.7	93.2	88.3	82.6	73.8	<b>97.3</b>	No	0	192.6	60/60/60	—	— GHD Site Measurement
S03A	Digester Tank Axial Agitator	PWL (dB)	85.7	83.0	79.0	77.3	72.7	80.0	73.0	80.6	64.2	89.8						
		A-weighted correction	-39.4	-26.2	-16.1	-8.6	-3.2	0.0	1.2	1.0	-1.1							
		PWL (dBA)	46.3	56.8	62.9	68.7	69.5	80.0	74.2	81.6	63.1	<b>84.6</b>	No	0	193.0	10/10/10	—	— GHD Site Measurement
S03B	Digester Tank Axial Agitator	PWL (dB)	85.7	83.0	79.0	77.3	72.7	80.0	73.0	80.6	64.2	89.8						
		A-weighted correction	-39.4	-26.2	-16.1	-8.6	-3.2	0.0	1.2	1.0	-1.1							
		PWL (dBA)	46.3	56.8	62.9	68.7	69.5	80.0	74.2	81.6	63.1	<b>84.6</b>	No	0	193.0	10/10/10	—	— GHD Site Measurement
S03C	Digester Tank Axial Agitator	PWL (dB)	85.7	83.0	79.0	77.3	72.7	80.0	73.0	80.6	64.2	89.8						
		A-weighted correction	-39.4	-26.2	-16.1	-8.6	-3.2	0.0	1.2	1.0	-1.1							
		PWL (dBA)	46.3	56.8	62.9	68.7	69.5	80.0	74.2	81.6	63.1	<b>84.6</b>	No	0	193.0	10/10/10	—	— GHD Site Measurement
S03D	Digester Tank Axial Agitator	PWL (dB)	85.7	83.0	79.0	77.3	72.7	80.0	73.0	80.6	64.2	89.8						
		A-weighted correction	-39.4	-26.2	-16.1	-8.6	-3.2	0.0	1.2	1.0	-1.1							
		PWL (dBA)	46.3	56.8	62.9	68.7	69.5	80.0	74.2	81.6	63.1	<b>84.6</b>	No	0	193.0	10/10/10	—	— GHD Site Measurement
S04A	Agitator Motor (High Pitch)	PWL (dB)	78.2	75.9	72.6	78.6	87.3	91.5	87.0	92.0	69.4	96.3						
		A-weighted correction	-39.4	-26.2	-16.1	-8.6	-3.2	0.0	1.2	1.0	-1.1							
		PWL (dBA)	38.8	49.7	56.5	70.0	84.1	91.5	88.2	93.0	68.3	<b>96.4</b>	No	0	192.4	15/15/15	—	— GHD Site Measurement
S04B	Agitator Motor (High Pitch)	PWL (dB)	78.2	75.9	72.6	78.6	87.3	91.5	87.0	92.0	69.4	96.3						
		A-weighted correction	-39.4	-26.2	-16.1	-8.6	-3.2	0.0	1.2	1.0	-1.1							
		PWL (dBA)	38.8	49.7	56.5	70.0	84.1	91.5	88.2	93.0	68.3	<b>96.4</b>	No	0	192.4	15/15/15	—	— GHD Site Measurement
S04C	Agitator Motor (High Pitch)	PWL (dB)	78.2	75.9	72.6	78.6	87.3	91.5	87.0	92.0	69.4	96.3						
		A-weighted correction	-39.4	-26.2	-16.1	-8.6	-3.2	0.0	1.2	1.0	-1.1							
		PWL (dBA)	38.8	49.7	56.5	70.0	84.1	91.5	88.2	93.0	68.3	<b>96.4</b>	No	0	192.4	15/15/15	—	— GHD Site Measurement
S04D	Agitator Motor (High Pitch)	PWL (dB)	78.2	75.9	72.6	78.6	87.3	91.5	87.0	92.0	69.4	96.3						
		A-weighted correction	-39.4	-26.2	-16.1	-8.6	-3.2	0.0	1.2	1.0	-1.1							
		PWL (dBA)	38.8	49.7	56.5	70.0	84.1	91.5	88.2	93.0	68.3	<b>96.4</b>	No	0	192.4	15/15/15	—	— GHD Site Measurement
S05A	Digester Tank Axial Agitator	PWL (dB)	85.7	83.0	79.0	77.3	72.7	80.0	73.0	80.6	64.2	89.8						
		A-weighted correction	-39.4	-26.2	-16.1	-8.6	-3.2	0.0	1.2	1.0	-1.1							
		PWL (dBA)	46.3	56.8	62.9	68.7	69.5	80.0	74.2	81.6	63.1	<b>84.6</b>	No	0	207.2	10/10/10	—	— GHD Site Measurement
S05B	Digester Tank Axial Agitator	PWL (dB)	85.7	83.0	79.0	77.3	72.7	80.0	73.0	80.6	64.2	89.8						
		A-weighted correction	-39.4	-26.2	-16.1	-8.6	-3.2	0.0	1.2	1.0	-1.1							
		PWL (dBA)	46.3	56.8	62.9	68.7	69.5	80.0	74.2	81.6	63.1	<b>84.6</b>	No	0	207.1	10/10/10	—	— GHD Site Measurement
S05C	Digester Tank Axial Agitator	PWL (dB)	85.7	83.0	79.0	77.3	72.7	80.0	73.0	80.6	64.2	89.8						
		A-weighted correction	-39.4	-26.2	-16.1	-8.6	-3.2	0.0	1.2	1.0	-1.1							
		PWL (dBA)	46.3	56.8	62.9	68.7	69.5	80.0	74.2	81.6	63.1	<b>84.6</b>	No	0	207.1	10/10/10	—	— GHD Site Measurement
S05D	Digester Tank Axial Agitator	PWL (dB)	85.7	83.0	79.0	77.3	72.7	80.0	73.0	80.6	64.2	89.8						
		A-weighted correction	-39.4	-26.2	-16.1	-8.6	-3.2	0.0	1.2	1.0	-1.1							
		PWL (dBA)	46.3	56.8	62.9	68.7	69.5	80.0	74.2	81.6	63.1	<b>84.6</b>	No	0	207.0	10/10/10	—	— GHD Site Measurement
S05E	Digester Tank Axial Agitator	PWL (dB)	85.7	83.0	79.0	77.3	72.7	80.0	73.0	80.6	64.2	89.8						
		A-weighted correction	-39.4	-26.2	-16.1	-8.6	-3.2	0.0	1.2	1.0	-1.1							
		PWL (dBA)	46.3	56.8	62.9	68.7	69.5	80.0	74.2	81.6	63.1	<b>84.6</b>	No	0	207.1	10/10/10	—	— GHD Site Measurement
S05F	Digester Tank Axial Agitator	PWL (dB)	85.7	83.0	79.0	77.3	72.7	80.0	73.0	80.6	64.2	89.8						
		A-weighted correction	-39.4	-26.2	-16.1	-8.6	-3.2	0.0	1.2	1.0	-1.1							
		PWL (dBA)	46.3	56.8	62.9	68.7	69.5	80.0	74.2	81.6	63.1	<b>84.6</b>	No	0	207.2	10/10/10	—	— GHD Site Measurement
S05G	Digester Tank Axial Agitator	PWL (dB)	85.7	83.0	79.0	77.3	72.7	80.0	73.0	80.6	64.2	89.8						
		A-weighted correction	-39.4	-26.2	-16.1	-8.6	-3.2	0.0	1.2	1.0	-1.1							
		PWL (dBA)	46.3	56.8	62.9	68.7	69.5	80.0	74.2	81.6	63.1	<b>84.6</b>	No	0	207.0	10/10/10	—	— GHD Site Measurement
S05H	Digester Tank Axial Agitator	PWL (dB)	85.7	83.0	79.0	77.3	72.7	80.0	73.0	80.6	64.2	89.8						
		A-weighted correction	-39.4	-26.2	-16.1	-8.6	-3.2	0.0	1.2	1.0	-1.1							
		PWL (dBA)	46.3	56.8	62.9	68.7	69.5	80.0	74.2	81.6	63.1	<b>84.6</b>	No	0	207.0	10/10/10	—	— GHD Site Measurement
S06A	Side Wall Ventilation Fan	PWL (dB)	100.6	82.9	81.6	94.4	88.7	85.0	80.2	76.9	67.0	102.0						
		A-weighted correction	-39.4	-26.2	-16.1	-8.6	-3.2	0.0	1.2	1.0	-1.1							
		PWL (dBA)	61.2	56.7	65.5	85.8	85.5	85.0	81.4	77.9	65.9	<b>91.0</b>	No	0	193.9	60/60/60	—	— GHD Site Measurement
S06B	Side Wall Ventilation Fan	PWL (dB)	100.6	82.9	81.6	94.4	88.7	85.0	80.2	76.9	67.0	102.0						
		A-weighted correction	-39.4	-26.2	-16.1	-8.6	-3.2	0.0	1.2	1.0	-1.1							
		PWL (dBA)	61.2	56.7	65.5	85.8	85.5	85.0	81.4	77.9	65.9	<b>91.0</b>	No	0	193.9	60/60/60	—	— GHD Site Measurement
S07	CHP Unit	PWL (dB)	107.6	102.6	105.8	106.5	96.3	96.8	95.3	91.9	86.5	112.4						
		A-weighted correction	-39.4	-26.2	-16.1	-8.6	-3.2	0.0	1.2	1.0	-1.1							
		PWL (dBA)	68.2	76.4	89.7	97.9	93.1	96.8	96.5	92.9	85.4	<b>103.2</b>	No	0	198.1	60/60/60	—	— GHD Site Measurement
S08	Side Wall Ventilation Fan	PWL (dB)	83.7	87.5	89.5	90.6	86.4	84.5	80.2	75.8	67.7	95.7						
		A-weighted correction	-39.4	-26.2	-16.1	-8.6	-3.2	0.0	1.2	1.0	-1.1							
		PWL (dBA)	44.3	61.3	73.4	82.0	83.2	84.5	81.4	76.8	66.6	<b>89.4</b>	No	0	194.0	60/60/60	—	— GHD Site Measurement
S09	Truck Idle on Weight Scale	PWL (dB)	92.6	91.7	91.6	91.9	95.6	96.3	91.8	86.4	80.4	102.1						
		A-weighted correction	-39.4	-26.2	-16.1	-8.6	-3.2	0.0	1.2	1.0	-1.1							
		PWL (dBA)	53.2	65.5	75.5	83.3	92.4	96.3	93.0	87.4	79.3	<b>99.5</b>	No	0	193.0	30/0/0	—	— GHD Reference Spectra
S10	Flare	PWL (dB)	108.4	104.4	103.4	99.8	98.0	92.6	87.8	83.4	76.2	111.4						
		A-weighted correction	-39.4	-26.2	-16.1	-8.6	-3.2	0.0	1.2	1.0	-1.1							
		PWL (dBA)	69.0	78.2	87.3	91.2	94.8	92.6	89.0	84.4	75.1	<b>99.0</b>	No	0	207.0	30/30/30	—	— GHD Site Measurement

**Table C.1**  
**Noise Source Sound Level Summary**  
**Escarpment Renewables**  
**424 Sobie Road, Beamsville, Ontario**

Cadna A ID	Noise Source Description		1/1 Octave Band Data								Unadjusted Total Sound Power Level	Tonal Penalty Assessment	Height Absolute	Operating Time Day/Eve/Night	Vehicle Volumes Day/Eve/Night	Speed Reference/Comments		
			32	63	125	250	500	1000	2000	4000							8000	
S11	Truck Idle on Weight Scale	PWL (dB)	92.6	91.7	91.6	91.9	95.6	96.3	91.8	86.4	80.4	102.1						
		A-weighted correction	-39.4	-26.2	-16.1	-8.6	-3.2	0.0	1.2	1.0	-1.1							
		PWL (dBA)	53.2	65.5	75.5	83.3	92.4	96.3	93.0	87.4	79.3							
S12A	RNG Facility Compressor Outlet	PWL (dB)	99.9	94.9	94.9	93.9	96.9	99.9	99.9	97.9	94.9	107.2	No	0	193.0	30/0/0	—	— GHD Reference Spectra
		A-weighted correction	-39.4	-26.2	-16.1	-8.6	-3.2	0.0	1.2	1.0	-1.1							
		PWL (dBA)	60.5	68.7	78.8	85.3	93.7	99.9	101.1	98.9	93.8							
S12B	RNG Facility Compressor Outlet	PWL (dB)	99.9	94.9	94.9	93.9	96.9	99.9	99.9	97.9	94.9	107.2	No	0	194.4	60/60/60	—	— Manufacturer's Specification
		A-weighted correction	-39.4	-26.2	-16.1	-8.6	-3.2	0.0	1.2	1.0	-1.1							
		PWL (dBA)	60.5	68.7	78.8	85.3	93.7	99.9	101.1	98.9	93.8							
S13A	Chiller	PWL (dB)	85.6	102.7	97.7	93.0	88.9	85.7	81.4	74.5	68.3	104.5	No	0	194.4	60/60/60	—	— Manufacturer's Specification
		A-weighted correction	-39.4	-26.2	-16.1	-8.6	-3.2	0.0	1.2	1.0	-1.1							
		PWL (dBA)	46.2	76.5	81.6	84.4	85.7	85.7	82.6	75.5	67.2							
S13B	Chiller	PWL (dB)	85.6	102.7	97.7	93.0	88.9	85.7	81.4	74.5	68.3	104.5	No	0	193.5	60/60/60	—	— Manufacturer's Specification
		A-weighted correction	-39.4	-26.2	-16.1	-8.6	-3.2	0.0	1.2	1.0	-1.1							
		PWL (dBA)	46.2	76.5	81.6	84.4	85.7	85.7	82.6	75.5	67.2							
S14A	RNG Compressor Truck Idling	PWL (dB)	92.6	91.7	91.6	91.9	95.6	96.3	91.8	86.4	80.4	102.1	No	0	193.0	60/60/60	—	— GHD Reference Spectra
		A-weighted correction	-39.4	-26.2	-16.1	-8.6	-3.2	0.0	1.2	1.0	-1.1							
		PWL (dBA)	53.2	65.5	75.5	83.3	92.4	96.3	93.0	87.4	79.3							
S14B	RNG Compressor Truck Idling	PWL (dB)	92.6	91.7	91.6	91.9	95.6	96.3	91.8	86.4	80.4	102.1	No	0	193.0	60/60/60	—	— GHD Reference Spectra
		A-weighted correction	-39.4	-26.2	-16.1	-8.6	-3.2	0.0	1.2	1.0	-1.1							
		PWL (dBA)	53.2	65.5	75.5	83.3	92.4	96.3	93.0	87.4	79.3							
S15	RNG Facility Compressor Inlet	PWL (dB)	103.0	98.0	98.0	97.0	100.0	103.0	103.0	101.0	98.0	110.3	No	0	192.5	60/60/60	—	— GHD Reference Spectra
		A-weighted correction	-39.4	-26.2	-16.1	-8.6	-3.2	0.0	1.2	1.0	-1.1							
		PWL (dBA)	63.6	71.8	81.9	88.4	96.8	103.0	104.2	102.0	96.9							
S16A	Organic Processing Building Bay Door (Open)	PWL (dB)	90.8	89.1	87.9	88.9	100.2	89.6	85.1	76.1	70.2	101.8	No	0	191.5	60/60/60	—	— Manufacturer's Specification
		A-weighted correction	-39.4	-26.2	-16.1	-8.6	-3.2	0.0	1.2	1.0	-1.1							
		PWL (dBA)	51.4	62.9	71.8	80.3	97.0	89.6	86.3	77.1	69.1							
S16B	Organic Processing Building Bay Door (Open)	PWL (dB)	90.8	89.1	87.9	88.9	100.2	89.6	85.1	76.1	70.2	101.8	No	0	193.5	60/60/60	—	— Manufacturer's Specification
		A-weighted correction	-39.4	-26.2	-16.1	-8.6	-3.2	0.0	1.2	1.0	-1.1							
		PWL (dBA)	51.4	62.9	71.8	80.3	97.0	89.6	86.3	77.1	69.1							
S16C	Organic Processing Building Bay Door (Open)	PWL (dB)	90.8	89.1	87.9	88.9	100.2	89.6	85.1	76.1	70.2	101.8	No	0	194.5	60/60/60	—	— Manufacturer's Specification
		A-weighted correction	-39.4	-26.2	-16.1	-8.6	-3.2	0.0	1.2	1.0	-1.1							
		PWL (dBA)	51.4	62.9	71.8	80.3	97.0	89.6	86.3	77.1	69.1							
S16D	Organic Processing Building Bay Door (Open)	PWL (dB)	90.8	89.1	87.9	88.9	100.2	89.6	85.1	76.1	70.2	101.8	No	0	193.5	60/60/60	—	— Manufacturer's Specification
		A-weighted correction	-39.4	-26.2	-16.1	-8.6	-3.2	0.0	1.2	1.0	-1.1							
		PWL (dBA)	51.4	62.9	71.8	80.3	97.0	89.6	86.3	77.1	69.1							
S16E	Organic Processing Building Bay Door (Open)	PWL (dB)	90.8	89.1	87.9	88.9	100.2	89.6	85.1	76.1	70.2	101.8	No	0	193.5	60/60/60	—	— Manufacturer's Specification
		A-weighted correction	-39.4	-26.2	-16.1	-8.6	-3.2	0.0	1.2	1.0	-1.1							
		PWL (dBA)	51.4	62.9	71.8	80.3	97.0	89.6	86.3	77.1	69.1							
S16F	Organic Processing Building Bay Door (Open)	PWL (dB)	90.8	89.1	87.9	88.9	100.2	89.6	85.1	76.1	70.2	101.8	No	0	191.5	60/60/60	—	— Manufacturer's Specification
		A-weighted correction	-39.4	-26.2	-16.1	-8.6	-3.2	0.0	1.2	1.0	-1.1							
		PWL (dBA)	51.4	62.9	71.8	80.3	97.0	89.6	86.3	77.1	69.1							
S17A	Pump Building Bay Door (Open)	PWL (dB)	68.1	60.6	60.7	68.6	66.7	68.5	67.8	70.5	69.7	77.4	No	0	192.9	60/60/60	—	— GHD Site Measurement
		A-weighted correction	-39.4	-26.2	-16.1	-8.6	-3.2	0.0	1.2	1.0	-1.1							
		PWL (dBA)	28.7	34.4	44.6	60.0	63.5	68.5	69.0	71.5	68.6							
S17B	Pump Building Bay Door (Open)	PWL (dB)	68.1	60.6	60.7	68.6	66.7	68.5	67.8	70.5	69.7	77.4	No	0	192.9	60/60/60	—	— GHD Site Measurement
		A-weighted correction	-39.4	-26.2	-16.1	-8.6	-3.2	0.0	1.2	1.0	-1.1							
		PWL (dBA)	28.7	34.4	44.6	60.0	63.5	68.5	69.0	71.5	68.6							
S18	Pump Building Bay Door (Open)	PWL (dB)	70.0	64.5	64.4	68.2	67.3	65.6	62.8	64.3	59.8	75.7	No	0	191.9	60/60/60	—	— GHD Site Measurement
		A-weighted correction	-39.4	-26.2	-16.1	-8.6	-3.2	0.0	1.2	1.0	-1.1							
		PWL (dBA)	30.6	38.3	48.3	59.6	64.1	65.6	64.0	65.3	58.7							
S19	Skimmer Building Bay Door (Open)	PWL (dB)	77.8	60.9	61.5	66.5	66.7	67.4	63.2	62.5	55.8	79.2	No	0	192.4	60/60/60	—	— GHD Site Measurement
		A-weighted correction	-39.4	-26.2	-16.1	-8.6	-3.2	0.0	1.2	1.0	-1.1							
		PWL (dBA)	38.4	34.7	45.4	57.9	63.5	67.4	64.4	63.5	54.7							
TR1	Truck Route	PWL (dB)	31.0	117.0	112.0	105.0	107.0	104.0	103.0	100.0	91.0	119.0	No	0	193.0	—	10/3/3	Referenced from UK Department for Environment, Food and Rural Affairs (Defra) Noise Database for Construction Noise document 15 Transport Truck Route - 26ton 235kw - DEFRA Table 1(c)#16
		A-weighted correction	-39.4	-26.2	-16.1	-8.6	-3.2	0.0	1.2	1.0	-1.1							
		PWL (dBA)	—	90.8	95.9	96.4	103.8	104.0	104.2	101.0	89.9							
Emg_1	Emergency Generator (200 kW)	PWL (dB)	101.9	114.9	116.2	108.2	106.8	108.1	105.1	102.7	100.9	119.9	No	0	194.5	60/0/0	—	— GHD Site Measurement
		A-weighted correction	-39.4	-26.2	-16.1	-8.6	-3.2	0.0	1.2	1.0	-1.1							
		PWL (dBA)	62.5	88.7	100.1	99.6	103.6	108.1	106.3	103.7	99.8							

# **Appendix D**

## **Manufacturer Specifications and Preliminary Drawings**

## Carol Bravo

---

**From:** Sam East  
**Sent:** Thursday, November 25, 2021 12:48 PM  
**To:** Sam East  
**Subject:** RE: ComTech Energy - Escarpment Renewables

---

**From:** Guy Couturier <[guy.couturier@comtechenergy.ca](mailto:guy.couturier@comtechenergy.ca)>  
**Sent:** Friday, September 17, 2021 4:13 PM  
**To:** Daniel Turner <[Daniel.Turner@ghd.com](mailto:Daniel.Turner@ghd.com)>  
**Cc:** Jon Taylor <[jon.taylor@comtechenergy.ca](mailto:jon.taylor@comtechenergy.ca)>; James Ro @ ComTech <[james.ro@comtechenergy.ca](mailto:james.ro@comtechenergy.ca)>; Marie-Geneviève Poitras <[mg.poitras@comtechenergy.ca](mailto:mg.poitras@comtechenergy.ca)>  
**Subject:** RE: ComTech Energy - Escarpment Renewables

Hello Daniel,

The high pressure CNG compressors we are looking at for this application typically have a sound rating of 80-85 dBa @ 10 feet. If this is too high for your requirements we can look into sound attenuation dampers as an option. We have just this week also provided Sam and Andrew some pricing for the transportation costs and proposed a call the week of the 27<sup>th</sup> to get everyone back on the same page and see where they are at and how we can help them move forward. Hopefully they will agree and we will all get the chance to catch up.

Let us know if you have any questions or need any additional information.

Thanks,

Guy

**Guy Couturier**  
*Senior Sales Specialist Renewable & Alternative Energy*

**ComTech** Energy

C: (514) 777-9544

Visit the NEW [www.comtechenergy.ca](http://www.comtechenergy.ca) to learn more about us and why we are the right partner for you!



# S13

**motivair**<sup>™</sup>  
COOLING SOLUTIONS

OFFER REFERENCE: QT20-12855 / OP20-12093  
CUSTOMER: GHD  
CONTACT: Scott Dunbar  
PROJECT: Humber Plant Wide Upgrades - Gas Chilling  
DATE: 2020 September 17<sup>th</sup>

CREATED BY  
NAME: Ahmed El Nady  
PHONE: 416-819-0151  
EMAIL: aelnady@trane.com



<i>Free Cooling chiller with scroll compressors</i>		<b>MPC-FC-5000-SP</b>
Refrigerant	R	410A
Electrical	V/ph/Hz	460/3/60
Electrical cabinet	NEMA	3R
Cooling capacity	TONS	26.09
Cooling capacity	BTU/h	313,095
Inlet fluid temperature	°F	41.0
Outlet fluid temperature	°F	35.6
Fluid type	Type	Propylene glycol
Glycol percentage	%	50%
Design ambient temperature	°F	95
Elevation	ft	0
<b>INTEGRATED FREE COOLING DATA</b>		
Cooling capacity	TONS	26.09
Cooling capacity	BTU/h	313,095
Ambient temperature for 100% Free Cooling	°F	20.3
Inlet fluid temperature	°F	41.0
Outlet fluid temperature	°F	35.6
Free Cooling pressure drops (Free Cooling coil + evaporator + valves + piping)	ftH2O	127.2
<b>COMPRESSOR DATA</b>		
Compressor number and type	N°xType	4 x scroll
Number of circuits	N°	2
Total compressors running current RLA	A	60.4
Chiller capacity steps	N°	4

EVAPORATOR DATA		
Number of evaporators	N°	2
Type of evaporator	Type	plate
Approval	/	<b>CRN</b>
Nominal flow rate	gpm	130.8
Minimum flow rate	gpm	70.4
Mechanical cooling pressure drops (evaporator + valves + piping)	ftH <sub>2</sub> O	68.8
Hydraulic connections	ANSI	2.5"
AIR AXIAL FANS AND CONDENSER DATA		
Number of fans	N°	4.0
Total air flow	cfm	42,380
Minimum ambient temperature	°F	-40.0
Maximum ambient temperature	°F	105
PUMP AND TANK DATA		
Pump motor size	HP	<b>15</b>
Available external pressure	ftH <sub>2</sub> O	77.3
Buffer tank material	Type	<b>Stainless steel</b>
Buffer tank volume	gal	132
TOTAL ELECTRICAL DATA (standard configuration)		
Full load amps (FLA)	A	98
Minimum circuit ampacity (MCA)	A	102
Maximum overcurrent protection (MOP)	A	118
Short circuit current rating (SCCR)	kA	6
NOISE DATA ACCORDING ISO3744		
Sound pressure level at 33ft	dba	63
DIMENSIONS		
Length	in	171
Width	in	44
Height	in	86
WEIGHT		
Empty	lb	4,860



BUDGET PRICING (CAD\$)	
Qty. One (1) Motivair MPC-FC-5000-SP Chiller as described above:	\$119,500.00
***Freight Estimate:	\$5,500.00
Available Options:	
Adder: Stainless Steel Tank:	INCLUDED.
Adder: P5 High Pressure Pumps (Required):	INCLUDED.
Adder: Condenser Coil Coating:	\$17,650.00
Adder: Communication Interface Card:	\$3,200.0.
Adder: Duplex Pumps w/ Automatic Changeover:	\$10,590.00
Adder: Scroll Compressor Wraps (Low Noise):	\$3,662.00
Adder: Evaporator Heat Trace:	\$2,948.00
Adder: Compressor Service Valves:	\$3,942.00
Adder: 2nd-5th year extended compressor parts only warranty (No Labor):	\$8,311.00
<u>Note: extended compressor parts only warranty is only available with verification that start-up has been performed by a factory authorized representative.</u>	
NOTES	
All data subject to change.	
See Motivair Engineering Bulletin for installation details.	
<b>For 575V chillers, specify region to have CRN approval.</b>	
Customer is responsible for ensuring there is an adequate amount of system volume. Motivair requires 3 to 5 times the amount of flow through the chiller at a minimum. Example: 300GPM x 5 minutes = 1,500 Gallons. The recommended system volume must be maintained during all modes of operation including when a system bypass is active.	
Correct glycol percentage required for design winter ambient. Motivair warranty does not cover damage due to freezing.	
SHIPMENT	
Approximate shipment is 12 - 14 weeks, A.R.O. pending all approvals.	

**S13**

**motivair™**

\*\*\*Freight is an estimate only and is subject to change based on current day charges.

NOTES:

1. DIMENSIONS AND TOLERANCES IN ACCORDANCE WITH ASME Y14.5M-2009.

2. ALL HINGED DOORS SWING OUT 36" FROM THE ENCLOSURE.

3. ALLOW 48" ON THE MOTOR SIDE TO ALLOW FOR COOLER REMOVAL SEE SHEET 2.

4. THIS DRAWING IS AN ELECTRICAL PIT CONDUIT CONFIGURATION, ALL SIDE ELECTRICAL PENETRATIONS ARE PLUGGED.

5. DRAIN VALVES EXTEND APPROXIMATELY 6 INCHES OUT FROM THE ENCLOSURE.

**S12**

COMPRESSOR DATA

WEIGHT: 30,000 LBS (APPROXIMATE).


TYPE: ARIEL RECIPROCATING COMPRESSOR.

CLEARANCE: ALLOW 36" MINIMUM ON ALL SIDES FOR ACCESS UNLESS OTHERWISE INDICATED.

MOUNTING: REQUIRES EIGHT (8) 1" DIAMETER ANCHOR BOLTS (NOT PROVIDED). GROUTING THE COMPRESSOR TO THE CONCRETE PAD IS NOT RECOMMENDED.

LIFTING: FOR SPREADER BAR SIZING, SEE A05-13-NG300E-DUPLEX

SHIPPING: VENT STACK, INLET VALVE, DRAIN VALVES, AND 1/4" ACTUATOR TUBING ARE REMOVED FOR SHIPPING.




REV	DATE	APPROVED	DESCRIPTION
B	02/08/2018	JFO	UPDATE VISUALS, ADD DIMS ACN1005622
A	10/9/17	JRG	UPDATE PIT PENETRATIONS, ACN1004520
REV	DATE	APPROVED	DESCRIPTION

UNLESS OTHERWISE SPECIFIED		TITLE	
BREAK SHARP EDGES .005 - .015		GENERAL LAYOUT - NG300E DUPLEX COLD WEATHER - PIT PENETRATIONS	
ALL DIMENSIONS IN INCHES		CUSTOMER	PROJECT NO
FRACTIONAL	± 1/8	SHEET	1 of 3
TWO PLACE DECIMAL	± .010	SCALE	0.050
THREE PLACE DECIMAL	± .005	DATE	10/19/2015
ANGLES	± 1"	DRAWN BY	JFO
ANGI ENERGY SYSTEMS 305 W DELAVAN DR JANESVILLE, WI 53546 PH: 608-563-2800 WWW.ANGIENERGY.COM		DRAWING NO A05-10-ED-CW-PIT	
THIS DRAWING AND INFORMATION THEREIN IS PROPRIETARY INFORMATION, AND IS THE SOLE PROPERTY OF ANGI ENERGY SYSTEMS, LLC. IT MAY NOT BE COPIED, REPRODUCED OR PROVIDED TO OTHERS WITHOUT EXPRESS WRITTEN AUTHORIZATION BY ANGI ENERGY SYSTEMS, LLC. ALL COPIES AND REPRODUCTIONS ARE THE PROPERTY OF ANGI ENERGY AND SUBJECT TO RETURN ON DEMAND.		REV B	




ANGI RELEASED 14-Feb-18



ENCLOSURE BUMP OUT WIDTH - SEE SITE PID TO DETERMINE DIM "A"


ENGINE HP	BUMP OUT STYLE	DIM "A"
100 HP	E1	0.00
125 HP	E1	0.00
150 HP	E1	0.00
200 HP	E2	5.19
250 HP	E2	5.19
300 HP	E3	10.39

DETAIL I  
SCALE 0.125




<p>ANGI ENERGY SYSTEMS 305 W DELAVAN DR JANESVILLE, WI 53546 PH: 608-563-2800 WWW.ANGIENERGY.COM</p>	UNLESS OTHERWISE SPECIFIED	<p>GENERAL LAYOUT - NG300E DUPLEX COLD WEATHER - PIT PENETRATIONS</p>	
	<p>BREAK SHARP EDGES .005 - .015 ALL DIMENSIONS IN INCHES</p> <p>FRACTIONAL ± 1/8 TWO PLACE DECIMAL ± .010 THREE PLACE DECIMAL ± .005 ANGLES ± 1°</p>	<p>CUSTOMER</p> <p>SHEET 2 of 3</p> <p>SCALE 0.063</p> <p>DATE 10/19/2015</p>	<p>PROJECT NO</p> <p>DRAWING NO A05-10-ED-CW-PIT</p> <p>REV B</p>

ANGI RELEASED 14-Feb-18



ANCHOR BOLT LOCATIONS  
AND CONDUIT PENETRATION LOCATIONS



	ANGI ENERGY SYSTEMS 305 W DELAVAN DR JANEVILLE, WI 53546 PH: 608-563-2800 WWW.ANGIENERGY.COM	UNLESS OTHERWISE SPECIFIED		TOLERANCE	
		BREAK SHARP EDGES .005 - .015 ALL DIMENSIONS IN INCHES	FRACTIONAL ± 1/8 TWO PLACE DECIMAL ± .010 THREE PLACE DECIMAL ± .005 ANGLES ± 1°	CUSTOMER PROJECT NO	SCALE DATE
THIS DRAWING AND INFORMATION THEREIN IS PROPRIETARY INFORMATION, AND IS THE SOLE PROPERTY OF ANGI ENERGY SYSTEMS, LLC. IT MAY NOT BE COPIED, REPRODUCED OR PROVIDED TO OTHERS WITHOUT EXPRESS WRITTEN AUTHORIZATION BY ANGI ENERGY SYSTEMS, LLC. ALL COPIES AND REPRODUCTIONS ARE THE PROPERTY OF ANGI ENERGY SYSTEMS, LLC.		SHEET 3 of 3 DRAWN BY JFO	SCALE 0.063 DATE 10/19/2015	GENERAL LAYOUT - NG300E DUPLEX COLD WEATHER - PIT PENETRATIONS A05-10-ED-CW-PIT	REV B

ANGI RELEASED 14-Feb-18

# S16



EQUIPMENT: SCOTT EQUIPMENT COMPANY  
SUBJECT: TURBO SEPARATOR  
SOUND RATINGS


Please find a specification for our normalized, expected dB output when processing organic waste in our Turbo Separator models (T16, T20, T30, T42, THOR, and Mega THOR).

5'	10'	20'	50'
90dB*	80-85dB	70-75dB	<70dB

A sound level meter is the instrument normally used to measure noise levels on the decibel scale. Several factors affect the noise level reading:

- The distance between the meter and the source of the sound
- The direction the noise source is facing, relative to the meter
- Whether the measurement is taken outdoors (where noise can dissipate) or indoors (where noise can reverberate)

*\*when processing metal cans only, dB rating increases by >5%*



Should you have any additional questions, please do not hesitate to contact Scott Test Lab directly at 952.758.0418.

Sincerely,

A handwritten signature in black ink, appearing to read "Kevin Pedretti".

Kevin Pedretti  
Scott Equipment Company

# **Appendix E**

## **CadnaA Sample Calculation**

## Receiver

Name: Sobie Road One-Storey Residential Facade

ID: POR4

X: 619494.26 m

Y: 4778092.25 m

Z: 191.57 m

Point Source, ISO 9613, Name: "RNG Facility Compressor Inlet", ID: "!07!S15"

Nr.	X (m)	Y (m)	Z (m)	Refl.	DEN	Freq. (Hz)	Lw dB(A)	l/a dB	Optime dB	K0 (dB)	Di (dB)	Adiv (dB)	Aatm (dB)	Agr (dB)	Afol (dB)	Ahous (dB)	Abar (dB)	Cmet (dB)	RL (dB)	Lr dB(A)
109	618939.98	4778235.69	192.50	0	DEN	A	108.6	0.0	0.0	0.0	0.0	66.2	4.7	-0.3	0.0	0.0	6.9	0.0	0.0	31.1
119	618939.98	4778235.69	192.50	1	DEN	A	108.6	0.0	0.0	0.0	0.0	67.9	5.4	-0.6	0.0	0.0	24.0	0.0	13.5	-1.6
123	618939.98	4778235.69	192.50	1	DEN	A	108.6	0.0	0.0	0.0	0.0	67.3	5.2	-0.5	0.0	0.0	24.0	0.0	11.9	0.7
130	618939.98	4778235.69	192.50	1	DEN	A	108.6	0.0	0.0	0.0	0.0	66.4	4.8	-0.3	0.0	0.0	6.1	0.0	5.1	26.5
134	618939.98	4778235.69	192.50	1	DEN	A	108.6	0.0	0.0	0.0	0.0	67.0	5.1	-0.4	0.0	0.0	4.8	0.0	9.8	22.4
141	618939.98	4778235.69	192.50	1	DEN	A	108.6	0.0	0.0	0.0	0.0	68.4	5.6	-0.6	0.0	0.0	23.9	0.0	14.7	-3.5
144	618939.98	4778235.69	192.50	1	DEN	A	108.6	0.0	0.0	0.0	0.0	67.2	5.1	-0.5	0.0	0.0	23.5	0.0	11.2	2.1

Point Source, ISO 9613, Name: "RNG Facility Compressor Outlet", ID: "!07!S12B"

Nr.	X (m)	Y (m)	Z (m)	Refl.	DEN	Freq. (Hz)	Lw dB(A)	l/a dB	Optime dB	K0 (dB)	Di (dB)	Adiv (dB)	Aatm (dB)	Agr (dB)	Afol (dB)	Ahous (dB)	Abar (dB)	Cmet (dB)	RL (dB)	Lr dB(A)
153	618939.62	4778197.30	194.35	0	DEN	A	105.5	0.0	0.0	0.0	0.0	66.0	4.7	-0.2	0.0	0.0	5.7	0.0	0.0	29.3
157	618939.62	4778197.30	194.35	1	DEN	A	105.5	0.0	0.0	0.0	0.0	68.2	5.5	-0.6	0.0	0.0	15.7	0.0	15.0	1.6
160	618939.62	4778197.30	194.35	1	DEN	A	105.5	0.0	0.0	0.0	0.0	67.7	5.3	-0.5	0.0	0.0	12.2	0.0	13.8	6.9
169	618939.62	4778197.30	194.35	1	DEN	A	105.5	0.0	0.0	0.0	0.0	66.9	5.0	-0.4	0.0	0.0	4.5	0.0	10.4	19.0
172	618939.62	4778197.30	194.35	1	DEN	A	105.5	0.0	0.0	0.0	0.0	66.9	5.0	-0.4	0.0	0.0	4.5	0.0	8.4	21.1
175	618939.62	4778197.30	194.35	1	DEN	A	105.5	0.0	0.0	0.0	0.0	67.4	5.2	-0.5	0.0	0.0	4.4	0.0	12.8	16.2

Point Source, ISO 9613, Name: "RNG Facility Compressor Outlet", ID: "!07!S12A"

Nr.	X (m)	Y (m)	Z (m)	Refl.	DEN	Freq. (Hz)	Lw dB(A)	l/a dB	Optime dB	K0 (dB)	Di (dB)	Adiv (dB)	Aatm (dB)	Agr (dB)	Afol (dB)	Ahous (dB)	Abar (dB)	Cmet (dB)	RL (dB)	Lr dB(A)
179	618934.96	4778198.83	194.35	0	DEN	A	105.5	0.0	0.0	0.0	0.0	66.1	4.7	-0.2	0.0	0.0	5.5	0.0	0.0	29.4
183	618934.96	4778198.83	194.35	1	DEN	A	105.5	0.0	0.0	0.0	0.0	68.2	5.5	-0.6	0.0	0.0	16.5	0.0	14.9	1.0
185	618934.96	4778198.83	194.35	1	DEN	A	105.5	0.0	0.0	0.0	0.0	67.6	5.3	-0.5	0.0	0.0	12.6	0.0	13.7	6.8
192	618934.96	4778198.83	194.35	1	DEN	A	105.5	0.0	0.0	0.0	0.0	66.9	5.0	-0.4	0.0	0.0	4.5	0.0	10.4	19.1
196	618934.96	4778198.83	194.35	1	DEN	A	105.5	0.0	0.0	0.0	0.0	66.8	5.0	-0.4	0.0	0.0	4.6	0.0	7.8	21.7
202	618934.96	4778198.83	194.35	1	DEN	A	105.5	0.0	0.0	0.0	0.0	67.4	5.2	-0.5	0.0	0.0	4.4	0.0	12.5	16.5

Point Source, ISO 9613, Name: "CHP Unit", ID: "!03!S07"

Nr.	X (m)	Y (m)	Z (m)	Refl.	DEN	Freq. (Hz)	Lw dB(A)	l/a dB	Optime dB	K0 (dB)	Di (dB)	Adiv (dB)	Aatm (dB)	Agr (dB)	Afol (dB)	Ahous (dB)	Abar (dB)	Cmet (dB)	RL (dB)	Lr dB(A)
208	618826.17	4778286.11	198.09	0	DEN	A	103.2	0.0	0.0	0.0	0.0	67.8	2.7	2.1	0.0	0.0	12.7	0.0	0.0	17.8
214	618826.17	4778286.11	198.09	1	DEN	A	103.2	0.0	0.0	0.0	0.0	68.0	2.7	2.1	0.0	0.0	2.7	0.0	22.1	5.5

Point Source, ISO 9613, Name: "RNG Compressor Truck Idling", ID: "!07!S14A"

Nr.	X (m)	Y (m)	Z (m)	Refl.	DEN	Freq. (Hz)	Lw dB(A)	l/a dB	Optime dB	K0 (dB)	Di (dB)	Adiv (dB)	Aatm (dB)	Agr (dB)	Afol (dB)	Ahous (dB)	Abar (dB)	Cmet (dB)	RL (dB)	Lr dB(A)
220	618938.71	4778187.69	193.00	0	DEN	A	99.5	0.0	0.0	0.0	0.0	66.0	2.7	0.4	0.0	0.0	6.0	0.0	0.0	24.4
224	618938.71	4778187.69	193.00	1	DEN	A	99.5	0.0	0.0	0.0	0.0	68.3	3.3	-0.0	0.0	0.0	15.0	0.0	15.4	-2.4
228	618938.71	4778187.69	193.00	1	DEN	A	99.5	0.0	0.0	0.0	0.0	67.8	3.1	0.1	0.0	0.0	11.3	0.0	14.3	3.0
230	618938.71	4778187.69	193.00	1	DEN	A	99.5	0.0	0.0	0.0	0.0	67.0	2.9	0.2	0.0	0.0	4.2	0.0	11.2	14.0
244	618938.71	4778187.69	193.00	1	DEN	A	99.5	0.0	0.0	0.0	0.0	66.9	2.9	0.2	0.0	0.0	4.3	0.0	8.7	16.6
250	618938.71	4778187.69	193.00	1	DEN	A	99.5	0.0	0.0	0.0	0.0	67.5	3.1	0.1	0.0	0.0	4.0	0.0	13.3	11.5

Point Source, ISO 9613, Name: "RNG Compressor Truck Idling", ID: "!07!S14B"

Nr.	X (m)	Y (m)	Z (m)	Refl.	DEN	Freq. (Hz)	Lw dB(A)	l/a dB	Optime dB	K0 (dB)	Di (dB)	Adiv (dB)	Aatm (dB)	Agr (dB)	Afol (dB)	Ahous (dB)	Abar (dB)	Cmet (dB)	RL (dB)	Lr dB(A)
261	618931.06	4778189.30	193.00	0	DEN	A	99.5	0.0	0.0	0.0	0.0	66.1	2.7	0.3	0.0	0.0	5.6	0.0	0.0	24.7
263	618931.06	4778189.30	193.00	1	DEN	A	99.5	0.0	0.0	0.0	0.0	68.2	3.3	0.0	0.0	0.0	15.9	0.0	15.3	-3.2
268	618931.06	4778189.30	193.00	1	DEN	A	99.5	0.0	0.0	0.0	0.0	67.7	3.1	0.1	0.0	0.0	11.5	0.0	14.1	2.9
270	618931.06	4778189.30	193.00	1	DEN	A	99.5	0.0	0.0	0.0	0.0	67.0	2.9	0.2	0.0	0.0	4.2	0.0	11.2	14.0
272	618931.06	4778189.30	193.00	1	DEN	A	99.5	0.0	0.0	0.0	0.0	66.8	2.9	0.2	0.0	0.0	4.4	0.0	7.8	17.5
274	618931.06	4778189.30	193.00	1	DEN	A	99.5	0.0	0.0	0.0	0.0	67.4	3.0	0.1	0.0	0.0	4.1	0.0	13.0	11.8



Point Source, ISO 9613, Name: "Flare", ID: "!07!S10"																				
Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)
276	618942.63	4778184.06	207.00	0	D	A	98.9	0.0	-3.0	0.0	0.0	66.0	1.6	3.0	0.0	0.0	0.0	0.0	0.0	25.3
276	618942.63	4778184.06	207.00	0	N	A	98.9	0.0	-3.0	0.0	0.0	66.0	1.6	3.0	0.0	0.0	0.0	0.0	0.0	25.3
276	618942.63	4778184.06	207.00	0	E	A	98.9	0.0	-3.0	0.0	0.0	66.0	1.6	3.0	0.0	0.0	0.0	0.0	0.0	25.3

Point Source, ISO 9613, Name: "Ventilation Exhaust", ID: "!03!S01"																				
Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)
283	618840.43	4778283.40	192.64	0	DEN	A	97.3	0.0	0.0	0.0	0.0	67.7	2.1	1.6	0.0	0.0	21.7	0.0	0.0	4.3
289	618840.43	4778283.40	192.64	1	DEN	A	97.3	0.0	0.0	0.0	0.0	68.5	2.3	1.5	0.0	0.0	10.5	0.0	19.7	-5.2

Line Source, ISO 9613, Name: "Fork Lift Route", ID: "!03!FR1"																				
Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)
300	618748.05	4778206.75	192.93	0	DEN	A	77.7	15.6	0.0	0.0	0.0	68.6	1.5	3.7	0.0	0.0	12.5	0.0	0.0	7.1
305	618748.05	4778206.75	192.93	1	DEN	A	77.7	15.6	0.0	0.0	0.0	68.9	1.5	3.6	0.0	0.0	19.7	0.0	01.9	-102.3
310	618766.80	4778200.96	192.86	0	DEN	A	77.7	4.7	0.0	0.0	0.0	68.3	1.4	3.7	0.0	0.0	2.4	0.0	0.0	6.6
315	618766.80	4778200.96	192.86	1	DEN	A	77.7	4.7	0.0	0.0	0.0	68.8	1.5	3.6	0.0	0.0	19.6	0.0	01.0	-112.0
319	618770.54	4778199.81	192.85	0	DEN	A	77.7	6.9	0.0	0.0	0.0	68.3	1.4	3.7	0.0	0.0	2.6	0.0	0.0	8.5
323	618770.54	4778199.81	192.85	1	DEN	A	77.7	6.9	0.0	0.0	0.0	68.7	1.5	3.6	0.0	0.0	19.5	0.0	96.3	-105.1
327	618779.01	4778197.19	192.81	0	DEN	A	77.7	11.1	0.0	0.0	0.0	68.2	1.4	3.8	0.0	0.0	0.8	0.0	0.0	14.7
334	618779.01	4778197.19	192.81	1	DEN	A	77.7	11.1	0.0	0.0	0.0	68.7	1.5	3.7	0.0	0.0	9.9	0.0	97.6	-92.5
1337	618821.57	4778192.70	192.85	0	DEN	A	77.7	2.9	0.0	0.0	0.0	67.7	1.3	3.9	0.0	0.0	11.0	0.0	0.0	-3.2
1341	618821.57	4778192.70	192.85	1	DEN	A	77.7	2.9	0.0	0.0	0.0	68.2	1.4	3.7	0.0	0.0	4.6	0.0	96.5	-93.8
1345	618821.57	4778192.70	192.85	1	DEN	A	77.7	2.9	0.0	0.0	0.0	68.1	1.4	3.8	0.0	0.0	6.0	0.0	98.0	-96.6
1350	618821.57	4778192.70	192.85	1	DEN	A	77.7	2.9	0.0	0.0	0.0	67.9	1.3	3.8	0.0	0.0	15.5	0.0	97.1	-105.0
1354	618821.57	4778192.70	192.85	1	DEN	A	77.7	2.9	0.0	0.0	0.0	68.4	1.4	3.7	0.0	0.0	6.5	0.0	15.9	-15.3
1359	618821.57	4778192.70	192.85	1	DEN	A	77.7	2.9	0.0	0.0	0.0	67.9	1.3	3.8	0.0	0.0	14.7	0.0	04.7	-111.8
1364	618824.99	4778191.72	192.85	0	DEN	A	77.7	7.1	0.0	0.0	0.0	67.6	1.3	3.9	0.0	0.0	11.7	0.0	0.0	0.4
1368	618824.99	4778191.72	192.85	1	DEN	A	77.7	7.1	0.0	0.0	0.0	68.2	1.4	3.7	0.0	0.0	4.8	0.0	96.3	-89.6
1372	618824.99	4778191.72	192.85	1	DEN	A	77.7	7.1	0.0	0.0	0.0	68.1	1.4	3.8	0.0	0.0	17.3	0.0	97.0	-102.7
1374	618824.99	4778191.72	192.85	1	DEN	A	77.7	7.1	0.0	0.0	0.0	67.9	1.3	3.8	0.0	0.0	16.6	0.0	96.6	-101.4
1380	618824.99	4778191.72	192.85	1	DEN	A	77.7	7.1	0.0	0.0	0.0	68.4	1.4	3.7	0.0	0.0	6.5	0.0	15.8	-11.0
1383	618824.99	4778191.72	192.85	1	DEN	A	77.7	7.1	0.0	0.0	0.0	67.9	1.3	3.8	0.0	0.0	16.7	0.0	03.0	-107.9
1390	618833.55	4778189.26	192.86	0	DEN	A	77.7	11.0	0.0	0.0	0.0	67.5	1.3	3.9	0.0	0.0	0.7	0.0	0.0	15.4
1395	618833.55	4778189.26	192.86	1	DEN	A	77.7	11.0	0.0	0.0	0.0	68.2	1.4	3.7	0.0	0.0	20.0	0.0	16.2	-20.8
1442	618833.55	4778189.26	192.86	1	DEN	A	77.7	11.0	0.0	0.0	0.0	68.0	1.4	3.8	0.0	0.0	20.2	0.0	94.3	-98.9
1444	618833.55	4778189.26	192.86	1	DEN	A	77.7	11.0	0.0	0.0	0.0	67.8	1.3	3.8	0.0	0.0	19.9	0.0	93.9	-98.0
1450	618833.55	4778189.26	192.86	1	DEN	A	77.7	11.0	0.0	0.0	0.0	67.5	1.3	3.9	0.0	0.0	0.9	0.0	76.0	-160.8
1454	618833.55	4778189.26	192.86	1	DEN	A	77.7	11.0	0.0	0.0	0.0	68.4	1.4	3.7	0.0	0.0	19.7	0.0	15.5	-20.1
1459	618833.55	4778189.26	192.86	1	DEN	A	77.7	11.0	0.0	0.0	0.0	67.8	1.3	3.8	0.0	0.0	19.9	0.0	94.9	-99.0
1463	618838.84	4778187.74	192.86	1	DEN	A	77.7	2.1	0.0	0.0	0.0	67.5	1.3	3.9	0.0	0.0	0.9	0.0	1.0	5.3
1469	618822.64	4778192.39	192.85	1	DEN	A	77.7	6.2	0.0	0.0	0.0	68.8	1.5	3.7	0.0	0.0	1.4	0.0	77.7	-69.0
1471	618832.13	4778189.67	192.86	1	DEN	A	77.7	11.9	0.0	0.0	0.0	68.9	1.5	3.6	0.0	0.0	1.3	0.0	77.6	-63.3
1479	618833.69	4778189.22	192.86	2	DEN	A	77.7	0.7	0.0	0.0	0.0	68.9	1.5	3.6	0.0	0.0	2.7	0.0	85.8	-84.1
1484	618836.28	4778188.48	192.86	2	DEN	A	77.7	6.2	0.0	0.0	0.0	68.9	1.5	3.6	0.0	0.0	1.3	0.0	83.4	-74.9
1490	618838.38	4778187.88	192.86	2	DEN	A	77.7	-7.8	0.0	0.0	0.0	68.9	1.5	3.6	0.0	0.0	1.3	0.0	83.4	-88.8
1498	618809.95	4778195.36	192.84	0	DEN	A	77.7	12.6	0.0	0.0	0.0	67.8	1.3	3.8	0.0	0.0	8.6	0.0	0.0	8.7
1503	618809.95	4778195.36	192.84	1	DEN	A	77.7	12.6	0.0	0.0	0.0	68.3	1.4	3.7	0.0	0.0	11.8	0.0	97.2	-92.1
1507	618809.95	4778195.36	192.84	1	DEN	A	77.7	12.6	0.0	0.0	0.0	68.2	1.4	3.7	0.0	0.0	2.1	0.0	01.0	-86.2
1512	618809.95	4778195.36	192.84	1	DEN	A	77.7	12.6	0.0	0.0	0.0	68.5	1.4	3.7	0.0	0.0	12.6	0.0	16.3	-12.2
1515	618809.95	4778195.36	192.84	1	DEN	A	77.7	12.6	0.0	0.0	0.0	68.0	1.4	3.8	0.0	0.0	1.0	0.0	99.7	-83.5
1520	618819.85	4778193.16	192.85	0	DEN	A	77.7	3.6	0.0	0.0	0.0	67.7	1.3	3.9	0.0	0.0	10.7	0.0	0.0	-2.2
1524	618819.85	4778193.16	192.85	1	DEN	A	77.7	3.6	0.0	0.0	0.0	68.3	1.4	3.7	0.0	0.0	4.5	0.0	96.5	-93.1
1528	618819.85	4778193.16	192.85	1	DEN	A	77.7	3.6	0.0	0.0	0.0	68.1	1.4	3.8	0.0	0.0	5.6	0.0	98.1	-95.7
1533	618819.85	4778193.16	192.85	1	DEN	A	77.7	3.6	0.0	0.0	0.0	68.4	1.4	3.7	0.0	0.0	6.4	0.0	16.0	-14.6
1537	618819.85	4778193.16	192.85	1	DEN	A	77.7	3.6	0.0	0.0	0.0	67.9	1.4	3.8	0.0	0.0	1.0	0.0	99.0	-91.7
1542	618805.43	4778196.36	192.83	1	DEN	A	77.7	9.4	0.0	0.0	0.0	68.6	1.5	3.7	0.0	0.0	2.0	0.0	78.4	-67.0
1548	618814.27	4778194.40	192.84	1	DEN	A	77.7	9.7	0.0	0.0	0.0	68.7	1.5	3.7	0.0	0.0	2.0	0.0	78.4	-66.7
1554	618819.90	4778193.15	192.85	1	DEN	A	77.7	3.4	0.0	0.0	0.0	68.7	1.5	3.7	0.0	0.0	1.4	0.0	77.7	-71.8
1839	618788.77	4778195.75	192.80	0	DEN	A	77.7	8.6	0.0	0.0	0.0	68.1	1.4	3.8	0.0	0.0	0.8	0.0	0.0	12.4
1846	618788.77	4778195.75	192.80	1	DEN	A	77.7	8.6	0.0	0.0	0.0	68.5	1.4	3.7	0.0	0.0	9.6	0.0	04.6	-101.5
1852	618788.77	4778195.75	192.80	1	DEN	A	77.7	8.6	0.0	0.0	0.0	68.6	1.5	3.7	0.0	0.0	10.6	0.0	97.2	-95.2
1859	618788.77	4778195.75	192.80	1	DEN	A	77.7	8.6	0.0	0.0	0.0	68.2	1.4	3.7	0.0	0.0	1.0	0.0	18.0	-106.1

Line Source, ISO 9613, Name: "Fork Lift Route", ID: "I03!FR1"																				
Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)
1865	618793.68	4778196.37	192.81	0	DEN	A	77.7	4.2	0.0	0.0	0.0	68.0	1.4	3.8	0.0	0.0	5.3	0.0	0.0	3.5
1871	618793.68	4778196.37	192.81	1	DEN	A	77.7	4.2	0.0	0.0	0.0	68.5	1.4	3.7	0.0	0.0	10.3	0.0	97.9	-99.8
1878	618793.68	4778196.37	192.81	1	DEN	A	77.7	4.2	0.0	0.0	0.0	68.6	1.5	3.7	0.0	0.0	11.2	0.0	97.0	-99.9
1888	618793.68	4778196.37	192.81	1	DEN	A	77.7	4.2	0.0	0.0	0.0	68.2	1.4	3.7	0.0	0.0	1.0	0.0	17.7	-110.1
1895	618798.07	4778196.92	192.82	0	DEN	A	77.7	7.9	0.0	0.0	0.0	68.0	1.4	3.8	0.0	0.0	6.2	0.0	0.0	6.4
1901	618798.07	4778196.92	192.82	1	DEN	A	77.7	7.9	0.0	0.0	0.0	68.4	1.4	3.7	0.0	0.0	10.9	0.0	97.7	-96.5
1923	618798.07	4778196.92	192.82	1	DEN	A	77.7	7.9	0.0	0.0	0.0	68.5	1.5	3.7	0.0	0.0	11.8	0.0	96.8	-96.6
1929	618798.07	4778196.92	192.82	1	DEN	A	77.7	7.9	0.0	0.0	0.0	68.1	1.4	3.8	0.0	0.0	1.0	0.0	17.4	-106.0
1936	618793.56	4778196.35	192.81	1	DEN	A	77.7	11.8	0.0	0.0	0.0	68.4	1.4	3.7	0.0	0.0	2.5	0.0	1.0	12.5
2252	618839.87	4778188.33	192.87	0	DEN	A	77.7	2.3	0.0	0.0	0.0	67.4	1.3	3.9	0.0	0.0	0.7	0.0	0.0	6.7
2258	618839.87	4778188.33	192.87	1	DEN	A	77.7	2.3	0.0	0.0	0.0	68.2	1.4	3.7	0.0	0.0	5.6	0.0	16.0	-14.9
2264	618839.87	4778188.33	192.87	1	DEN	A	77.7	2.3	0.0	0.0	0.0	68.0	1.4	3.8	0.0	0.0	8.7	0.0	96.8	-98.6
2271	618839.87	4778188.33	192.87	1	DEN	A	77.7	2.3	0.0	0.0	0.0	67.7	1.3	3.8	0.0	0.0	8.6	0.0	95.8	-97.2
2277	618839.87	4778188.33	192.87	1	DEN	A	77.7	2.3	0.0	0.0	0.0	67.4	1.3	3.9	0.0	0.0	0.9	0.0	16.3	-109.8
2284	618839.87	4778188.33	192.87	1	DEN	A	77.7	2.3	0.0	0.0	0.0	68.4	1.4	3.7	0.0	0.0	20.4	0.0	15.4	-29.3
2289	618839.87	4778188.33	192.87	1	DEN	A	77.7	2.3	0.0	0.0	0.0	67.7	1.3	3.8	0.0	0.0	1.0	0.0	93.2	-87.1
2294	618840.28	4778189.69	192.87	0	DEN	A	77.7	0.6	0.0	0.0	0.0	67.4	1.3	3.9	0.0	0.0	0.7	0.0	0.0	5.1
2301	618840.28	4778189.69	192.87	1	DEN	A	77.7	0.6	0.0	0.0	0.0	68.2	1.4	3.8	0.0	0.0	20.4	0.0	15.9	-31.2
2306	618840.28	4778189.69	192.87	1	DEN	A	77.7	0.6	0.0	0.0	0.0	68.0	1.4	3.8	0.0	0.0	8.8	0.0	96.8	-100.3
2312	618840.28	4778189.69	192.87	1	DEN	A	77.7	0.6	0.0	0.0	0.0	67.7	1.3	3.8	0.0	0.0	8.6	0.0	95.8	-98.9
2318	618840.28	4778189.69	192.87	1	DEN	A	77.7	0.6	0.0	0.0	0.0	67.4	1.3	3.9	0.0	0.0	0.9	0.0	75.2	-170.3
2323	618840.28	4778189.69	192.87	1	DEN	A	77.7	0.6	0.0	0.0	0.0	68.4	1.4	3.7	0.0	0.0	21.3	0.0	15.3	-31.7
2329	618840.28	4778189.69	192.87	1	DEN	A	77.7	0.6	0.0	0.0	0.0	67.7	1.3	3.8	0.0	0.0	1.0	0.0	93.2	-88.7
2336	618840.03	4778188.88	192.87	1	DEN	A	77.7	4.5	0.0	0.0	0.0	67.4	1.3	3.9	0.0	0.0	0.9	0.0	1.0	7.8
2341	618839.79	4778188.09	192.87	1	DEN	A	77.7	0.7	0.0	0.0	0.0	69.0	1.5	3.6	0.0	0.0	1.3	0.0	82.4	-79.3
2541	618840.28	4778190.58	192.88	0	DEN	A	77.7	-1.2	0.0	0.0	0.0	67.4	1.3	3.9	0.0	0.0	0.8	0.0	0.0	3.2
2548	618840.28	4778190.58	192.88	1	DEN	A	77.7	-1.2	0.0	0.0	0.0	68.1	1.4	3.8	0.0	0.0	21.2	0.0	15.9	-33.9
2554	618840.28	4778190.58	192.88	1	DEN	A	77.7	-1.2	0.0	0.0	0.0	68.0	1.4	3.8	0.0	0.0	8.9	0.0	96.8	-102.3
2560	618840.28	4778190.58	192.88	1	DEN	A	77.7	-1.2	0.0	0.0	0.0	67.7	1.3	3.8	0.0	0.0	8.5	0.0	95.8	-100.7
2565	618840.28	4778190.58	192.88	1	DEN	A	77.7	-1.2	0.0	0.0	0.0	67.4	1.3	3.9	0.0	0.0	0.9	0.0	75.6	-172.6
2571	618840.28	4778190.58	192.88	1	DEN	A	77.7	-1.2	0.0	0.0	0.0	68.4	1.4	3.7	0.0	0.0	21.3	0.0	15.3	-33.6
2577	618840.28	4778190.58	192.88	1	DEN	A	77.7	-1.2	0.0	0.0	0.0	67.7	1.3	3.8	0.0	0.0	1.0	0.0	93.2	-90.5
2584	618840.28	4778190.58	192.88	1	DEN	A	77.7	-1.2	0.0	0.0	0.0	67.4	1.3	3.9	0.0	0.0	0.9	0.0	1.0	2.0
2592	618820.80	4778192.94	192.85	0	DEN	A	77.7	-4.8	0.0	0.0	0.0	67.7	1.3	3.9	0.0	0.0	10.9	0.0	0.0	-10.8
2598	618820.80	4778192.94	192.85	1	DEN	A	77.7	-4.8	0.0	0.0	0.0	68.3	1.4	3.7	0.0	0.0	4.5	0.0	96.5	-101.5
2603	618820.80	4778192.94	192.85	1	DEN	A	77.7	-4.8	0.0	0.0	0.0	68.1	1.4	3.8	0.0	0.0	5.8	0.0	98.0	-104.2
2608	618820.80	4778192.94	192.85	1	DEN	A	77.7	-4.8	0.0	0.0	0.0	68.4	1.4	3.7	0.0	0.0	6.4	0.0	15.9	-23.0
2647	618820.80	4778192.94	192.85	1	DEN	A	77.7	-4.8	0.0	0.0	0.0	67.9	1.3	3.8	0.0	0.0	13.5	0.0	04.7	-118.3
2653	618820.80	4778192.94	192.85	1	DEN	A	77.7	-4.8	0.0	0.0	0.0	68.7	1.5	3.7	0.0	0.0	1.4	0.0	77.7	-80.0

Line Source, ISO 9613, Name: "Truck Route", ID: "I03!TR1"																				
Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)
416	618813.56	4778183.31	192.80	0	D	A	78.2	18.7	0.0	0.0	0.0	67.7	3.3	0.6	0.0	0.0	2.8	0.0	0.0	22.4
416	618813.56	4778183.31	192.80	0	N	A	72.9	18.7	0.0	0.0	0.0	67.7	3.3	0.6	0.0	0.0	2.8	0.0	0.0	17.1
416	618813.56	4778183.31	192.80	0	E	A	72.9	18.7	0.0	0.0	0.0	67.7	3.3	0.6	0.0	0.0	2.8	0.0	0.0	17.1
428	618813.56	4778183.31	192.80	1	D	A	78.2	18.7	0.0	0.0	0.0	68.4	3.5	0.5	0.0	0.0	6.6	0.0	22.9	-5.1
428	618813.56	4778183.31	192.80	1	N	A	72.9	18.7	0.0	0.0	0.0	68.4	3.5	0.5	0.0	0.0	6.6	0.0	22.9	-10.3
428	618813.56	4778183.31	192.80	1	E	A	72.9	18.7	0.0	0.0	0.0	68.4	3.5	0.5	0.0	0.0	6.6	0.0	22.9	-10.3
432	618813.56	4778183.31	192.80	1	D	A	78.2	18.7	0.0	0.0	0.0	68.3	3.4	0.5	0.0	0.0	7.7	0.0	24.7	-7.8
432	618813.56	4778183.31	192.80	1	N	A	72.9	18.7	0.0	0.0	0.0	68.3	3.4	0.5	0.0	0.0	7.7	0.0	24.7	-13.0
432	618813.56	4778183.31	192.80	1	E	A	72.9	18.7	0.0	0.0	0.0	68.3	3.4	0.5	0.0	0.0	7.7	0.0	24.7	-13.0
436	618813.56	4778183.31	192.80	1	D	A	78.2	18.7	0.0	0.0	0.0	68.0	3.4	0.6	0.0	0.0	12.6	0.0	24.9	-12.6
436	618813.56	4778183.31	192.80	1	N	A	72.9	18.7	0.0	0.0	0.0	68.0	3.4	0.6	0.0	0.0	12.6	0.0	24.9	-17.8
436	618813.56	4778183.31	192.80	1	E	A	72.9	18.7	0.0	0.0	0.0	68.0	3.4	0.6	0.0	0.0	12.6	0.0	24.9	-17.8
447	618813.56	4778183.31	192.80	1	D	A	78.2	18.7	0.0	0.0	0.0	67.8	3.3	0.6	0.0	0.0	3.5	0.0	47.8	-26.1
447	618813.56	4778183.31	192.80	1	N	A	72.9	18.7	0.0	0.0	0.0	67.8	3.3	0.6	0.0	0.0	3.5	0.0	47.8	-31.4
447	618813.56	4778183.31	192.80	1	E	A	72.9	18.7	0.0	0.0	0.0	67.8	3.3	0.6	0.0	0.0	3.5	0.0	47.8	-31.4
453	618813.56	4778183.31	192.80	1	D	A	78.2	18.7	0.0	0.0	0.0	68.6	3.5	0.5	0.0	0.0	7.7	0.0	18.9	-2.3
453	618813.56	4778183.31	192.80	1	N	A	72.9	18.7	0.0	0.0	0.0	68.6	3.5	0.5	0.0	0.0	7.7	0.0	18.9	-7.5
453	618813.56	4778183.31	192.80	1	E	A	72.9	18.7	0.0	0.0	0.0	68.6	3.5	0.5	0.0	0.0	7.7	0.0	18.9	-7.5
460	618813.56	4778183.31	192.80	1	D	A	78.2	18.7	0.0	0.0	0.0	68.0	3.4	0.6	0.0	0.0	12.5	0.0	33.4	-21.0
460	618813.56	4778183.31	192.80	1	N	A	72.9	18.7	0.0	0.0	0.0	68.0	3.4	0.6	0.0	0.0	12.5	0.0	33.4	-26.2

Line Source, ISO 9613, Name: "Truck Route", ID: "I03!TR1"

Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)
460	618813.56	4778183.31	192.80	1	E	A	72.9	18.7	0.0	0.0	0.0	68.0	3.4	0.6	0.0	0.0	12.5	0.0	33.4	-26.2
463	618831.14	4778178.08	192.81	1	D	A	78.2	15.7	0.0	0.0	0.0	68.9	3.6	0.5	0.0	0.0	3.8	0.0	4.5	12.5
463	618831.14	4778178.08	192.81	1	N	A	72.9	15.7	0.0	0.0	0.0	68.9	3.6	0.5	0.0	0.0	3.8	0.0	4.5	7.3
463	618831.14	4778178.08	192.81	1	E	A	72.9	15.7	0.0	0.0	0.0	68.9	3.6	0.5	0.0	0.0	3.8	0.0	4.5	7.3
471	618836.54	4778176.47	192.82	2	D	A	78.2	0.8	0.0	0.0	0.0	69.1	3.7	0.5	0.0	0.0	4.8	0.0	12.5	-11.5
471	618836.54	4778176.47	192.82	2	N	A	72.9	0.8	0.0	0.0	0.0	69.1	3.7	0.5	0.0	0.0	4.8	0.0	12.5	-16.7
471	618836.54	4778176.47	192.82	2	E	A	72.9	0.8	0.0	0.0	0.0	69.1	3.7	0.5	0.0	0.0	4.8	0.0	12.5	-16.7
475	618839.18	4778175.69	192.82	2	D	A	78.2	6.3	0.0	0.0	0.0	69.1	3.7	0.5	0.0	0.0	3.7	0.0	10.9	-3.3
475	618839.18	4778175.69	192.82	2	N	A	72.9	6.3	0.0	0.0	0.0	69.1	3.7	0.5	0.0	0.0	3.7	0.0	10.9	-8.6
475	618839.18	4778175.69	192.82	2	E	A	72.9	6.3	0.0	0.0	0.0	69.1	3.7	0.5	0.0	0.0	3.7	0.0	10.9	-8.6
483	618841.32	4778175.05	192.82	2	D	A	78.2	-7.7	0.0	0.0	0.0	69.1	3.7	0.5	0.0	0.0	3.6	0.0	10.9	-17.3
483	618841.32	4778175.05	192.82	2	N	A	72.9	-7.7	0.0	0.0	0.0	69.1	3.7	0.5	0.0	0.0	3.6	0.0	10.9	-22.5
483	618841.32	4778175.05	192.82	2	E	A	72.9	-7.7	0.0	0.0	0.0	69.1	3.7	0.5	0.0	0.0	3.6	0.0	10.9	-22.5
493	618839.85	4778175.49	192.82	1	D	A	78.2	6.3	0.0	0.0	0.0	67.6	3.3	0.6	0.0	0.0	3.5	0.0	4.2	5.3
493	618839.85	4778175.49	192.82	1	N	A	72.9	6.3	0.0	0.0	0.0	67.6	3.3	0.6	0.0	0.0	3.5	0.0	4.2	0.0
493	618839.85	4778175.49	192.82	1	E	A	72.9	6.3	0.0	0.0	0.0	67.6	3.3	0.6	0.0	0.0	3.5	0.0	4.2	0.0
498	618780.45	4778193.15	192.77	1	D	A	78.2	6.6	0.0	0.0	0.0	68.7	3.5	0.5	0.0	0.0	4.2	0.0	10.4	-2.5
498	618780.45	4778193.15	192.77	1	N	A	72.9	6.6	0.0	0.0	0.0	68.7	3.5	0.5	0.0	0.0	4.2	0.0	10.4	-7.8
498	618780.45	4778193.15	192.77	1	E	A	72.9	6.6	0.0	0.0	0.0	68.7	3.5	0.5	0.0	0.0	4.2	0.0	10.4	-7.8
502	618785.55	4778191.64	192.78	1	D	A	78.2	7.8	0.0	0.0	0.0	68.7	3.6	0.5	0.0	0.0	4.0	0.0	10.3	-1.2
502	618785.55	4778191.64	192.78	1	N	A	72.9	7.8	0.0	0.0	0.0	68.7	3.6	0.5	0.0	0.0	4.0	0.0	10.3	-6.4
502	618785.55	4778191.64	192.78	1	E	A	72.9	7.8	0.0	0.0	0.0	68.7	3.6	0.5	0.0	0.0	4.0	0.0	10.3	-6.4
508	618878.60	4778178.02	192.91	0	D	A	78.2	17.8	0.0	0.0	0.0	66.9	3.1	0.7	0.0	0.0	3.3	0.0	0.0	22.0
508	618878.60	4778178.02	192.91	0	N	A	72.9	17.8	0.0	0.0	0.0	66.9	3.1	0.7	0.0	0.0	3.3	0.0	0.0	16.8
508	618878.60	4778178.02	192.91	0	E	A	72.9	17.8	0.0	0.0	0.0	66.9	3.1	0.7	0.0	0.0	3.3	0.0	0.0	16.8
515	618878.60	4778178.02	192.91	1	D	A	78.2	17.8	0.0	0.0	0.0	68.2	3.4	0.5	0.0	0.0	8.2	0.0	17.9	-2.3
515	618878.60	4778178.02	192.91	1	N	A	72.9	17.8	0.0	0.0	0.0	68.2	3.4	0.5	0.0	0.0	8.2	0.0	17.9	-7.5
515	618878.60	4778178.02	192.91	1	E	A	72.9	17.8	0.0	0.0	0.0	68.2	3.4	0.5	0.0	0.0	8.2	0.0	17.9	-7.5
519	618878.60	4778178.02	192.91	1	D	A	78.2	17.8	0.0	0.0	0.0	67.9	3.3	0.6	0.0	0.0	16.4	0.0	20.0	-12.2
519	618878.60	4778178.02	192.91	1	N	A	72.9	17.8	0.0	0.0	0.0	67.9	3.3	0.6	0.0	0.0	16.4	0.0	20.0	-17.4
519	618878.60	4778178.02	192.91	1	E	A	72.9	17.8	0.0	0.0	0.0	67.9	3.3	0.6	0.0	0.0	16.4	0.0	20.0	-17.4
531	618878.60	4778178.02	192.91	1	D	A	78.2	17.8	0.0	0.0	0.0	67.4	3.2	0.6	0.0	0.0	16.9	0.0	18.2	-10.4
531	618878.60	4778178.02	192.91	1	N	A	72.9	17.8	0.0	0.0	0.0	67.4	3.2	0.6	0.0	0.0	16.9	0.0	18.2	-15.6
531	618878.60	4778178.02	192.91	1	E	A	72.9	17.8	0.0	0.0	0.0	67.4	3.2	0.6	0.0	0.0	16.9	0.0	18.2	-15.6
535	618878.60	4778178.02	192.91	1	D	A	78.2	17.8	0.0	0.0	0.0	66.9	3.1	0.7	0.0	0.0	3.7	0.0	12.3	9.3
535	618878.60	4778178.02	192.91	1	N	A	72.9	17.8	0.0	0.0	0.0	66.9	3.1	0.7	0.0	0.0	3.7	0.0	12.3	4.0
535	618878.60	4778178.02	192.91	1	E	A	72.9	17.8	0.0	0.0	0.0	66.9	3.1	0.7	0.0	0.0	3.7	0.0	12.3	4.0
539	618878.60	4778178.02	192.91	1	D	A	78.2	17.8	0.0	0.0	0.0	68.5	3.5	0.5	0.0	0.0	8.1	0.0	17.7	-2.3
539	618878.60	4778178.02	192.91	1	N	A	72.9	17.8	0.0	0.0	0.0	68.5	3.5	0.5	0.0	0.0	8.1	0.0	17.7	-7.6
539	618878.60	4778178.02	192.91	1	E	A	72.9	17.8	0.0	0.0	0.0	68.5	3.5	0.5	0.0	0.0	8.1	0.0	17.7	-7.6
547	618878.60	4778178.02	192.91	1	D	A	78.2	17.8	0.0	0.0	0.0	67.5	3.2	0.6	0.0	0.0	16.8	0.0	18.9	-11.1
547	618878.60	4778178.02	192.91	1	N	A	72.9	17.8	0.0	0.0	0.0	67.5	3.2	0.6	0.0	0.0	16.8	0.0	18.9	-16.3
547	618878.60	4778178.02	192.91	1	E	A	72.9	17.8	0.0	0.0	0.0	67.5	3.2	0.6	0.0	0.0	16.8	0.0	18.9	-16.3
551	618853.88	4778173.68	192.84	1	D	A	78.2	10.1	0.0	0.0	0.0	69.2	3.7	0.5	0.0	0.0	3.6	0.0	9.9	1.3
551	618853.88	4778173.68	192.84	1	N	A	72.9	10.1	0.0	0.0	0.0	69.2	3.7	0.5	0.0	0.0	3.6	0.0	9.9	-3.9
551	618853.88	4778173.68	192.84	1	E	A	72.9	10.1	0.0	0.0	0.0	69.2	3.7	0.5	0.0	0.0	3.6	0.0	9.9	-3.9
559	618860.51	4778174.85	192.86	1	D	A	78.2	5.2	0.0	0.0	0.0	69.2	3.7	0.5	0.0	0.0	3.7	0.0	10.1	-3.8
559	618860.51	4778174.85	192.86	1	N	A	72.9	5.2	0.0	0.0	0.0	69.2	3.7	0.5	0.0	0.0	3.7	0.0	10.1	-9.0
559	618860.51	4778174.85	192.86	1	E	A	72.9	5.2	0.0	0.0	0.0	69.2	3.7	0.5	0.0	0.0	3.7	0.0	10.1	-9.0
563	618862.92	4778175.27	192.87	1	D	A	78.2	2.0	0.0	0.0	0.0	69.2	3.7	0.5	0.0	0.0	3.6	0.0	9.9	-6.7
563	618862.92	4778175.27	192.87	1	N	A	72.9	2.0	0.0	0.0	0.0	69.2	3.7	0.5	0.0	0.0	3.6	0.0	9.9	-12.0
563	618862.92	4778175.27	192.87	1	E	A	72.9	2.0	0.0	0.0	0.0	69.2	3.7	0.5	0.0	0.0	3.6	0.0	9.9	-12.0
567	618866.55	4778175.91	192.88	1	D	A	78.2	7.6	0.0	0.0	0.0	69.3	3.7	0.5	0.0	0.0	3.6	0.0	9.9	-1.1
567	618866.55	4778175.91	192.88	1	N	A	72.9	7.6	0.0	0.0	0.0	69.3	3.7	0.5	0.0	0.0	3.6	0.0	9.9	-6.3
567	618866.55	4778175.91	192.88	1	E	A	72.9	7.6	0.0	0.0	0.0	69.3	3.7	0.5	0.0	0.0	3.6	0.0	9.9	-6.3
584	618900.46	4778181.85	192.98	1	D	A	78.2	9.2	0.0	0.0	0.0	68.6	3.5	0.5	0.0	0.0	4.1	0.0	4.7	5.9
584	618900.46	4778181.85	192.98	1	N	A	72.9	9.2	0.0	0.0	0.0	68.6	3.5	0.5	0.0	0.0	4.1	0.0	4.7	0.7
584	618900.46	4778181.85	192.98	1	E	A	72.9	9.2	0.0	0.0	0.0	68.6	3.5	0.5	0.0	0.0	4.1	0.0	4.7	0.7
590	618906.45	4778182.91	192.99	1	D	A	78.2	5.8	0.0	0.0	0.0	68.7	3.5	0.5	0.0	0.0	4.1	0.0	10.3	-3.1
590	618906.45	4778182.91	192.99	1	N	A	72.9	5.8	0.0	0.0	0.0	68.7	3.5	0.5	0.0	0.0	4.1	0.0	10.3	-8.3
590	618906.45	4778182.91	192.99	1	E	A	72.9	5.8	0.0	0.0	0.0	68.7	3.5	0.5	0.0	0.0	4.1	0.0	10.3	-8.3
672	618959.74	4778205.62	193.00	0	D	A	78.2	15.8	0.0	0.0	0.0	65.8	2.8	0.8	0.0	0.0	6.0	0.0	0.0	18.6
672	618959.74	4778205.62	193.00	0	N	A	72.9	15.8	0.0	0.0	0.0	65.8	2.8	0.8	0.0	0.0	6.0	0.0	0.0	13.3

Line Source, ISO 9613, Name: "Truck Route", ID: "I03!TR1"

Nr.	X	Y	Z	Ref.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)
672	618959.74	4778205.62	193.00	0	E	A	72.9	15.8	0.0	0.0	0.0	65.8	2.8	0.8	0.0	0.0	6.0	0.0	0.0	13.3
676	618959.74	4778205.62	193.00	1	D	A	78.2	15.8	0.0	0.0	0.0	68.3	3.4	0.5	0.0	0.0	11.0	0.0	18.1	-7.5
676	618959.74	4778205.62	193.00	1	N	A	72.9	15.8	0.0	0.0	0.0	68.3	3.4	0.5	0.0	0.0	11.0	0.0	18.1	-12.7
676	618959.74	4778205.62	193.00	1	E	A	72.9	15.8	0.0	0.0	0.0	68.3	3.4	0.5	0.0	0.0	11.0	0.0	18.1	-12.7
679	618959.74	4778205.62	193.00	1	D	A	78.2	15.8	0.0	0.0	0.0	67.8	3.3	0.6	0.0	0.0	10.8	0.0	16.1	-4.6
679	618959.74	4778205.62	193.00	1	N	A	72.9	15.8	0.0	0.0	0.0	67.8	3.3	0.6	0.0	0.0	10.8	0.0	16.1	-9.8
679	618959.74	4778205.62	193.00	1	E	A	72.9	15.8	0.0	0.0	0.0	67.8	3.3	0.6	0.0	0.0	10.8	0.0	16.1	-9.8
682	618959.74	4778205.62	193.00	1	D	A	78.2	15.8	0.0	0.0	0.0	66.9	3.1	0.7	0.0	0.0	3.8	0.0	10.9	8.6
682	618959.74	4778205.62	193.00	1	N	A	72.9	15.8	0.0	0.0	0.0	66.9	3.1	0.7	0.0	0.0	3.8	0.0	10.9	3.4
682	618959.74	4778205.62	193.00	1	E	A	72.9	15.8	0.0	0.0	0.0	66.9	3.1	0.7	0.0	0.0	3.8	0.0	10.9	3.4
688	618959.74	4778205.62	193.00	1	D	A	78.2	15.8	0.0	0.0	0.0	67.1	3.1	0.6	0.0	0.0	3.6	0.0	10.9	8.4
688	618959.74	4778205.62	193.00	1	N	A	72.9	15.8	0.0	0.0	0.0	67.1	3.1	0.6	0.0	0.0	3.6	0.0	10.9	3.2
688	618959.74	4778205.62	193.00	1	E	A	72.9	15.8	0.0	0.0	0.0	67.1	3.1	0.6	0.0	0.0	3.6	0.0	10.9	3.2
693	618959.74	4778205.62	193.00	1	D	A	78.2	15.8	0.0	0.0	0.0	67.5	3.2	0.6	0.0	0.0	3.5	0.0	13.9	5.1
693	618959.74	4778205.62	193.00	1	N	A	72.9	15.8	0.0	0.0	0.0	67.5	3.2	0.6	0.0	0.0	3.5	0.0	13.9	-0.1
693	618959.74	4778205.62	193.00	1	E	A	72.9	15.8	0.0	0.0	0.0	67.5	3.2	0.6	0.0	0.0	3.5	0.0	13.9	-0.1
698	618968.01	4778240.91	193.00	0	D	A	78.2	15.4	0.0	0.0	0.0	65.8	2.8	0.8	0.0	0.0	6.0	0.0	0.0	18.2
698	618968.01	4778240.91	193.00	0	N	A	72.9	15.4	0.0	0.0	0.0	65.8	2.8	0.8	0.0	0.0	6.0	0.0	0.0	13.0
698	618968.01	4778240.91	193.00	0	E	A	72.9	15.4	0.0	0.0	0.0	65.8	2.8	0.8	0.0	0.0	6.0	0.0	0.0	13.0
703	618968.01	4778240.91	193.00	1	D	A	78.2	15.4	0.0	0.0	0.0	68.2	3.4	0.5	0.0	0.0	13.8	0.0	18.4	-10.7
703	618968.01	4778240.91	193.00	1	N	A	72.9	15.4	0.0	0.0	0.0	68.2	3.4	0.5	0.0	0.0	13.8	0.0	18.4	-15.9
703	618968.01	4778240.91	193.00	1	E	A	72.9	15.4	0.0	0.0	0.0	68.2	3.4	0.5	0.0	0.0	13.8	0.0	18.4	-15.9
708	618968.01	4778240.91	193.00	1	D	A	78.2	15.4	0.0	0.0	0.0	67.6	3.3	0.6	0.0	0.0	13.3	0.0	15.9	-7.1
708	618968.01	4778240.91	193.00	1	N	A	72.9	15.4	0.0	0.0	0.0	67.6	3.3	0.6	0.0	0.0	13.3	0.0	15.9	-12.3
708	618968.01	4778240.91	193.00	1	E	A	72.9	15.4	0.0	0.0	0.0	67.6	3.3	0.6	0.0	0.0	13.3	0.0	15.9	-12.3
712	618968.01	4778240.91	193.00	1	D	A	78.2	15.4	0.0	0.0	0.0	66.7	3.0	0.7	0.0	0.0	3.9	0.0	9.2	10.1
712	618968.01	4778240.91	193.00	1	N	A	72.9	15.4	0.0	0.0	0.0	66.7	3.0	0.7	0.0	0.0	3.9	0.0	9.2	4.8
712	618968.01	4778240.91	193.00	1	E	A	72.9	15.4	0.0	0.0	0.0	66.7	3.0	0.7	0.0	0.0	3.9	0.0	9.2	4.8
715	618968.01	4778240.91	193.00	1	D	A	78.2	15.4	0.0	0.0	0.0	67.4	3.2	0.6	0.0	0.0	3.6	0.0	12.2	6.7
715	618968.01	4778240.91	193.00	1	N	A	72.9	15.4	0.0	0.0	0.0	67.4	3.2	0.6	0.0	0.0	3.6	0.0	12.2	1.4
715	618968.01	4778240.91	193.00	1	E	A	72.9	15.4	0.0	0.0	0.0	67.4	3.2	0.6	0.0	0.0	3.6	0.0	12.2	1.4
719	618968.01	4778240.91	193.00	1	D	A	78.2	15.4	0.0	0.0	0.0	67.5	3.2	0.6	0.0	0.0	12.7	0.0	15.9	-6.3
719	618968.01	4778240.91	193.00	1	N	A	72.9	15.4	0.0	0.0	0.0	67.5	3.2	0.6	0.0	0.0	12.7	0.0	15.9	-11.6
719	618968.01	4778240.91	193.00	1	E	A	72.9	15.4	0.0	0.0	0.0	67.5	3.2	0.6	0.0	0.0	12.7	0.0	15.9	-11.6
730	618742.88	4778277.75	193.00	0	D	A	78.2	8.9	0.0	0.0	0.0	68.8	3.6	0.5	0.0	0.0	5.3	0.0	0.0	8.9
730	618742.88	4778277.75	193.00	0	N	A	72.9	8.9	0.0	0.0	0.0	68.8	3.6	0.5	0.0	0.0	5.3	0.0	0.0	3.6
730	618742.88	4778277.75	193.00	0	E	A	72.9	8.9	0.0	0.0	0.0	68.8	3.6	0.5	0.0	0.0	5.3	0.0	0.0	3.6
737	618741.10	4778271.88	193.00	0	D	A	78.2	6.6	0.0	0.0	0.0	68.8	3.6	0.5	0.0	0.0	5.1	0.0	0.0	6.8
737	618741.10	4778271.88	193.00	0	N	A	72.9	6.6	0.0	0.0	0.0	68.8	3.6	0.5	0.0	0.0	5.1	0.0	0.0	1.5
737	618741.10	4778271.88	193.00	0	E	A	72.9	6.6	0.0	0.0	0.0	68.8	3.6	0.5	0.0	0.0	5.1	0.0	0.0	1.5
744	618739.60	4778266.97	193.00	0	D	A	78.2	7.6	0.0	0.0	0.0	68.8	3.6	0.5	0.0	0.0	3.5	0.0	0.0	9.4
744	618739.60	4778266.97	193.00	0	N	A	72.9	7.6	0.0	0.0	0.0	68.8	3.6	0.5	0.0	0.0	3.5	0.0	0.0	4.2
744	618739.60	4778266.97	193.00	0	E	A	72.9	7.6	0.0	0.0	0.0	68.8	3.6	0.5	0.0	0.0	3.5	0.0	0.0	4.2
747	618737.57	4778260.31	193.00	0	D	A	78.2	9.1	0.0	0.0	0.0	68.8	3.6	0.5	0.0	0.0	14.1	0.0	0.0	0.4
747	618737.57	4778260.31	193.00	0	N	A	72.9	9.1	0.0	0.0	0.0	68.8	3.6	0.5	0.0	0.0	14.1	0.0	0.0	-4.9
747	618737.57	4778260.31	193.00	0	E	A	72.9	9.1	0.0	0.0	0.0	68.8	3.6	0.5	0.0	0.0	14.1	0.0	0.0	-4.9
754	618735.28	4778252.78	193.00	0	D	A	78.2	8.8	0.0	0.0	0.0	68.8	3.6	0.5	0.0	0.0	14.2	0.0	0.0	-0.1
754	618735.28	4778252.78	193.00	0	N	A	72.9	8.8	0.0	0.0	0.0	68.8	3.6	0.5	0.0	0.0	14.2	0.0	0.0	-5.4
754	618735.28	4778252.78	193.00	0	E	A	72.9	8.8	0.0	0.0	0.0	68.8	3.6	0.5	0.0	0.0	14.2	0.0	0.0	-5.4
758	618733.81	4778247.94	193.00	0	D	A	78.2	4.1	0.0	0.0	0.0	68.8	3.6	0.5	0.0	0.0	14.2	0.0	0.0	-4.8
758	618733.81	4778247.94	193.00	0	N	A	72.9	4.1	0.0	0.0	0.0	68.8	3.6	0.5	0.0	0.0	14.2	0.0	0.0	-10.0
758	618733.81	4778247.94	193.00	0	E	A	72.9	4.1	0.0	0.0	0.0	68.8	3.6	0.5	0.0	0.0	14.2	0.0	0.0	-10.0
761	618732.94	4778245.08	193.00	0	D	A	78.2	5.3	0.0	0.0	0.0	68.8	3.6	0.5	0.0	0.0	14.1	0.0	0.0	-3.5
761	618732.94	4778245.08	193.00	0	N	A	72.9	5.3	0.0	0.0	0.0	68.8	3.6	0.5	0.0	0.0	14.1	0.0	0.0	-8.8
761	618732.94	4778245.08	193.00	0	E	A	72.9	5.3	0.0	0.0	0.0	68.8	3.6	0.5	0.0	0.0	14.1	0.0	0.0	-8.8
764	618730.50	4778237.07	193.00	0	D	A	78.2	11.2	0.0	0.0	0.0	68.8	3.6	0.5	0.0	0.0	14.1	0.0	0.0	2.4
764	618730.50	4778237.07	193.00	0	N	A	72.9	11.2	0.0	0.0	0.0	68.8	3.6	0.5	0.0	0.0	14.1	0.0	0.0	-2.8
764	618730.50	4778237.07	193.00	0	E	A	72.9	11.2	0.0	0.0	0.0	68.8	3.6	0.5	0.0	0.0	14.1	0.0	0.0	-2.8
770	618727.91	4778228.56	193.00	0	D	A	78.2	6.5	0.0	0.0	0.0	68.8	3.6	0.5	0.0	0.0	13.8	0.0	0.0	-2.1
770	618727.91	4778228.56	193.00	0	N	A	72.9	6.5	0.0	0.0	0.0	68.8	3.6	0.5	0.0	0.0	13.8	0.0	0.0	-7.3
770	618727.91	4778228.56	193.00	0	E	A	72.9	6.5	0.0	0.0	0.0	68.8	3.6	0.5	0.0	0.0	13.8	0.0	0.0	-7.3
776	618726.88	4778225.18	193.00	0	D	A	78.2	4.1	0.0	0.0	0.0	68.8	3.6	0.5	0.0	0.0	13.7	0.0	0.0	-4.3
776	618726.88	4778225.18	193.00	0	N	A	72.9	4.1	0.0	0.0	0.0	68.8	3.6	0.5	0.0	0.0	13.7	0.0	0.0	-9.6

Line Source, ISO 9613, Name: "Truck Route", ID: "I03!TR1"																				
Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)
776	618726.88	4778225.18	193.00	0	E	A	72.9	4.1	0.0	0.0	0.0	68.8	3.6	0.5	0.0	0.0	13.7	0.0	0.0	-9.6
780	618739.46	4778266.50	193.00	1	D	A	78.2	4.4	0.0	0.0	0.0	68.8	3.6	0.5	0.0	0.0	3.5	0.0	30.7	-24.4
780	618739.46	4778266.50	193.00	1	N	A	72.9	4.4	0.0	0.0	0.0	68.8	3.6	0.5	0.0	0.0	3.5	0.0	30.7	-29.7
780	618739.46	4778266.50	193.00	1	E	A	72.9	4.4	0.0	0.0	0.0	68.8	3.6	0.5	0.0	0.0	3.5	0.0	30.7	-29.7
796	618922.33	4778179.36	193.00	0	D	A	78.2	14.6	0.0	0.0	0.0	66.2	2.9	0.8	0.0	0.0	4.4	0.0	0.0	18.5
796	618922.33	4778179.36	193.00	0	N	A	72.9	14.6	0.0	0.0	0.0	66.2	2.9	0.8	0.0	0.0	4.4	0.0	0.0	13.2
796	618922.33	4778179.36	193.00	0	E	A	72.9	14.6	0.0	0.0	0.0	66.2	2.9	0.8	0.0	0.0	4.4	0.0	0.0	13.2
800	618922.33	4778179.36	193.00	1	D	A	78.2	14.6	0.0	0.0	0.0	68.3	3.4	0.5	0.0	0.0	14.6	0.0	19.1	-13.2
800	618922.33	4778179.36	193.00	1	N	A	72.9	14.6	0.0	0.0	0.0	68.3	3.4	0.5	0.0	0.0	14.6	0.0	19.1	-18.4
800	618922.33	4778179.36	193.00	1	E	A	72.9	14.6	0.0	0.0	0.0	68.3	3.4	0.5	0.0	0.0	14.6	0.0	19.1	-18.4
803	618922.33	4778179.36	193.00	1	D	A	78.2	14.6	0.0	0.0	0.0	67.8	3.3	0.6	0.0	0.0	6.5	0.0	15.7	-1.1
803	618922.33	4778179.36	193.00	1	N	A	72.9	14.6	0.0	0.0	0.0	67.8	3.3	0.6	0.0	0.0	6.5	0.0	15.7	-6.4
803	618922.33	4778179.36	193.00	1	E	A	72.9	14.6	0.0	0.0	0.0	67.8	3.3	0.6	0.0	0.0	6.5	0.0	15.7	-6.4
818	618922.33	4778179.36	193.00	1	D	A	78.2	14.6	0.0	0.0	0.0	67.1	3.1	0.6	0.0	0.0	3.6	0.0	12.8	5.5
818	618922.33	4778179.36	193.00	1	N	A	72.9	14.6	0.0	0.0	0.0	67.1	3.1	0.6	0.0	0.0	3.6	0.0	12.8	0.2
818	618922.33	4778179.36	193.00	1	E	A	72.9	14.6	0.0	0.0	0.0	67.1	3.1	0.6	0.0	0.0	3.6	0.0	12.8	0.2
824	618922.33	4778179.36	193.00	1	D	A	78.2	14.6	0.0	0.0	0.0	66.8	3.1	0.7	0.0	0.0	3.8	0.0	8.5	9.9
824	618922.33	4778179.36	193.00	1	N	A	72.9	14.6	0.0	0.0	0.0	66.8	3.1	0.7	0.0	0.0	3.8	0.0	8.5	4.7
824	618922.33	4778179.36	193.00	1	E	A	72.9	14.6	0.0	0.0	0.0	66.8	3.1	0.7	0.0	0.0	3.8	0.0	8.5	4.7
835	618922.33	4778179.36	193.00	1	D	A	78.2	14.6	0.0	0.0	0.0	68.7	3.6	0.5	0.0	0.0	14.9	0.0	19.5	-14.3
835	618922.33	4778179.36	193.00	1	N	A	72.9	14.6	0.0	0.0	0.0	68.7	3.6	0.5	0.0	0.0	14.9	0.0	19.5	-19.5
835	618922.33	4778179.36	193.00	1	E	A	72.9	14.6	0.0	0.0	0.0	68.7	3.6	0.5	0.0	0.0	14.9	0.0	19.5	-19.5
838	618922.33	4778179.36	193.00	1	D	A	78.2	14.6	0.0	0.0	0.0	67.5	3.2	0.6	0.0	0.0	3.5	0.0	14.1	3.8
838	618922.33	4778179.36	193.00	1	N	A	72.9	14.6	0.0	0.0	0.0	67.5	3.2	0.6	0.0	0.0	3.5	0.0	14.1	-1.5
838	618922.33	4778179.36	193.00	1	E	A	72.9	14.6	0.0	0.0	0.0	67.5	3.2	0.6	0.0	0.0	3.5	0.0	14.1	-1.5
844	618711.41	4778190.08	192.95	0	D	A	78.2	11.2	0.0	0.0	0.0	68.9	3.6	0.5	0.0	0.0	3.5	0.0	0.0	12.9
844	618711.41	4778190.08	192.95	0	N	A	72.9	11.2	0.0	0.0	0.0	68.9	3.6	0.5	0.0	0.0	3.5	0.0	0.0	7.6
844	618711.41	4778190.08	192.95	0	E	A	72.9	11.2	0.0	0.0	0.0	68.9	3.6	0.5	0.0	0.0	3.5	0.0	0.0	7.6
884	618735.24	4778183.12	192.82	0	D	A	78.2	15.6	0.0	0.0	0.0	68.7	3.5	0.4	0.0	0.0	1.7	0.0	0.0	19.5
884	618735.24	4778183.12	192.82	0	N	A	72.9	15.6	0.0	0.0	0.0	68.7	3.5	0.4	0.0	0.0	1.7	0.0	0.0	14.3
884	618735.24	4778183.12	192.82	0	E	A	72.9	15.6	0.0	0.0	0.0	68.7	3.5	0.4	0.0	0.0	1.7	0.0	0.0	14.3
890	618785.95	4778303.57	193.22	0	D	A	78.2	2.2	0.0	0.0	0.0	68.4	3.5	0.5	0.0	0.0	11.0	0.0	0.0	-3.0
890	618785.95	4778303.57	193.22	0	N	A	72.9	2.2	0.0	0.0	0.0	68.4	3.5	0.5	0.0	0.0	11.0	0.0	0.0	-8.2
890	618785.95	4778303.57	193.22	0	E	A	72.9	2.2	0.0	0.0	0.0	68.4	3.5	0.5	0.0	0.0	11.0	0.0	0.0	-8.2
897	618778.96	4778299.88	193.19	0	D	A	78.2	11.5	0.0	0.0	0.0	68.4	3.5	0.5	0.0	0.0	10.7	0.0	0.0	6.6
897	618778.96	4778299.88	193.19	0	N	A	72.9	11.5	0.0	0.0	0.0	68.4	3.5	0.5	0.0	0.0	10.7	0.0	0.0	1.3
897	618778.96	4778299.88	193.19	0	E	A	72.9	11.5	0.0	0.0	0.0	68.4	3.5	0.5	0.0	0.0	10.7	0.0	0.0	1.3
904	618771.97	4778296.20	193.15	0	D	A	78.2	2.1	0.0	0.0	0.0	68.5	3.5	0.5	0.0	0.0	14.6	0.0	0.0	-6.9
904	618771.97	4778296.20	193.15	0	N	A	72.9	2.1	0.0	0.0	0.0	68.5	3.5	0.5	0.0	0.0	14.6	0.0	0.0	-12.1
904	618771.97	4778296.20	193.15	0	E	A	72.9	2.1	0.0	0.0	0.0	68.5	3.5	0.5	0.0	0.0	14.6	0.0	0.0	-12.1
919	618770.33	4778295.33	193.14	0	D	A	78.2	3.2	0.0	0.0	0.0	68.5	3.5	0.5	0.0	0.0	14.5	0.0	0.0	-5.7
919	618770.33	4778295.33	193.14	0	N	A	72.9	3.2	0.0	0.0	0.0	68.5	3.5	0.5	0.0	0.0	14.5	0.0	0.0	-10.9
919	618770.33	4778295.33	193.14	0	E	A	72.9	3.2	0.0	0.0	0.0	68.5	3.5	0.5	0.0	0.0	14.5	0.0	0.0	-10.9
927	618767.51	4778293.85	193.12	0	D	A	78.2	6.3	0.0	0.0	0.0	68.5	3.5	0.5	0.0	0.0	14.3	0.0	0.0	-2.4
927	618767.51	4778293.85	193.12	0	N	A	72.9	6.3	0.0	0.0	0.0	68.5	3.5	0.5	0.0	0.0	14.3	0.0	0.0	-7.6
927	618767.51	4778293.85	193.12	0	E	A	72.9	6.3	0.0	0.0	0.0	68.5	3.5	0.5	0.0	0.0	14.3	0.0	0.0	-7.6
931	618765.05	4778292.55	193.11	0	D	A	78.2	1.1	0.0	0.0	0.0	68.6	3.5	0.5	0.0	0.0	14.0	0.0	0.0	-7.4
931	618765.05	4778292.55	193.11	0	N	A	72.9	1.1	0.0	0.0	0.0	68.6	3.5	0.5	0.0	0.0	14.0	0.0	0.0	-12.6
931	618765.05	4778292.55	193.11	0	E	A	72.9	1.1	0.0	0.0	0.0	68.6	3.5	0.5	0.0	0.0	14.0	0.0	0.0	-12.6
939	618763.97	4778291.97	193.11	0	D	A	78.2	0.7	0.0	0.0	0.0	68.6	3.5	0.5	0.0	0.0	13.8	0.0	0.0	-7.6
939	618763.97	4778291.97	193.11	0	N	A	72.9	0.7	0.0	0.0	0.0	68.6	3.5	0.5	0.0	0.0	13.8	0.0	0.0	-12.8
939	618763.97	4778291.97	193.11	0	E	A	72.9	0.7	0.0	0.0	0.0	68.6	3.5	0.5	0.0	0.0	13.8	0.0	0.0	-12.8
945	618762.57	4778291.24	193.10	0	D	A	78.2	3.0	0.0	0.0	0.0	68.6	3.5	0.5	0.0	0.0	10.8	0.0	0.0	-2.3
945	618762.57	4778291.24	193.10	0	N	A	72.9	3.0	0.0	0.0	0.0	68.6	3.5	0.5	0.0	0.0	10.8	0.0	0.0	-7.5
945	618762.57	4778291.24	193.10	0	E	A	72.9	3.0	0.0	0.0	0.0	68.6	3.5	0.5	0.0	0.0	10.8	0.0	0.0	-7.5
952	618760.33	4778290.06	193.09	0	D	A	78.2	4.9	0.0	0.0	0.0	68.6	3.5	0.5	0.0	0.0	10.5	0.0	0.0	-0.1
952	618760.33	4778290.06	193.09	0	N	A	72.9	4.9	0.0	0.0	0.0	68.6	3.5	0.5	0.0	0.0	10.5	0.0	0.0	-5.3
952	618760.33	4778290.06	193.09	0	E	A	72.9	4.9	0.0	0.0	0.0	68.6	3.5	0.5	0.0	0.0	10.5	0.0	0.0	-5.3
956	618758.18	4778288.92	193.08	0	D	A	78.2	2.5	0.0	0.0	0.0	68.6	3.5	0.5	0.0	0.0	9.3	0.0	0.0	-1.3
956	618758.18	4778288.92	193.08	0	N	A	72.9	2.5	0.0	0.0	0.0	68.6	3.5	0.5	0.0	0.0	9.3	0.0	0.0	-6.6
956	618758.18	4778288.92	193.08	0	E	A	72.9	2.5	0.0	0.0	0.0	68.6	3.5	0.5	0.0	0.0	9.3	0.0	0.0	-6.6
960	618756.28	4778287.92	193.07	0	D	A	78.2	4.0	0.0	0.0	0.0	68.7	3.5	0.5	0.0	0.0	11.0	0.0	0.0	-1.5
960	618756.28	4778287.92	193.07	0	N	A	72.9	4.0	0.0	0.0	0.0	68.7	3.5	0.5	0.0	0.0	11.0	0.0	0.0	-6.8

Line Source, ISO 9613, Name: "Truck Route", ID: "I03!TR1"

Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)
960	618756.28	4778287.92	193.07	0	E	A	72.9	4.0	0.0	0.0	0.0	68.7	3.5	0.5	0.0	0.0	11.0	0.0	0.0	-6.8
964	618749.92	4778284.57	193.03	0	D	A	78.2	10.8	0.0	0.0	0.0	68.7	3.6	0.5	0.0	0.0	5.5	0.0	0.0	10.7
964	618749.92	4778284.57	193.03	0	N	A	72.9	10.8	0.0	0.0	0.0	68.7	3.6	0.5	0.0	0.0	5.5	0.0	0.0	5.5
964	618749.92	4778284.57	193.03	0	E	A	72.9	10.8	0.0	0.0	0.0	68.7	3.6	0.5	0.0	0.0	5.5	0.0	0.0	5.5
974	618744.34	4778281.62	193.00	0	D	A	78.2	-1.3	0.0	0.0	0.0	68.8	3.6	0.5	0.0	0.0	5.3	0.0	0.0	-1.3
974	618744.34	4778281.62	193.00	0	N	A	72.9	-1.3	0.0	0.0	0.0	68.8	3.6	0.5	0.0	0.0	5.3	0.0	0.0	-6.5
974	618744.34	4778281.62	193.00	0	E	A	72.9	-1.3	0.0	0.0	0.0	68.8	3.6	0.5	0.0	0.0	5.3	0.0	0.0	-6.5
976	618785.46	4778303.31	193.22	1	D	A	78.2	3.3	0.0	0.0	0.0	68.5	3.5	0.5	0.0	0.0	9.8	0.0	8.0	-9.0
976	618785.46	4778303.31	193.22	1	N	A	72.9	3.3	0.0	0.0	0.0	68.5	3.5	0.5	0.0	0.0	9.8	0.0	8.0	-14.2
976	618785.46	4778303.31	193.22	1	E	A	72.9	3.3	0.0	0.0	0.0	68.5	3.5	0.5	0.0	0.0	9.8	0.0	8.0	-14.2
977	618783.73	4778302.40	193.21	1	D	A	78.2	2.5	0.0	0.0	0.0	68.5	3.5	0.5	0.0	0.0	10.0	0.0	4.2	-6.1
977	618783.73	4778302.40	193.21	1	N	A	72.9	2.5	0.0	0.0	0.0	68.5	3.5	0.5	0.0	0.0	10.0	0.0	4.2	-11.3
977	618783.73	4778302.40	193.21	1	E	A	72.9	2.5	0.0	0.0	0.0	68.5	3.5	0.5	0.0	0.0	10.0	0.0	4.2	-11.3
983	618782.38	4778301.69	193.20	1	D	A	78.2	1.0	0.0	0.0	0.0	68.5	3.5	0.5	0.0	0.0	10.2	0.0	4.3	-7.8
983	618782.38	4778301.69	193.20	1	N	A	72.9	1.0	0.0	0.0	0.0	68.5	3.5	0.5	0.0	0.0	10.2	0.0	4.3	-13.0
983	618782.38	4778301.69	193.20	1	E	A	72.9	1.0	0.0	0.0	0.0	68.5	3.5	0.5	0.0	0.0	10.2	0.0	4.3	-13.0
1628	618972.82	4778259.80	193.01	0	D	A	78.2	6.1	0.0	0.0	0.0	65.8	2.8	0.8	0.0	0.0	5.9	0.0	0.0	8.9
1628	618972.82	4778259.80	193.01	0	N	A	72.9	6.1	0.0	0.0	0.0	65.8	2.8	0.8	0.0	0.0	5.9	0.0	0.0	3.7
1628	618972.82	4778259.80	193.01	0	E	A	72.9	6.1	0.0	0.0	0.0	65.8	2.8	0.8	0.0	0.0	5.9	0.0	0.0	3.7
1632	618972.82	4778259.80	193.01	1	D	A	78.2	6.1	0.0	0.0	0.0	68.2	3.4	0.5	0.0	0.0	12.7	0.0	18.2	-18.8
1632	618972.82	4778259.80	193.01	1	N	A	72.9	6.1	0.0	0.0	0.0	68.2	3.4	0.5	0.0	0.0	12.7	0.0	18.2	-24.1
1632	618972.82	4778259.80	193.01	1	E	A	72.9	6.1	0.0	0.0	0.0	68.2	3.4	0.5	0.0	0.0	12.7	0.0	18.2	-24.1
1634	618972.82	4778259.80	193.01	1	D	A	78.2	6.1	0.0	0.0	0.0	67.6	3.3	0.6	0.0	0.0	12.1	0.0	15.8	-15.1
1634	618972.82	4778259.80	193.01	1	N	A	72.9	6.1	0.0	0.0	0.0	67.6	3.3	0.6	0.0	0.0	12.1	0.0	15.8	-20.3
1634	618972.82	4778259.80	193.01	1	E	A	72.9	6.1	0.0	0.0	0.0	67.6	3.3	0.6	0.0	0.0	12.1	0.0	15.8	-20.3
1639	618972.82	4778259.80	193.01	1	D	A	78.2	6.1	0.0	0.0	0.0	66.7	3.0	0.7	0.0	0.0	3.9	0.0	9.7	0.2
1639	618972.82	4778259.80	193.01	1	N	A	72.9	6.1	0.0	0.0	0.0	66.7	3.0	0.7	0.0	0.0	3.9	0.0	9.7	-5.0
1639	618972.82	4778259.80	193.01	1	E	A	72.9	6.1	0.0	0.0	0.0	66.7	3.0	0.7	0.0	0.0	3.9	0.0	9.7	-5.0
1643	618972.82	4778259.80	193.01	1	D	A	78.2	6.1	0.0	0.0	0.0	67.6	3.3	0.6	0.0	0.0	3.5	0.0	12.9	-3.6
1643	618972.82	4778259.80	193.01	1	N	A	72.9	6.1	0.0	0.0	0.0	67.6	3.3	0.6	0.0	0.0	3.5	0.0	12.9	-8.8
1643	618972.82	4778259.80	193.01	1	E	A	72.9	6.1	0.0	0.0	0.0	67.6	3.3	0.6	0.0	0.0	3.5	0.0	12.9	-8.8
1645	618972.82	4778259.80	193.01	1	D	A	78.2	6.1	0.0	0.0	0.0	67.6	3.3	0.6	0.0	0.0	12.4	0.0	16.3	-15.9
1645	618972.82	4778259.80	193.01	1	N	A	72.9	6.1	0.0	0.0	0.0	67.6	3.3	0.6	0.0	0.0	12.4	0.0	16.3	-21.1
1645	618972.82	4778259.80	193.01	1	E	A	72.9	6.1	0.0	0.0	0.0	67.6	3.3	0.6	0.0	0.0	12.4	0.0	16.3	-21.1
1650	618973.61	4778262.69	193.02	0	D	A	78.2	2.8	0.0	0.0	0.0	65.8	2.8	0.8	0.0	0.0	0.0	0.0	0.0	11.6
1650	618973.61	4778262.69	193.02	0	N	A	72.9	2.8	0.0	0.0	0.0	65.8	2.8	0.8	0.0	0.0	0.0	0.0	0.0	6.3
1650	618973.61	4778262.69	193.02	0	E	A	72.9	2.8	0.0	0.0	0.0	65.8	2.8	0.8	0.0	0.0	0.0	0.0	0.0	6.3
1655	618973.61	4778262.69	193.02	1	D	A	78.2	2.8	0.0	0.0	0.0	68.2	3.4	0.5	0.0	0.0	12.4	0.0	18.2	-21.8
1655	618973.61	4778262.69	193.02	1	N	A	72.9	2.8	0.0	0.0	0.0	68.2	3.4	0.5	0.0	0.0	12.4	0.0	18.2	-27.0
1655	618973.61	4778262.69	193.02	1	E	A	72.9	2.8	0.0	0.0	0.0	68.2	3.4	0.5	0.0	0.0	12.4	0.0	18.2	-27.0
1660	618973.61	4778262.69	193.02	1	D	A	78.2	2.8	0.0	0.0	0.0	67.6	3.3	0.6	0.0	0.0	11.8	0.0	15.8	-18.0
1660	618973.61	4778262.69	193.02	1	N	A	72.9	2.8	0.0	0.0	0.0	67.6	3.3	0.6	0.0	0.0	11.8	0.0	15.8	-23.3
1660	618973.61	4778262.69	193.02	1	E	A	72.9	2.8	0.0	0.0	0.0	67.6	3.3	0.6	0.0	0.0	11.8	0.0	15.8	-23.3
1665	618973.61	4778262.69	193.02	1	D	A	78.2	2.8	0.0	0.0	0.0	66.8	3.1	0.7	0.0	0.0	3.8	0.0	9.9	-3.2
1665	618973.61	4778262.69	193.02	1	N	A	72.9	2.8	0.0	0.0	0.0	66.8	3.1	0.7	0.0	0.0	3.8	0.0	9.9	-8.5
1665	618973.61	4778262.69	193.02	1	E	A	72.9	2.8	0.0	0.0	0.0	66.8	3.1	0.7	0.0	0.0	3.8	0.0	9.9	-8.5
1670	618973.61	4778262.69	193.02	1	D	A	78.2	2.8	0.0	0.0	0.0	67.6	3.3	0.6	0.0	0.0	3.5	0.0	13.0	-7.0
1670	618973.61	4778262.69	193.02	1	N	A	72.9	2.8	0.0	0.0	0.0	67.6	3.3	0.6	0.0	0.0	3.5	0.0	13.0	-12.3
1670	618973.61	4778262.69	193.02	1	E	A	72.9	2.8	0.0	0.0	0.0	67.6	3.3	0.6	0.0	0.0	3.5	0.0	13.0	-12.3
1674	618973.61	4778262.69	193.02	1	D	A	78.2	2.8	0.0	0.0	0.0	67.6	3.3	0.6	0.0	0.0	12.3	0.0	16.3	-19.1
1674	618973.61	4778262.69	193.02	1	N	A	72.9	2.8	0.0	0.0	0.0	67.6	3.3	0.6	0.0	0.0	12.3	0.0	16.3	-24.3
1674	618973.61	4778262.69	193.02	1	E	A	72.9	2.8	0.0	0.0	0.0	67.6	3.3	0.6	0.0	0.0	12.3	0.0	16.3	-24.3
1678	618976.07	4778271.68	193.04	0	D	A	78.2	12.2	0.0	0.0	0.0	65.8	2.8	0.8	0.0	0.0	4.4	0.0	0.0	16.6
1678	618976.07	4778271.68	193.04	0	N	A	72.9	12.2	0.0	0.0	0.0	65.8	2.8	0.8	0.0	0.0	4.4	0.0	0.0	11.4
1678	618976.07	4778271.68	193.04	0	E	A	72.9	12.2	0.0	0.0	0.0	65.8	2.8	0.8	0.0	0.0	4.4	0.0	0.0	11.4
1683	618976.07	4778271.68	193.04	1	D	A	78.2	12.2	0.0	0.0	0.0	68.2	3.4	0.5	0.0	0.0	10.7	0.0	17.9	-10.4
1683	618976.07	4778271.68	193.04	1	N	A	72.9	12.2	0.0	0.0	0.0	68.2	3.4	0.5	0.0	0.0	10.7	0.0	17.9	-15.6
1683	618976.07	4778271.68	193.04	1	E	A	72.9	12.2	0.0	0.0	0.0	68.2	3.4	0.5	0.0	0.0	10.7	0.0	17.9	-15.6
1688	618976.07	4778271.68	193.04	1	D	A	78.2	12.2	0.0	0.0	0.0	67.7	3.3	0.6	0.0	0.0	10.6	0.0	15.7	-7.3
1688	618976.07	4778271.68	193.04	1	N	A	72.9	12.2	0.0	0.0	0.0	67.7	3.3	0.6	0.0	0.0	10.6	0.0	15.7	-12.6
1688	618976.07	4778271.68	193.04	1	E	A	72.9	12.2	0.0	0.0	0.0	67.7	3.3	0.6	0.0	0.0	10.6	0.0	15.7	-12.6
1692	618976.07	4778271.68	193.04	1	D	A	78.2	12.2	0.0	0.0	0.0	66.8	3.1	0.7	0.0	0.0	3.8	0.0	10.6	5.4
1692	618976.07	4778271.68	193.04	1	N	A	72.9	12.2	0.0	0.0	0.0	66.8	3.1	0.7	0.0	0.0	3.8	0.0	10.6	0.2

Line Source, ISO 9613, Name: "Truck Route", ID: "I03!TR1"

Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)
1692	618976.07	4778271.68	193.04	1	E	A	72.9	12.2	0.0	0.0	0.0	66.8	3.1	0.7	0.0	0.0	3.8	0.0	10.6	0.2
1697	618976.07	4778271.68	193.04	1	D	A	78.2	12.2	0.0	0.0	0.0	67.7	3.3	0.6	0.0	0.0	3.5	0.0	15.6	-0.3
1697	618976.07	4778271.68	193.04	1	N	A	72.9	12.2	0.0	0.0	0.0	67.7	3.3	0.6	0.0	0.0	3.5	0.0	15.6	-5.5
1697	618976.07	4778271.68	193.04	1	E	A	72.9	12.2	0.0	0.0	0.0	67.7	3.3	0.6	0.0	0.0	3.5	0.0	15.6	-5.5
1703	618976.07	4778271.68	193.04	1	D	A	78.2	12.2	0.0	0.0	0.0	67.7	3.3	0.6	0.0	0.0	11.4	0.0	16.4	-9.0
1703	618976.07	4778271.68	193.04	1	N	A	72.9	12.2	0.0	0.0	0.0	67.7	3.3	0.6	0.0	0.0	11.4	0.0	16.4	-14.2
1703	618976.07	4778271.68	193.04	1	E	A	72.9	12.2	0.0	0.0	0.0	67.7	3.3	0.6	0.0	0.0	11.4	0.0	16.4	-14.2
1942	618765.46	4778185.91	192.75	0	D	A	78.2	14.8	0.0	0.0	0.0	68.3	3.4	0.6	0.0	0.0	2.5	0.0	0.0	18.1
1942	618765.46	4778185.91	192.75	0	N	A	72.9	14.8	0.0	0.0	0.0	68.3	3.4	0.6	0.0	0.0	2.5	0.0	0.0	12.9
1942	618765.46	4778185.91	192.75	0	E	A	72.9	14.8	0.0	0.0	0.0	68.3	3.4	0.6	0.0	0.0	2.5	0.0	0.0	12.9
1948	618768.35	4778187.70	192.76	1	D	A	78.2	13.5	0.0	0.0	0.0	68.6	3.5	0.5	0.0	0.0	3.5	0.0	4.2	11.3
1948	618768.35	4778187.70	192.76	1	N	A	72.9	13.5	0.0	0.0	0.0	68.6	3.5	0.5	0.0	0.0	3.5	0.0	4.2	6.1
1948	618768.35	4778187.70	192.76	1	E	A	72.9	13.5	0.0	0.0	0.0	68.6	3.5	0.5	0.0	0.0	3.5	0.0	4.2	6.1
1953	618778.08	4778193.71	192.77	1	D	A	78.2	-4.3	0.0	0.0	0.0	68.7	3.5	0.5	0.0	0.0	4.2	0.0	10.5	-13.6
1953	618778.08	4778193.71	192.77	1	N	A	72.9	-4.3	0.0	0.0	0.0	68.7	3.5	0.5	0.0	0.0	4.2	0.0	10.5	-18.8
1953	618778.08	4778193.71	192.77	1	E	A	72.9	-4.3	0.0	0.0	0.0	68.7	3.5	0.5	0.0	0.0	4.2	0.0	10.5	-18.8
2004	618725.74	4778223.53	193.00	0	D	A	78.2	2.4	0.0	0.0	0.0	68.8	3.6	0.5	0.0	0.0	13.3	0.0	0.0	-5.7
2004	618725.74	4778223.53	193.00	0	N	A	72.9	2.4	0.0	0.0	0.0	68.8	3.6	0.5	0.0	0.0	13.3	0.0	0.0	-10.9
2004	618725.74	4778223.53	193.00	0	E	A	72.9	2.4	0.0	0.0	0.0	68.8	3.6	0.5	0.0	0.0	13.3	0.0	0.0	-10.9
2011	618722.75	4778221.90	193.00	0	D	A	78.2	7.1	0.0	0.0	0.0	68.9	3.6	0.5	0.0	0.0	12.2	0.0	0.0	0.1
2011	618722.75	4778221.90	193.00	0	N	A	72.9	7.1	0.0	0.0	0.0	68.9	3.6	0.5	0.0	0.0	12.2	0.0	0.0	-5.1
2011	618722.75	4778221.90	193.00	0	E	A	72.9	7.1	0.0	0.0	0.0	68.9	3.6	0.5	0.0	0.0	12.2	0.0	0.0	-5.1
2030	618719.93	4778220.36	193.00	0	D	A	78.2	1.2	0.0	0.0	0.0	68.9	3.6	0.5	0.0	0.0	11.2	0.0	0.0	-4.8
2030	618719.93	4778220.36	193.00	0	N	A	72.9	1.2	0.0	0.0	0.0	68.9	3.6	0.5	0.0	0.0	11.2	0.0	0.0	-10.1
2030	618719.93	4778220.36	193.00	0	E	A	72.9	1.2	0.0	0.0	0.0	68.9	3.6	0.5	0.0	0.0	11.2	0.0	0.0	-10.1
2037	618718.10	4778219.37	193.00	0	D	A	78.2	4.5	0.0	0.0	0.0	68.9	3.6	0.5	0.0	0.0	10.7	0.0	0.0	-1.0
2037	618718.10	4778219.37	193.00	0	N	A	72.9	4.5	0.0	0.0	0.0	68.9	3.6	0.5	0.0	0.0	10.7	0.0	0.0	-6.2
2037	618718.10	4778219.37	193.00	0	E	A	72.9	4.5	0.0	0.0	0.0	68.9	3.6	0.5	0.0	0.0	10.7	0.0	0.0	-6.2
2044	618711.74	4778215.91	193.00	0	D	A	78.2	10.7	0.0	0.0	0.0	69.0	3.6	0.5	0.0	0.0	8.8	0.0	0.0	6.9
2044	618711.74	4778215.91	193.00	0	N	A	72.9	10.7	0.0	0.0	0.0	69.0	3.6	0.5	0.0	0.0	8.8	0.0	0.0	1.7
2044	618711.74	4778215.91	193.00	0	E	A	72.9	10.7	0.0	0.0	0.0	69.0	3.6	0.5	0.0	0.0	8.8	0.0	0.0	1.7
2050	618705.97	4778212.77	193.00	0	D	A	78.2	1.7	0.0	0.0	0.0	69.0	3.6	0.5	0.0	0.0	4.9	0.0	0.0	1.8
2050	618705.97	4778212.77	193.00	0	N	A	72.9	1.7	0.0	0.0	0.0	69.0	3.6	0.5	0.0	0.0	4.9	0.0	0.0	-3.5
2050	618705.97	4778212.77	193.00	0	E	A	72.9	1.7	0.0	0.0	0.0	69.0	3.6	0.5	0.0	0.0	4.9	0.0	0.0	-3.5
2057	618705.31	4778211.41	193.00	0	D	A	78.2	3.1	0.0	0.0	0.0	69.0	3.6	0.5	0.0	0.0	4.4	0.0	0.0	3.6
2057	618705.31	4778211.41	193.00	0	N	A	72.9	3.1	0.0	0.0	0.0	69.0	3.6	0.5	0.0	0.0	4.4	0.0	0.0	-1.6
2057	618705.31	4778211.41	193.00	0	E	A	72.9	3.1	0.0	0.0	0.0	69.0	3.6	0.5	0.0	0.0	4.4	0.0	0.0	-1.6
2062	618705.29	4778209.75	193.00	0	D	A	78.2	1.1	0.0	0.0	0.0	69.0	3.6	0.5	0.0	0.0	5.4	0.0	0.0	0.7
2062	618705.29	4778209.75	193.00	0	N	A	72.9	1.1	0.0	0.0	0.0	69.0	3.6	0.5	0.0	0.0	5.4	0.0	0.0	-4.5
2062	618705.29	4778209.75	193.00	0	E	A	72.9	1.1	0.0	0.0	0.0	69.0	3.6	0.5	0.0	0.0	5.4	0.0	0.0	-4.5
2069	618705.15	4778200.52	192.99	0	D	A	78.2	12.3	0.0	0.0	0.0	69.0	3.6	0.5	0.0	0.0	4.7	0.0	0.0	12.6
2069	618705.15	4778200.52	192.99	0	N	A	72.9	12.3	0.0	0.0	0.0	69.0	3.6	0.5	0.0	0.0	4.7	0.0	0.0	7.4
2069	618705.15	4778200.52	192.99	0	E	A	72.9	12.3	0.0	0.0	0.0	69.0	3.6	0.5	0.0	0.0	4.7	0.0	0.0	7.4
2076	618953.59	4778183.14	193.00	0	D	A	78.2	9.7	0.0	0.0	0.0	65.8	2.8	0.8	0.0	0.0	5.8	0.0	0.0	12.6
2076	618953.59	4778183.14	193.00	0	N	A	72.9	9.7	0.0	0.0	0.0	65.8	2.8	0.8	0.0	0.0	5.8	0.0	0.0	7.3
2076	618953.59	4778183.14	193.00	0	E	A	72.9	9.7	0.0	0.0	0.0	65.8	2.8	0.8	0.0	0.0	5.8	0.0	0.0	7.3
2082	618953.59	4778183.14	193.00	1	D	A	78.2	9.7	0.0	0.0	0.0	67.9	3.3	0.6	0.0	0.0	8.3	0.0	16.9	-9.1
2082	618953.59	4778183.14	193.00	1	N	A	72.9	9.7	0.0	0.0	0.0	67.9	3.3	0.6	0.0	0.0	8.3	0.0	16.9	-14.4
2082	618953.59	4778183.14	193.00	1	E	A	72.9	9.7	0.0	0.0	0.0	67.9	3.3	0.6	0.0	0.0	8.3	0.0	16.9	-14.4
2089	618953.59	4778183.14	193.00	1	D	A	78.2	9.7	0.0	0.0	0.0	67.1	3.1	0.6	0.0	0.0	3.6	0.0	12.1	1.2
2089	618953.59	4778183.14	193.00	1	N	A	72.9	9.7	0.0	0.0	0.0	67.1	3.1	0.6	0.0	0.0	3.6	0.0	12.1	-4.1
2089	618953.59	4778183.14	193.00	1	E	A	72.9	9.7	0.0	0.0	0.0	67.1	3.1	0.6	0.0	0.0	3.6	0.0	12.1	-4.1
2094	618953.59	4778183.14	193.00	1	D	A	78.2	9.7	0.0	0.0	0.0	67.1	3.1	0.6	0.0	0.0	3.6	0.0	10.8	2.5
2094	618953.59	4778183.14	193.00	1	N	A	72.9	9.7	0.0	0.0	0.0	67.1	3.1	0.6	0.0	0.0	3.6	0.0	10.8	-2.7
2094	618953.59	4778183.14	193.00	1	E	A	72.9	9.7	0.0	0.0	0.0	67.1	3.1	0.6	0.0	0.0	3.6	0.0	10.8	-2.7
2100	618953.59	4778183.14	193.00	1	D	A	78.2	9.7	0.0	0.0	0.0	67.7	3.3	0.6	0.0	0.0	3.5	0.0	14.5	-1.7
2100	618953.59	4778183.14	193.00	1	N	A	72.9	9.7	0.0	0.0	0.0	67.7	3.3	0.6	0.0	0.0	3.5	0.0	14.5	-6.9
2100	618953.59	4778183.14	193.00	1	E	A	72.9	9.7	0.0	0.0	0.0	67.7	3.3	0.6	0.0	0.0	3.5	0.0	14.5	-6.9
2107	618803.48	4778324.22	193.52	0	D	A	78.2	9.3	0.0	0.0	0.0	68.3	3.4	0.5	0.0	0.0	4.2	0.0	0.0	11.1
2107	618803.48	4778324.22	193.52	0	N	A	72.9	9.3	0.0	0.0	0.0	68.3	3.4	0.5	0.0	0.0	4.2	0.0	0.0	5.9
2107	618803.48	4778324.22	193.52	0	E	A	72.9	9.3	0.0	0.0	0.0	68.3	3.4	0.5	0.0	0.0	4.2	0.0	0.0	5.9
2113	618803.48	4778324.22	193.52	1	D	A	78.2	9.3	0.0	0.0	0.0	68.3	3.4	0.5	0.0	0.0	8.9	0.0	33.2	-126.9
2113	618803.48	4778324.22	193.52	1	N	A	72.9	9.3	0.0	0.0	0.0	68.3	3.4	0.5	0.0	0.0	8.9	0.0	33.2	-132.1

Line Source, ISO 9613, Name: "Truck Route", ID: "I03!TR1"																				
Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)
2113	618803.48	4778324.22	193.52	1	E	A	72.9	9.3	0.0	0.0	0.0	68.3	3.4	0.5	0.0	0.0	8.9	0.0	33.2	-132.1
2119	618801.78	4778319.21	193.40	0	D	A	78.2	3.1	0.0	0.0	0.0	68.3	3.4	0.5	0.0	0.0	0.0	0.0	0.0	9.0
2119	618801.78	4778319.21	193.40	0	N	A	72.9	3.1	0.0	0.0	0.0	68.3	3.4	0.5	0.0	0.0	0.0	0.0	0.0	3.8
2119	618801.78	4778319.21	193.40	0	E	A	72.9	3.1	0.0	0.0	0.0	68.3	3.4	0.5	0.0	0.0	0.0	0.0	0.0	3.8
2126	618801.78	4778319.21	193.40	1	D	A	78.2	3.1	0.0	0.0	0.0	68.3	3.4	0.5	0.0	0.0	9.1	0.0	34.2	-134.3
2126	618801.78	4778319.21	193.40	1	N	A	72.9	3.1	0.0	0.0	0.0	68.3	3.4	0.5	0.0	0.0	9.1	0.0	34.2	-139.5
2126	618801.78	4778319.21	193.40	1	E	A	72.9	3.1	0.0	0.0	0.0	68.3	3.4	0.5	0.0	0.0	9.1	0.0	34.2	-139.5
2132	618800.50	4778315.47	193.31	0	D	A	78.2	7.7	0.0	0.0	0.0	68.3	3.4	0.5	0.0	0.0	3.5	0.0	0.0	10.2
2132	618800.50	4778315.47	193.31	0	N	A	72.9	7.7	0.0	0.0	0.0	68.3	3.4	0.5	0.0	0.0	3.5	0.0	0.0	4.9
2132	618800.50	4778315.47	193.31	0	E	A	72.9	7.7	0.0	0.0	0.0	68.3	3.4	0.5	0.0	0.0	3.5	0.0	0.0	4.9
2140	618797.17	4778311.06	193.25	0	D	A	78.2	7.6	0.0	0.0	0.0	68.3	3.4	0.5	0.0	0.0	3.5	0.0	0.0	10.0
2140	618797.17	4778311.06	193.25	0	N	A	72.9	7.6	0.0	0.0	0.0	68.3	3.4	0.5	0.0	0.0	3.5	0.0	0.0	4.8
2140	618797.17	4778311.06	193.25	0	E	A	72.9	7.6	0.0	0.0	0.0	68.3	3.4	0.5	0.0	0.0	3.5	0.0	0.0	4.8
2160	618793.36	4778308.48	193.24	0	D	A	78.2	5.4	0.0	0.0	0.0	68.3	3.4	0.5	0.0	0.0	4.1	0.0	0.0	7.1
2160	618793.36	4778308.48	193.24	0	N	A	72.9	5.4	0.0	0.0	0.0	68.3	3.4	0.5	0.0	0.0	4.1	0.0	0.0	1.9
2160	618793.36	4778308.48	193.24	0	E	A	72.9	5.4	0.0	0.0	0.0	68.3	3.4	0.5	0.0	0.0	4.1	0.0	0.0	1.9
2169	618790.73	4778306.70	193.23	0	D	A	78.2	4.6	0.0	0.0	0.0	68.3	3.5	0.5	0.0	0.0	6.8	0.0	0.0	3.7
2169	618790.73	4778306.70	193.23	0	N	A	72.9	4.6	0.0	0.0	0.0	68.3	3.5	0.5	0.0	0.0	6.8	0.0	0.0	-1.6
2169	618790.73	4778306.70	193.23	0	E	A	72.9	4.6	0.0	0.0	0.0	68.3	3.5	0.5	0.0	0.0	6.8	0.0	0.0	-1.6
2176	618788.51	4778305.20	193.23	0	D	A	78.2	4.0	0.0	0.0	0.0	68.4	3.5	0.5	0.0	0.0	10.7	0.0	0.0	-0.9
2176	618788.51	4778305.20	193.23	0	N	A	72.9	4.0	0.0	0.0	0.0	68.4	3.5	0.5	0.0	0.0	10.7	0.0	0.0	-6.2
2176	618788.51	4778305.20	193.23	0	E	A	72.9	4.0	0.0	0.0	0.0	68.4	3.5	0.5	0.0	0.0	10.7	0.0	0.0	-6.2
2183	618787.08	4778304.23	193.23	0	D	A	78.2	-0.1	0.0	0.0	0.0	68.4	3.5	0.5	0.0	0.0	10.9	0.0	0.0	-5.2
2183	618787.08	4778304.23	193.23	0	N	A	72.9	-0.1	0.0	0.0	0.0	68.4	3.5	0.5	0.0	0.0	10.9	0.0	0.0	-10.4
2183	618787.08	4778304.23	193.23	0	E	A	72.9	-0.1	0.0	0.0	0.0	68.4	3.5	0.5	0.0	0.0	10.9	0.0	0.0	-10.4
2193	618947.70	4778176.84	193.00	0	D	A	78.2	9.4	0.0	0.0	0.0	65.9	2.8	0.8	0.0	0.0	5.5	0.0	0.0	12.5
2193	618947.70	4778176.84	193.00	0	N	A	72.9	9.4	0.0	0.0	0.0	65.9	2.8	0.8	0.0	0.0	5.5	0.0	0.0	7.3
2193	618947.70	4778176.84	193.00	0	E	A	72.9	9.4	0.0	0.0	0.0	65.9	2.8	0.8	0.0	0.0	5.5	0.0	0.0	7.3
2200	618947.70	4778176.84	193.00	1	D	A	78.2	9.4	0.0	0.0	0.0	68.0	3.4	0.6	0.0	0.0	7.7	0.0	16.9	-8.9
2200	618947.70	4778176.84	193.00	1	N	A	72.9	9.4	0.0	0.0	0.0	68.0	3.4	0.6	0.0	0.0	7.7	0.0	16.9	-14.2
2200	618947.70	4778176.84	193.00	1	E	A	72.9	9.4	0.0	0.0	0.0	68.0	3.4	0.6	0.0	0.0	7.7	0.0	16.9	-14.2
2204	618947.70	4778176.84	193.00	1	D	A	78.2	9.4	0.0	0.0	0.0	67.2	3.2	0.6	0.0	0.0	3.6	0.0	12.5	0.5
2204	618947.70	4778176.84	193.00	1	N	A	72.9	9.4	0.0	0.0	0.0	67.2	3.2	0.6	0.0	0.0	3.6	0.0	12.5	-4.8
2204	618947.70	4778176.84	193.00	1	E	A	72.9	9.4	0.0	0.0	0.0	67.2	3.2	0.6	0.0	0.0	3.6	0.0	12.5	-4.8
2208	618947.70	4778176.84	193.00	1	D	A	78.2	9.4	0.0	0.0	0.0	67.1	3.1	0.7	0.0	0.0	3.7	0.0	10.7	2.3
2208	618947.70	4778176.84	193.00	1	N	A	72.9	9.4	0.0	0.0	0.0	67.1	3.1	0.7	0.0	0.0	3.7	0.0	10.7	-2.9
2208	618947.70	4778176.84	193.00	1	E	A	72.9	9.4	0.0	0.0	0.0	67.1	3.1	0.7	0.0	0.0	3.7	0.0	10.7	-2.9
2215	618947.70	4778176.84	193.00	1	D	A	78.2	9.4	0.0	0.0	0.0	67.7	3.3	0.6	0.0	0.0	3.5	0.0	14.6	-2.2
2215	618947.70	4778176.84	193.00	1	N	A	72.9	9.4	0.0	0.0	0.0	67.7	3.3	0.6	0.0	0.0	3.5	0.0	14.6	-7.4
2215	618947.70	4778176.84	193.00	1	E	A	72.9	9.4	0.0	0.0	0.0	67.7	3.3	0.6	0.0	0.0	3.5	0.0	14.6	-7.4
2222	618940.15	4778175.08	193.00	0	D	A	78.2	8.9	0.0	0.0	0.0	66.0	2.9	0.8	0.0	0.0	5.1	0.0	0.0	12.3
2222	618940.15	4778175.08	193.00	0	N	A	72.9	8.9	0.0	0.0	0.0	66.0	2.9	0.8	0.0	0.0	5.1	0.0	0.0	7.1
2222	618940.15	4778175.08	193.00	0	E	A	72.9	8.9	0.0	0.0	0.0	66.0	2.9	0.8	0.0	0.0	5.1	0.0	0.0	7.1
2228	618940.15	4778175.08	193.00	1	D	A	78.2	8.9	0.0	0.0	0.0	67.9	3.3	0.6	0.0	0.0	7.6	0.0	16.8	-9.2
2228	618940.15	4778175.08	193.00	1	N	A	72.9	8.9	0.0	0.0	0.0	67.9	3.3	0.6	0.0	0.0	7.6	0.0	16.8	-14.4
2228	618940.15	4778175.08	193.00	1	E	A	72.9	8.9	0.0	0.0	0.0	67.9	3.3	0.6	0.0	0.0	7.6	0.0	16.8	-14.4
2234	618940.15	4778175.08	193.00	1	D	A	78.2	8.9	0.0	0.0	0.0	67.2	3.2	0.6	0.0	0.0	3.6	0.0	12.6	-0.2
2234	618940.15	4778175.08	193.00	1	N	A	72.9	8.9	0.0	0.0	0.0	67.2	3.2	0.6	0.0	0.0	3.6	0.0	12.6	-5.4
2234	618940.15	4778175.08	193.00	1	E	A	72.9	8.9	0.0	0.0	0.0	67.2	3.2	0.6	0.0	0.0	3.6	0.0	12.6	-5.4
2240	618940.15	4778175.08	193.00	1	D	A	78.2	8.9	0.0	0.0	0.0	67.0	3.1	0.7	0.0	0.0	3.7	0.0	10.1	2.5
2240	618940.15	4778175.08	193.00	1	N	A	72.9	8.9	0.0	0.0	0.0	67.0	3.1	0.7	0.0	0.0	3.7	0.0	10.1	-2.8
2240	618940.15	4778175.08	193.00	1	E	A	72.9	8.9	0.0	0.0	0.0	67.0	3.1	0.7	0.0	0.0	3.7	0.0	10.1	-2.8
2247	618940.15	4778175.08	193.00	1	D	A	78.2	8.9	0.0	0.0	0.0	67.6	3.3	0.6	0.0	0.0	3.5	0.0	14.5	-2.6
2247	618940.15	4778175.08	193.00	1	N	A	72.9	8.9	0.0	0.0	0.0	67.6	3.3	0.6	0.0	0.0	3.5	0.0	14.5	-7.8
2247	618940.15	4778175.08	193.00	1	E	A	72.9	8.9	0.0	0.0	0.0	67.6	3.3	0.6	0.0	0.0	3.5	0.0	14.5	-7.8

Point Source, ISO 9613, Name: "Chiller", ID: "I07!S13B"																				
Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)
598	618952.30	4778218.63	193.50	0	DEN	A	91.6	0.0	0.0	0.0	0.0	65.9	1.6	1.4	0.0	0.0	4.1	0.0	0.0	18.6
604	618952.30	4778218.63	193.50	1	DEN	A	91.6	0.0	0.0	0.0	0.0	68.1	1.9	1.2	0.0	0.0	10.7	0.0	21.3	-11.7
613	618952.30	4778218.63	193.50	1	DEN	A	91.6	0.0	0.0	0.0	0.0	67.6	1.8	1.2	0.0	0.0	10.6	0.0	16.9	-6.5
617	618952.30	4778218.63	193.50	1	DEN	A	91.6	0.0	0.0	0.0	0.0	66.7	1.7	1.3	0.0	0.0	3.3	0.0	10.1	8.5



Point Source, ISO 9613, Name: "Chiller", ID: "I07!S13B"																				
Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)
619	618952.30	4778218.63	193.50	1	DEN	A	91.6	0.0	0.0	0.0	0.0	67.1	1.7	1.3	0.0	0.0	3.2	0.0	12.1	6.2
622	618952.30	4778218.63	193.50	1	DEN	A	91.6	0.0	0.0	0.0	0.0	67.4	1.8	1.2	0.0	0.0	3.2	0.0	13.9	4.1

Point Source, ISO 9613, Name: "Chiller", ID: "I07!S13A"																				
Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)
626	618950.45	4778212.20	193.50	0	DEN	A	91.6	0.0	0.0	0.0	0.0	65.9	1.6	1.4	0.0	0.0	4.0	0.0	0.0	18.6
628	618950.45	4778212.20	193.50	1	DEN	A	91.6	0.0	0.0	0.0	0.0	68.2	1.9	1.2	0.0	0.0	9.7	0.0	21.1	-10.5
631	618950.45	4778212.20	193.50	1	DEN	A	91.6	0.0	0.0	0.0	0.0	67.6	1.8	1.2	0.0	0.0	9.7	0.0	16.9	-5.7
632	618950.45	4778212.20	193.50	1	DEN	A	91.6	0.0	0.0	0.0	0.0	66.7	1.7	1.3	0.0	0.0	3.3	0.0	10.6	7.9
637	618950.45	4778212.20	193.50	1	DEN	A	91.6	0.0	0.0	0.0	0.0	67.0	1.7	1.3	0.0	0.0	3.2	0.0	11.8	6.5
640	618950.45	4778212.20	193.50	1	DEN	A	91.6	0.0	0.0	0.0	0.0	67.4	1.8	1.2	0.0	0.0	3.2	0.0	14.0	4.0

Point Source, ISO 9613, Name: "Truck Idle on Weight Scale", ID: "I07!S11"																				
Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)
644	618962.11	4778222.96	193.00	0	D	A	99.5	0.0	-3.0	0.0	0.0	65.8	2.6	0.4	0.0	0.0	7.1	0.0	0.0	20.6
644	618962.11	4778222.96	193.00	0	N	A	99.5	0.0	-188.0	0.0	0.0	65.8	2.6	0.4	0.0	0.0	7.1	0.0	0.0	-164.4
644	618962.11	4778222.96	193.00	0	E	A	99.5	0.0	-188.0	0.0	0.0	65.8	2.6	0.4	0.0	0.0	7.1	0.0	0.0	-164.4
650	618962.11	4778222.96	193.00	1	D	A	99.5	0.0	-3.0	0.0	0.0	68.2	3.3	0.0	0.0	0.0	16.5	0.0	15.0	-6.5
650	618962.11	4778222.96	193.00	1	N	A	99.5	0.0	-188.0	0.0	0.0	68.2	3.3	0.0	0.0	0.0	16.5	0.0	15.0	-191.5
650	618962.11	4778222.96	193.00	1	E	A	99.5	0.0	-188.0	0.0	0.0	68.2	3.3	0.0	0.0	0.0	16.5	0.0	15.0	-191.5
654	618962.11	4778222.96	193.00	1	D	A	99.5	0.0	-3.0	0.0	0.0	67.6	3.1	0.1	0.0	0.0	15.9	0.0	13.5	-3.7
654	618962.11	4778222.96	193.00	1	N	A	99.5	0.0	-188.0	0.0	0.0	67.6	3.1	0.1	0.0	0.0	15.9	0.0	13.5	-188.7
654	618962.11	4778222.96	193.00	1	E	A	99.5	0.0	-188.0	0.0	0.0	67.6	3.1	0.1	0.0	0.0	15.9	0.0	13.5	-188.7
656	618962.11	4778222.96	193.00	1	D	A	99.5	0.0	-3.0	0.0	0.0	66.7	2.8	0.2	0.0	0.0	4.4	0.0	8.9	13.3
656	618962.11	4778222.96	193.00	1	N	A	99.5	0.0	-188.0	0.0	0.0	66.7	2.8	0.2	0.0	0.0	4.4	0.0	8.9	-171.6
656	618962.11	4778222.96	193.00	1	E	A	99.5	0.0	-188.0	0.0	0.0	66.7	2.8	0.2	0.0	0.0	4.4	0.0	8.9	-171.6
664	618962.11	4778222.96	193.00	1	D	A	99.5	0.0	-3.0	0.0	0.0	67.2	3.0	0.2	0.0	0.0	4.1	0.0	10.6	11.4
664	618962.11	4778222.96	193.00	1	N	A	99.5	0.0	-188.0	0.0	0.0	67.2	3.0	0.2	0.0	0.0	4.1	0.0	10.6	-173.6
664	618962.11	4778222.96	193.00	1	E	A	99.5	0.0	-188.0	0.0	0.0	67.2	3.0	0.2	0.0	0.0	4.1	0.0	10.6	-173.6
667	618962.11	4778222.96	193.00	1	D	A	99.5	0.0	-3.0	0.0	0.0	67.5	3.1	0.1	0.0	0.0	4.1	0.0	13.0	8.8
667	618962.11	4778222.96	193.00	1	N	A	99.5	0.0	-188.0	0.0	0.0	67.5	3.1	0.1	0.0	0.0	4.1	0.0	13.0	-176.2
667	618962.11	4778222.96	193.00	1	E	A	99.5	0.0	-188.0	0.0	0.0	67.5	3.1	0.1	0.0	0.0	4.1	0.0	13.0	-176.2

vert. Area Source, ISO 9613, Name: "Organic Processing Building Bay Door (Open)", ID: "I07!S16F"																				
Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)
1017	618746.09	4778258.72	194.50	0	DEN	A	86.2	6.0	0.0	0.0	0.0	68.7	1.9	2.4	0.0	0.0	20.2	0.0	0.0	-1.0
1022	618746.09	4778258.72	194.50	1	DEN	A	86.2	6.0	0.0	0.0	0.0	68.8	1.9	2.3	0.0	0.0	20.6	0.0	39.9	-141.3
1045	618746.09	4778258.72	191.50	0	DEN	A	86.2	6.0	0.0	0.0	0.0	68.7	1.9	4.4	0.0	0.0	20.3	0.0	0.0	-3.0
1049	618746.09	4778258.72	191.50	1	DEN	A	86.2	6.0	0.0	0.0	0.0	68.8	1.9	4.3	0.0	0.0	20.4	0.0	37.8	-141.1
1056	618746.09	4778258.72	192.50	0	DEN	A	86.2	6.0	0.0	0.0	0.0	68.7	1.9	3.1	0.0	0.0	21.5	0.0	0.0	-3.0
1057	618746.09	4778258.72	192.50	1	DEN	A	86.2	6.0	0.0	0.0	0.0	68.8	1.9	3.0	0.0	0.0	21.6	0.0	38.0	-141.2
1062	618746.09	4778258.72	193.50	0	DEN	A	86.2	6.0	0.0	0.0	0.0	68.7	1.9	2.4	0.0	0.0	21.4	0.0	0.0	-2.3
1072	618746.09	4778258.72	193.50	1	DEN	A	86.2	6.0	0.0	0.0	0.0	68.8	1.9	2.4	0.0	0.0	21.7	0.0	38.7	-141.3

vert. Area Source, ISO 9613, Name: "Organic Processing Building Bay Door (Open)", ID: "I07!S16E"																				
Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)
1080	618744.12	4778251.89	193.50	0	DEN	A	86.2	6.0	0.0	0.0	0.0	68.7	1.9	2.4	0.0	0.0	21.5	0.0	0.0	-2.3
1091	618744.12	4778251.89	192.50	0	DEN	A	86.2	6.0	0.0	0.0	0.0	68.7	1.9	3.1	0.0	0.0	21.5	0.0	0.0	-2.9
1105	618744.12	4778251.89	191.50	0	DEN	A	86.2	6.0	0.0	0.0	0.0	68.7	1.9	4.4	0.0	0.0	20.3	0.0	0.0	-3.0
1115	618744.12	4778251.89	194.50	0	DEN	A	86.2	6.0	0.0	0.0	0.0	68.7	1.9	2.4	0.0	0.0	20.3	0.0	0.0	-1.1

vert. Area Source, ISO 9613, Name: "Organic Processing Building Bay Door (Open)", ID: "I07!S16D"																				
Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)
1126	618742.45	4778246.12	194.50	0	DEN	A	86.2	3.8	0.0	0.0	0.0	68.7	1.9	2.4	0.0	0.0	20.3	0.0	0.0	-3.3
1131	618741.90	4778244.20	194.50	0	DEN	A	86.2	1.9	0.0	0.0	0.0	68.7	1.9	2.4	0.0	0.0	20.3	0.0	0.0	-5.2
1139	618742.45	4778246.12	193.50	0	DEN	A	86.2	3.8	0.0	0.0	0.0	68.7	1.9	2.4	0.0	0.0	21.5	0.0	0.0	-4.5
1144	618741.90	4778244.20	193.50	0	DEN	A	86.2	1.9	0.0	0.0	0.0	68.7	1.9	2.4	0.0	0.0	21.5	0.0	0.0	-6.4
1153	618742.45	4778246.12	192.50	0	DEN	A	86.2	3.8	0.0	0.0	0.0	68.7	1.9	3.1	0.0	0.0	21.5	0.0	0.0	-5.1

vert. Area Source, ISO 9613, Name: "Organic Processing Building Bay Door (Open)", ID: "!07!S16D"																				
Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)
1159	618741.90	4778244.20	192.50	0	DEN	A	86.2	1.9	0.0	0.0	0.0	68.7	1.9	3.1	0.0	0.0	21.4	0.0	0.0	-7.0
1170	618742.45	4778246.12	191.50	0	DEN	A	86.2	3.8	0.0	0.0	0.0	68.7	1.9	4.4	0.0	0.0	20.3	0.0	0.0	-5.2
1178	618741.90	4778244.20	191.50	0	DEN	A	86.2	1.9	0.0	0.0	0.0	68.7	1.9	4.4	0.0	0.0	20.3	0.0	0.0	-7.2

vert. Area Source, ISO 9613, Name: "Organic Processing Building Bay Door (Open)", ID: "!07!S16C"																				
Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)
1189	618740.28	4778238.59	193.50	0	DEN	A	86.2	6.0	0.0	0.0	0.0	68.7	1.9	2.4	0.0	0.0	21.3	0.0	0.0	-2.1
1205	618740.28	4778238.59	192.50	0	DEN	A	86.2	6.0	0.0	0.0	0.0	68.7	1.9	3.1	0.0	0.0	21.4	0.0	0.0	-2.9
1218	618740.28	4778238.59	194.50	0	DEN	A	86.2	6.0	0.0	0.0	0.0	68.7	1.9	2.4	0.0	0.0	20.3	0.0	0.0	-1.1
1231	618740.28	4778238.59	191.50	0	DEN	A	86.2	6.0	0.0	0.0	0.0	68.7	1.9	4.4	0.0	0.0	20.3	0.0	0.0	-3.1

vert. Area Source, ISO 9613, Name: "Organic Processing Building Bay Door (Open)", ID: "!07!S16B"																				
Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)
1245	618735.64	4778222.55	191.50	0	DEN	A	86.1	6.1	0.0	0.0	0.0	68.7	1.9	4.4	0.0	0.0	20.1	0.0	0.0	-2.9
1251	618735.64	4778222.55	193.50	0	DEN	A	86.1	6.1	0.0	0.0	0.0	68.7	1.9	2.4	0.0	0.0	21.1	0.0	0.0	-1.9
1262	618735.64	4778222.55	194.50	0	DEN	A	86.1	6.1	0.0	0.0	0.0	68.7	1.9	2.4	0.0	0.0	20.0	0.0	0.0	-0.8
1276	618735.64	4778222.55	192.50	0	DEN	A	86.1	6.1	0.0	0.0	0.0	68.7	1.9	3.1	0.0	0.0	21.2	0.0	0.0	-2.7

vert. Area Source, ISO 9613, Name: "Organic Processing Building Bay Door (Open)", ID: "!07!S16A"																				
Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)
1283	618733.39	4778214.73	194.50	0	DEN	A	86.2	4.0	0.0	0.0	0.0	68.7	1.9	2.4	0.0	0.0	19.2	0.0	0.0	-2.1
1290	618733.94	4778216.65	194.50	0	DEN	A	86.2	1.7	0.0	0.0	0.0	68.7	1.9	2.4	0.0	0.0	19.6	0.0	0.0	-4.8
1297	618733.39	4778214.73	193.50	0	DEN	A	86.2	4.0	0.0	0.0	0.0	68.7	1.9	2.4	0.0	0.0	20.2	0.0	0.0	-3.0
1301	618733.94	4778216.65	193.50	0	DEN	A	86.2	1.7	0.0	0.0	0.0	68.7	1.9	2.4	0.0	0.0	20.6	0.0	0.0	-5.8
1310	618733.39	4778214.73	192.50	0	DEN	A	86.2	4.0	0.0	0.0	0.0	68.7	1.9	3.1	0.0	0.0	20.3	0.0	0.0	-3.8
1317	618733.94	4778216.65	192.50	0	DEN	A	86.2	1.7	0.0	0.0	0.0	68.7	1.9	3.1	0.0	0.0	20.7	0.0	0.0	-6.6
1322	618733.39	4778214.73	191.50	0	DEN	A	86.2	4.0	0.0	0.0	0.0	68.7	1.9	4.4	0.0	0.0	19.4	0.0	0.0	-4.3
1330	618733.94	4778216.65	191.50	0	DEN	A	86.2	1.7	0.0	0.0	0.0	68.7	1.9	4.4	0.0	0.0	19.8	0.0	0.0	-6.9

Point Source, ISO 9613, Name: "Side Wall Ventilation Fan", ID: "!03!S06B"																				
Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)
1565	618809.24	4778213.67	193.91	0	DEN	A	91.0	0.0	0.0	0.0	0.0	67.8	2.0	2.3	0.0	0.0	17.4	0.0	0.0	1.4
1570	618809.24	4778213.67	193.91	1	DEN	A	91.0	0.0	0.0	0.0	0.0	68.2	2.1	2.3	0.0	0.0	20.5	0.0	24.5	-26.6
1581	618809.24	4778213.67	193.91	1	DEN	A	91.0	0.0	0.0	0.0	0.0	68.1	2.1	2.3	0.0	0.0	20.5	0.0	33.8	-35.7
1586	618809.24	4778213.67	193.91	1	DEN	A	91.0	0.0	0.0	0.0	0.0	68.3	2.1	2.3	0.0	0.0	20.6	0.0	20.0	-22.3
1591	618809.24	4778213.67	193.91	1	DEN	A	91.0	0.0	0.0	0.0	0.0	67.9	2.0	2.3	0.0	0.0	20.4	0.0	55.2	-56.9

Point Source, ISO 9613, Name: "Side Wall Ventilation Fan", ID: "!03!S06A"																				
Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)
1600	618807.67	4778212.65	193.91	0	DEN	A	91.0	0.0	0.0	0.0	0.0	67.9	2.0	2.3	0.0	0.0	10.5	0.0	0.0	8.3
1605	618807.67	4778212.65	193.91	1	DEN	A	91.0	0.0	0.0	0.0	0.0	68.2	2.1	2.3	0.0	0.0	19.0	0.0	26.1	-26.7
1611	618807.67	4778212.65	193.91	1	DEN	A	91.0	0.0	0.0	0.0	0.0	68.1	2.1	2.3	0.0	0.0	18.5	0.0	35.8	-35.8
1616	618807.67	4778212.65	193.91	1	DEN	A	91.0	0.0	0.0	0.0	0.0	68.3	2.1	2.3	0.0	0.0	19.3	0.0	20.6	-21.6
1622	618807.67	4778212.65	193.91	1	DEN	A	91.0	0.0	0.0	0.0	0.0	68.0	2.0	2.3	0.0	0.0	17.7	0.0	58.0	-57.0

Point Source, ISO 9613, Name: "Truck Idle on Weight Scale", ID: "!03!S09"																				
Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)
1709	618771.13	4778292.13	193.00	0	D	A	99.5	0.0	-3.0	0.0	0.0	68.5	3.4	-0.0	0.0	0.0	19.8	0.0	0.0	4.8
1709	618771.13	4778292.13	193.00	0	N	A	99.5	0.0	-188.0	0.0	0.0	68.5	3.4	-0.0	0.0	0.0	19.8	0.0	0.0	-180.2
1709	618771.13	4778292.13	193.00	0	E	A	99.5	0.0	-188.0	0.0	0.0	68.5	3.4	-0.0	0.0	0.0	19.8	0.0	0.0	-180.2

Point Source, ISO 9613, Name: "Agitator Motor (High Pitch)", ID: "!03!S04A"																				
Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)
1716	618808.31	4778210.97	192.40	0	D	A	96.4	0.0	-6.0	0.0	0.0	67.9	5.8	-0.5	0.0	0.0	10.5	0.0	0.0	6.7
1716	618808.31	4778210.97	192.40	0	N	A	96.4	0.0	-6.0	0.0	0.0	67.9	5.8	-0.5	0.0	0.0	10.5	0.0	0.0	6.7
1716	618808.31	4778210.97	192.40	0	E	A	96.4	0.0	-6.0	0.0	0.0	67.9	5.8	-0.5	0.0	0.0	10.5	0.0	0.0	6.7
1721	618808.31	4778210.97	192.40	1	D	A	96.4	0.0	-6.0	0.0	0.0	68.2	6.0	-0.6	0.0	0.0	24.3	0.0	18.5	-26.0

Point Source, ISO 9613, Name: "Agitator Motor (High Pitch)", ID: "I03!S04A"																				
Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)
1721	618808.31	4778210.97	192.40	1	N	A	96.4	0.0	-6.0	0.0	0.0	68.2	6.0	-0.6	0.0	0.0	24.3	0.0	18.5	-26.0
1721	618808.31	4778210.97	192.40	1	E	A	96.4	0.0	-6.0	0.0	0.0	68.2	6.0	-0.6	0.0	0.0	24.3	0.0	18.5	-26.0
1726	618808.31	4778210.97	192.40	1	D	A	96.4	0.0	-6.0	0.0	0.0	68.1	5.9	-0.5	0.0	0.0	24.1	0.0	27.3	-34.6
1726	618808.31	4778210.97	192.40	1	N	A	96.4	0.0	-6.0	0.0	0.0	68.1	5.9	-0.5	0.0	0.0	24.1	0.0	27.3	-34.6
1726	618808.31	4778210.97	192.40	1	E	A	96.4	0.0	-6.0	0.0	0.0	68.1	5.9	-0.5	0.0	0.0	24.1	0.0	27.3	-34.6
1731	618808.31	4778210.97	192.40	1	D	A	96.4	0.0	-6.0	0.0	0.0	68.3	6.0	-0.6	0.0	0.0	24.3	0.0	16.3	-24.1
1731	618808.31	4778210.97	192.40	1	N	A	96.4	0.0	-6.0	0.0	0.0	68.3	6.0	-0.6	0.0	0.0	24.3	0.0	16.3	-24.1
1731	618808.31	4778210.97	192.40	1	E	A	96.4	0.0	-6.0	0.0	0.0	68.3	6.0	-0.6	0.0	0.0	24.3	0.0	16.3	-24.1
1736	618808.31	4778210.97	192.40	1	D	A	96.4	0.0	-6.0	0.0	0.0	68.0	5.9	-0.5	0.0	0.0	23.5	0.0	41.1	-47.6
1736	618808.31	4778210.97	192.40	1	N	A	96.4	0.0	-6.0	0.0	0.0	68.0	5.9	-0.5	0.0	0.0	23.5	0.0	41.1	-47.6
1736	618808.31	4778210.97	192.40	1	E	A	96.4	0.0	-6.0	0.0	0.0	68.0	5.9	-0.5	0.0	0.0	23.5	0.0	41.1	-47.6
1739	618808.31	4778210.97	192.40	1	D	A	96.4	0.0	-6.0	0.0	0.0	67.9	5.8	-0.5	0.0	0.0	10.4	0.0	1.0	5.7
1739	618808.31	4778210.97	192.40	1	N	A	96.4	0.0	-6.0	0.0	0.0	67.9	5.8	-0.5	0.0	0.0	10.4	0.0	1.0	5.7
1739	618808.31	4778210.97	192.40	1	E	A	96.4	0.0	-6.0	0.0	0.0	67.9	5.8	-0.5	0.0	0.0	10.4	0.0	1.0	5.7

Point Source, ISO 9613, Name: "Agitator Motor (High Pitch)", ID: "I03!S04B"																				
Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)
1744	618803.04	4778208.23	192.38	0	D	A	96.4	0.0	-6.0	0.0	0.0	67.9	5.9	-0.5	0.0	0.0	9.6	0.0	0.0	7.4
1744	618803.04	4778208.23	192.38	0	N	A	96.4	0.0	-6.0	0.0	0.0	67.9	5.9	-0.5	0.0	0.0	9.6	0.0	0.0	7.4
1744	618803.04	4778208.23	192.38	0	E	A	96.4	0.0	-6.0	0.0	0.0	67.9	5.9	-0.5	0.0	0.0	9.6	0.0	0.0	7.4
1748	618803.04	4778208.23	192.38	1	D	A	96.4	0.0	-6.0	0.0	0.0	68.3	6.0	-0.6	0.0	0.0	24.0	0.0	19.0	-26.4
1748	618803.04	4778208.23	192.38	1	N	A	96.4	0.0	-6.0	0.0	0.0	68.3	6.0	-0.6	0.0	0.0	24.0	0.0	19.0	-26.4
1748	618803.04	4778208.23	192.38	1	E	A	96.4	0.0	-6.0	0.0	0.0	68.3	6.0	-0.6	0.0	0.0	24.0	0.0	19.0	-26.4
1753	618803.04	4778208.23	192.38	1	D	A	96.4	0.0	-6.0	0.0	0.0	68.4	6.0	-0.6	0.0	0.0	24.1	0.0	17.7	-25.3
1753	618803.04	4778208.23	192.38	1	N	A	96.4	0.0	-6.0	0.0	0.0	68.4	6.0	-0.6	0.0	0.0	24.1	0.0	17.7	-25.3
1753	618803.04	4778208.23	192.38	1	E	A	96.4	0.0	-6.0	0.0	0.0	68.4	6.0	-0.6	0.0	0.0	24.1	0.0	17.7	-25.3
1758	618803.04	4778208.23	192.38	1	D	A	96.4	0.0	-6.0	0.0	0.0	68.0	5.9	-0.5	0.0	0.0	19.5	0.0	45.4	-47.9
1758	618803.04	4778208.23	192.38	1	N	A	96.4	0.0	-6.0	0.0	0.0	68.0	5.9	-0.5	0.0	0.0	19.5	0.0	45.4	-47.9
1758	618803.04	4778208.23	192.38	1	E	A	96.4	0.0	-6.0	0.0	0.0	68.0	5.9	-0.5	0.0	0.0	19.5	0.0	45.4	-47.9
1764	618803.04	4778208.23	192.38	1	D	A	96.4	0.0	-6.0	0.0	0.0	68.5	6.1	-0.6	0.0	0.0	10.8	0.0	1.1	4.5
1764	618803.04	4778208.23	192.38	1	N	A	96.4	0.0	-6.0	0.0	0.0	68.5	6.1	-0.6	0.0	0.0	10.8	0.0	1.1	4.5
1764	618803.04	4778208.23	192.38	1	E	A	96.4	0.0	-6.0	0.0	0.0	68.5	6.1	-0.6	0.0	0.0	10.8	0.0	1.1	4.5

Point Source, ISO 9613, Name: "Agitator Motor (High Pitch)", ID: "I03!S04C"																				
Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)
1769	618798.09	4778209.34	192.37	0	D	A	96.4	0.0	-6.0	0.0	0.0	68.0	5.9	-0.5	0.0	0.0	9.1	0.0	0.0	7.9
1769	618798.09	4778209.34	192.37	0	N	A	96.4	0.0	-6.0	0.0	0.0	68.0	5.9	-0.5	0.0	0.0	9.1	0.0	0.0	7.9
1769	618798.09	4778209.34	192.37	0	E	A	96.4	0.0	-6.0	0.0	0.0	68.0	5.9	-0.5	0.0	0.0	9.1	0.0	0.0	7.9
1774	618798.09	4778209.34	192.37	1	D	A	96.4	0.0	-6.0	0.0	0.0	68.3	6.0	-0.6	0.0	0.0	23.8	0.0	19.4	-26.6
1774	618798.09	4778209.34	192.37	1	N	A	96.4	0.0	-6.0	0.0	0.0	68.3	6.0	-0.6	0.0	0.0	23.8	0.0	19.4	-26.6
1774	618798.09	4778209.34	192.37	1	E	A	96.4	0.0	-6.0	0.0	0.0	68.3	6.0	-0.6	0.0	0.0	23.8	0.0	19.4	-26.6
1779	618798.09	4778209.34	192.37	1	D	A	96.4	0.0	-6.0	0.0	0.0	68.4	6.0	-0.6	0.0	0.0	24.0	0.0	18.1	-25.6
1779	618798.09	4778209.34	192.37	1	N	A	96.4	0.0	-6.0	0.0	0.0	68.4	6.0	-0.6	0.0	0.0	24.0	0.0	18.1	-25.6
1779	618798.09	4778209.34	192.37	1	E	A	96.4	0.0	-6.0	0.0	0.0	68.4	6.0	-0.6	0.0	0.0	24.0	0.0	18.1	-25.6
1787	618798.09	4778209.34	192.37	1	D	A	96.4	0.0	-6.0	0.0	0.0	68.1	5.9	-0.5	0.0	0.0	21.9	0.0	43.4	-48.4
1787	618798.09	4778209.34	192.37	1	N	A	96.4	0.0	-6.0	0.0	0.0	68.1	5.9	-0.5	0.0	0.0	21.9	0.0	43.4	-48.4
1787	618798.09	4778209.34	192.37	1	E	A	96.4	0.0	-6.0	0.0	0.0	68.1	5.9	-0.5	0.0	0.0	21.9	0.0	43.4	-48.4
1792	618798.09	4778209.34	192.37	1	D	A	96.4	0.0	-6.0	0.0	0.0	68.4	6.0	-0.6	0.0	0.0	11.8	0.0	1.1	3.6
1792	618798.09	4778209.34	192.37	1	N	A	96.4	0.0	-6.0	0.0	0.0	68.4	6.0	-0.6	0.0	0.0	11.8	0.0	1.1	3.6
1792	618798.09	4778209.34	192.37	1	E	A	96.4	0.0	-6.0	0.0	0.0	68.4	6.0	-0.6	0.0	0.0	11.8	0.0	1.1	3.6

Point Source, ISO 9613, Name: "Agitator Motor (High Pitch)", ID: "I03!S04D"																				
Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)
1796	618792.79	4778210.92	192.37	0	D	A	96.4	0.0	-6.0	0.0	0.0	68.0	5.9	-0.5	0.0	0.0	8.6	0.0	0.0	8.4
1796	618792.79	4778210.92	192.37	0	N	A	96.4	0.0	-6.0	0.0	0.0	68.0	5.9	-0.5	0.0	0.0	8.6	0.0	0.0	8.4
1796	618792.79	4778210.92	192.37	0	E	A	96.4	0.0	-6.0	0.0	0.0	68.0	5.9	-0.5	0.0	0.0	8.6	0.0	0.0	8.4
1801	618792.79	4778210.92	192.37	1	D	A	96.4	0.0	-6.0	0.0	0.0	68.4	6.0	-0.6	0.0	0.0	23.5	0.0	27.7	-34.6
1801	618792.79	4778210.92	192.37	1	N	A	96.4	0.0	-6.0	0.0	0.0	68.4	6.0	-0.6	0.0	0.0	23.5	0.0	27.7	-34.6
1801	618792.79	4778210.92	192.37	1	E	A	96.4	0.0	-6.0	0.0	0.0	68.4	6.0	-0.6	0.0	0.0	23.5	0.0	27.7	-34.6
1805	618792.79	4778210.92	192.37	1	D	A	96.4	0.0	-6.0	0.0	0.0	68.5	6.0	-0.6	0.0	0.0	24.0	0.0	18.4	-26.0

Point Source, ISO 9613, Name: "Agitator Motor (High Pitch)", ID: "!03!S04D"																				
Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)
1805	618792.79	4778210.92	192.37	1	N	A	96.4	0.0	-6.0	0.0	0.0	68.5	6.0	-0.6	0.0	0.0	24.0	0.0	18.4	-26.0
1805	618792.79	4778210.92	192.37	1	E	A	96.4	0.0	-6.0	0.0	0.0	68.5	6.0	-0.6	0.0	0.0	24.0	0.0	18.4	-26.0
1811	618792.79	4778210.92	192.37	1	D	A	96.4	0.0	-6.0	0.0	0.0	68.1	5.9	-0.5	0.0	0.0	21.9	0.0	44.0	-49.0
1811	618792.79	4778210.92	192.37	1	N	A	96.4	0.0	-6.0	0.0	0.0	68.1	5.9	-0.5	0.0	0.0	21.9	0.0	44.0	-49.0
1811	618792.79	4778210.92	192.37	1	E	A	96.4	0.0	-6.0	0.0	0.0	68.1	5.9	-0.5	0.0	0.0	21.9	0.0	44.0	-49.0
1817	618792.79	4778210.92	192.37	1	D	A	96.4	0.0	-6.0	0.0	0.0	68.4	6.0	-0.6	0.0	0.0	13.2	0.0	1.0	2.4
1817	618792.79	4778210.92	192.37	1	N	A	96.4	0.0	-6.0	0.0	0.0	68.4	6.0	-0.6	0.0	0.0	13.2	0.0	1.0	2.4
1817	618792.79	4778210.92	192.37	1	E	A	96.4	0.0	-6.0	0.0	0.0	68.4	6.0	-0.6	0.0	0.0	13.2	0.0	1.0	2.4

Point Source, ISO 9613, Name: "Side Wall Ventilation Fan", ID: "!03!S08"																				
Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)
1965	618826.46	4778215.44	193.95	0	DEN	A	89.4	0.0	0.0	0.0	0.0	67.6	2.4	1.5	0.0	0.0	7.7	0.0	0.0	10.1
1972	618826.46	4778215.44	193.95	1	DEN	A	89.4	0.0	0.0	0.0	0.0	68.0	2.4	1.4	0.0	0.0	6.9	0.0	23.3	-12.8
1979	618826.46	4778215.44	193.95	1	DEN	A	89.4	0.0	0.0	0.0	0.0	67.9	2.4	1.5	0.0	0.0	4.8	0.0	31.1	-18.3
1984	618826.46	4778215.44	193.95	1	DEN	A	89.4	0.0	0.0	0.0	0.0	67.8	2.4	1.5	0.0	0.0	3.2	0.0	28.9	-14.3
1990	618826.46	4778215.44	193.95	1	DEN	A	89.4	0.0	0.0	0.0	0.0	68.2	2.5	1.4	0.0	0.0	9.5	0.0	18.3	-10.5
1997	618826.46	4778215.44	193.95	1	DEN	A	89.4	0.0	0.0	0.0	0.0	67.7	2.4	1.5	0.0	0.0	3.2	0.0	50.7	-36.2

Point Source, ISO 9613, Name: "Digester Tank Axial Agitator", ID: "!07!S05G"																				
Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)
2346	618897.15	4778236.95	207.00	0	D	A	84.7	0.0	-7.8	0.0	0.0	66.8	5.4	0.7	0.0	0.0	0.0	0.0	0.0	4.0
2346	618897.15	4778236.95	207.00	0	N	A	84.7	0.0	-7.8	0.0	0.0	66.8	5.4	0.7	0.0	0.0	0.0	0.0	0.0	4.0
2346	618897.15	4778236.95	207.00	0	E	A	84.7	0.0	-7.8	0.0	0.0	66.8	5.4	0.7	0.0	0.0	0.0	0.0	0.0	4.0

Point Source, ISO 9613, Name: "Digester Tank Axial Agitator", ID: "!07!S05D"																				
Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)
2352	618900.92	4778260.30	207.03	0	D	A	84.7	0.0	-7.8	0.0	0.0	66.8	5.5	0.7	0.0	0.0	0.0	0.0	0.0	3.9
2352	618900.92	4778260.30	207.03	0	N	A	84.7	0.0	-7.8	0.0	0.0	66.8	5.5	0.7	0.0	0.0	0.0	0.0	0.0	3.9
2352	618900.92	4778260.30	207.03	0	E	A	84.7	0.0	-7.8	0.0	0.0	66.8	5.5	0.7	0.0	0.0	0.0	0.0	0.0	3.9

Point Source, ISO 9613, Name: "Digester Tank Axial Agitator", ID: "!07!S05H"																				
Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)
2357	618895.08	4778246.97	207.00	0	D	A	84.7	0.0	-7.8	0.0	0.0	66.8	5.5	0.7	0.0	0.0	0.0	0.0	0.0	3.9
2357	618895.08	4778246.97	207.00	0	N	A	84.7	0.0	-7.8	0.0	0.0	66.8	5.5	0.7	0.0	0.0	0.0	0.0	0.0	3.9
2357	618895.08	4778246.97	207.00	0	E	A	84.7	0.0	-7.8	0.0	0.0	66.8	5.5	0.7	0.0	0.0	0.0	0.0	0.0	3.9

Point Source, ISO 9613, Name: "Digester Tank Axial Agitator", ID: "!07!S05C"																				
Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)
2362	618896.35	4778269.17	207.11	0	D	A	84.7	0.0	-7.8	0.0	0.0	66.9	5.5	0.7	0.0	0.0	0.0	0.0	0.0	3.8
2362	618896.35	4778269.17	207.11	0	N	A	84.7	0.0	-7.8	0.0	0.0	66.9	5.5	0.7	0.0	0.0	0.0	0.0	0.0	3.8
2362	618896.35	4778269.17	207.11	0	E	A	84.7	0.0	-7.8	0.0	0.0	66.9	5.5	0.7	0.0	0.0	0.0	0.0	0.0	3.8

Point Source, ISO 9613, Name: "Digester Tank Axial Agitator", ID: "!07!S05B"																				
Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)
2368	618880.32	4778266.84	207.12	0	D	A	84.7	0.0	-7.8	0.0	0.0	67.1	5.5	0.7	0.0	0.0	0.0	0.0	0.0	3.6
2368	618880.32	4778266.84	207.12	0	N	A	84.7	0.0	-7.8	0.0	0.0	67.1	5.5	0.7	0.0	0.0	0.0	0.0	0.0	3.6
2368	618880.32	4778266.84	207.12	0	E	A	84.7	0.0	-7.8	0.0	0.0	67.1	5.5	0.7	0.0	0.0	0.0	0.0	0.0	3.6

Point Source, ISO 9613, Name: "Digester Tank Axial Agitator", ID: "!07!S05A"																				
Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)
2374	618872.11	4778273.82	207.19	0	D	A	84.7	0.0	-7.8	0.0	0.0	67.2	5.6	0.7	0.0	0.0	0.0	0.0	0.0	3.4
2374	618872.11	4778273.82	207.19	0	N	A	84.7	0.0	-7.8	0.0	0.0	67.2	5.6	0.7	0.0	0.0	0.0	0.0	0.0	3.4
2374	618872.11	4778273.82	207.19	0	E	A	84.7	0.0	-7.8	0.0	0.0	67.2	5.6	0.7	0.0	0.0	0.0	0.0	0.0	3.4

Point Source, ISO 9613, Name: "Digester Tank Axial Agitator", ID: "I03!S03C"																				
Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)
2382	618846.56	4778230.40	193.00	0	D	A	84.7	0.0	-7.8	0.0	0.0	67.4	5.6	-0.4	0.0	0.0	13.4	0.0	0.0	-9.1
2382	618846.56	4778230.40	193.00	0	N	A	84.7	0.0	-7.8	0.0	0.0	67.4	5.6	-0.4	0.0	0.0	13.4	0.0	0.0	-9.1
2382	618846.56	4778230.40	193.00	0	E	A	84.7	0.0	-7.8	0.0	0.0	67.4	5.6	-0.4	0.0	0.0	13.4	0.0	0.0	-9.1
2388	618846.56	4778230.40	193.00	1	D	A	84.7	0.0	-7.8	0.0	0.0	67.7	5.7	-0.5	0.0	0.0	13.9	0.0	17.1	-27.0
2388	618846.56	4778230.40	193.00	1	N	A	84.7	0.0	-7.8	0.0	0.0	67.7	5.7	-0.5	0.0	0.0	13.9	0.0	17.1	-27.0
2388	618846.56	4778230.40	193.00	1	E	A	84.7	0.0	-7.8	0.0	0.0	67.7	5.7	-0.5	0.0	0.0	13.9	0.0	17.1	-27.0
2393	618846.56	4778230.40	193.00	1	D	A	84.7	0.0	-7.8	0.0	0.0	67.6	5.7	-0.5	0.0	0.0	10.3	0.0	18.8	-25.0
2393	618846.56	4778230.40	193.00	1	N	A	84.7	0.0	-7.8	0.0	0.0	67.6	5.7	-0.5	0.0	0.0	10.3	0.0	18.8	-25.0
2393	618846.56	4778230.40	193.00	1	E	A	84.7	0.0	-7.8	0.0	0.0	67.6	5.7	-0.5	0.0	0.0	10.3	0.0	18.8	-25.0
2399	618846.56	4778230.40	193.00	1	D	A	84.7	0.0	-7.8	0.0	0.0	67.9	5.8	-0.5	0.0	0.0	16.6	0.0	14.3	-27.2
2399	618846.56	4778230.40	193.00	1	N	A	84.7	0.0	-7.8	0.0	0.0	67.9	5.8	-0.5	0.0	0.0	16.6	0.0	14.3	-27.2
2399	618846.56	4778230.40	193.00	1	E	A	84.7	0.0	-7.8	0.0	0.0	67.9	5.8	-0.5	0.0	0.0	16.6	0.0	14.3	-27.2
2403	618846.56	4778230.40	193.00	1	D	A	84.7	0.0	-7.8	0.0	0.0	67.4	5.6	-0.4	0.0	0.0	4.5	0.0	13.7	-113.9
2403	618846.56	4778230.40	193.00	1	N	A	84.7	0.0	-7.8	0.0	0.0	67.4	5.6	-0.4	0.0	0.0	4.5	0.0	13.7	-113.9
2403	618846.56	4778230.40	193.00	1	E	A	84.7	0.0	-7.8	0.0	0.0	67.4	5.6	-0.4	0.0	0.0	4.5	0.0	13.7	-113.9

Point Source, ISO 9613, Name: "Digester Tank Axial Agitator", ID: "I03!S03B"																				
Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)
2409	618844.00	4778218.20	192.98	0	D	A	84.7	0.0	-7.8	0.0	0.0	67.4	5.6	-0.4	0.0	0.0	14.8	0.0	0.0	-10.5
2409	618844.00	4778218.20	192.98	0	N	A	84.7	0.0	-7.8	0.0	0.0	67.4	5.6	-0.4	0.0	0.0	14.8	0.0	0.0	-10.5
2409	618844.00	4778218.20	192.98	0	E	A	84.7	0.0	-7.8	0.0	0.0	67.4	5.6	-0.4	0.0	0.0	14.8	0.0	0.0	-10.5
2415	618844.00	4778218.20	192.98	1	D	A	84.7	0.0	-7.8	0.0	0.0	67.8	5.8	-0.5	0.0	0.0	12.9	0.0	17.2	-26.3
2415	618844.00	4778218.20	192.98	1	N	A	84.7	0.0	-7.8	0.0	0.0	67.8	5.8	-0.5	0.0	0.0	12.9	0.0	17.2	-26.3
2415	618844.00	4778218.20	192.98	1	E	A	84.7	0.0	-7.8	0.0	0.0	67.8	5.8	-0.5	0.0	0.0	12.9	0.0	17.2	-26.3
2420	618844.00	4778218.20	192.98	1	D	A	84.7	0.0	-7.8	0.0	0.0	67.7	5.7	-0.5	0.0	0.0	9.3	0.0	18.4	-23.7
2420	618844.00	4778218.20	192.98	1	N	A	84.7	0.0	-7.8	0.0	0.0	67.7	5.7	-0.5	0.0	0.0	9.3	0.0	18.4	-23.7
2420	618844.00	4778218.20	192.98	1	E	A	84.7	0.0	-7.8	0.0	0.0	67.7	5.7	-0.5	0.0	0.0	9.3	0.0	18.4	-23.7
2425	618844.00	4778218.20	192.98	1	D	A	84.7	0.0	-7.8	0.0	0.0	67.5	5.7	-0.5	0.0	0.0	4.5	0.0	18.2	-18.5
2425	618844.00	4778218.20	192.98	1	N	A	84.7	0.0	-7.8	0.0	0.0	67.5	5.7	-0.5	0.0	0.0	4.5	0.0	18.2	-18.5
2425	618844.00	4778218.20	192.98	1	E	A	84.7	0.0	-7.8	0.0	0.0	67.5	5.7	-0.5	0.0	0.0	4.5	0.0	18.2	-18.5
2429	618844.00	4778218.20	192.98	1	D	A	84.7	0.0	-7.8	0.0	0.0	68.1	5.8	-0.5	0.0	0.0	14.8	0.0	15.0	-26.3
2429	618844.00	4778218.20	192.98	1	N	A	84.7	0.0	-7.8	0.0	0.0	68.1	5.8	-0.5	0.0	0.0	14.8	0.0	15.0	-26.3
2429	618844.00	4778218.20	192.98	1	E	A	84.7	0.0	-7.8	0.0	0.0	68.1	5.8	-0.5	0.0	0.0	14.8	0.0	15.0	-26.3
2435	618844.00	4778218.20	192.98	1	D	A	84.7	0.0	-7.8	0.0	0.0	67.5	5.7	-0.5	0.0	0.0	4.5	0.0	28.1	-28.5
2435	618844.00	4778218.20	192.98	1	N	A	84.7	0.0	-7.8	0.0	0.0	67.5	5.7	-0.5	0.0	0.0	4.5	0.0	28.1	-28.5
2435	618844.00	4778218.20	192.98	1	E	A	84.7	0.0	-7.8	0.0	0.0	67.5	5.7	-0.5	0.0	0.0	4.5	0.0	28.1	-28.5
2439	618844.00	4778218.20	192.98	1	D	A	84.7	0.0	-7.8	0.0	0.0	68.9	6.1	-0.6	0.0	0.0	4.8	0.0	12.1	-14.3
2439	618844.00	4778218.20	192.98	1	N	A	84.7	0.0	-7.8	0.0	0.0	68.9	6.1	-0.6	0.0	0.0	4.8	0.0	12.1	-14.3
2439	618844.00	4778218.20	192.98	1	E	A	84.7	0.0	-7.8	0.0	0.0	68.9	6.1	-0.6	0.0	0.0	4.8	0.0	12.1	-14.3

Point Source, ISO 9613, Name: "Digester Tank Axial Agitator", ID: "I07!S05E"																					
Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr	
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)	
2444	618854.23	4778269.59	207.11	0	D	A	84.7	0.0	-7.8	0.0	0.0	67.4	5.7	0.6	0.0	0.0	0.0	0.0	0.0	3.2	
2444	618854.23	4778269.59	207.11	0	N	A	84.7	0.0	-7.8	0.0	0.0	67.4	5.7	0.6	0.0	0.0	0.0	0.0	0.0	0.0	3.2
2444	618854.23	4778269.59	207.11	0	E	A	84.7	0.0	-7.8	0.0	0.0	67.4	5.7	0.6	0.0	0.0	0.0	0.0	0.0	0.0	3.2

Point Source, ISO 9613, Name: "Digester Tank Axial Agitator", ID: "I07!S05F"																					
Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr	
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)	
2450	618857.09	4778282.14	207.20	0	D	A	84.7	0.0	-7.8	0.0	0.0	67.5	5.7	0.6	0.0	0.0	0.0	0.0	0.0	3.2	
2450	618857.09	4778282.14	207.20	0	N	A	84.7	0.0	-7.8	0.0	0.0	67.5	5.7	0.6	0.0	0.0	0.0	0.0	0.0	0.0	3.2
2450	618857.09	4778282.14	207.20	0	E	A	84.7	0.0	-7.8	0.0	0.0	67.5	5.7	0.6	0.0	0.0	0.0	0.0	0.0	0.0	3.2

Point Source, ISO 9613, Name: "Digester Tank Axial Agitator", ID: "I03!S03D"																				
Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)
2457	618837.58	4778247.16	193.00	0	D	A	84.7	0.0	-7.8	0.0	0.0	67.6	5.7	-0.5	0.0	0.0	14.2	0.0	0.0	-10.1
2457	618837.58	4778247.16	193.00	0	N	A	84.7	0.0	-7.8	0.0	0.0	67.6	5.7	-0.5	0.0	0.0	14.2	0.0	0.0	-10.1
2457	618837.58	4778247.16	193.00	0	E	A	84.7	0.0	-7.8	0.0	0.0	67.6	5.7	-0.5	0.0	0.0	14.2	0.0	0.0	-10.1
2463	618837.58	4778247.16	193.00	1	D	A	84.7	0.0	-7.8	0.0	0.0	67.7	5.7	-0.5	0.0	0.0	9.5	0.0	18.0	-23.5
2463	618837.58	4778247.16	193.00	1	N	A	84.7	0.0	-7.8	0.0	0.0	67.7	5.7	-0.5	0.0	0.0	9.5	0.0	18.0	-23.5

Point Source, ISO 9613, Name: "Digester Tank Axial Agitator", ID: "I03!S03D"																				
Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)
2463	618837.58	4778247.16	193.00	1	E	A	84.7	0.0	-7.8	0.0	0.0	67.7	5.7	-0.5	0.0	0.0	9.5	0.0	18.0	-23.5
2469	618837.58	4778247.16	193.00	1	D	A	84.7	0.0	-7.8	0.0	0.0	67.6	5.7	-0.5	0.0	0.0	9.8	0.0	44.1	-49.8
2469	618837.58	4778247.16	193.00	1	N	A	84.7	0.0	-7.8	0.0	0.0	67.6	5.7	-0.5	0.0	0.0	9.8	0.0	44.1	-49.8
2469	618837.58	4778247.16	193.00	1	E	A	84.7	0.0	-7.8	0.0	0.0	67.6	5.7	-0.5	0.0	0.0	9.8	0.0	44.1	-49.8
2475	618837.58	4778247.16	193.00	1	D	A	84.7	0.0	-7.8	0.0	0.0	67.6	5.7	-0.5	0.0	0.0	4.5	0.0	15.5	-115.9
2475	618837.58	4778247.16	193.00	1	N	A	84.7	0.0	-7.8	0.0	0.0	67.6	5.7	-0.5	0.0	0.0	4.5	0.0	15.5	-115.9
2475	618837.58	4778247.16	193.00	1	E	A	84.7	0.0	-7.8	0.0	0.0	67.6	5.7	-0.5	0.0	0.0	4.5	0.0	15.5	-115.9
2482	618837.58	4778247.16	193.00	1	D	A	84.7	0.0	-7.8	0.0	0.0	67.8	5.8	-0.5	0.0	0.0	18.0	0.0	14.3	-28.5
2482	618837.58	4778247.16	193.00	1	N	A	84.7	0.0	-7.8	0.0	0.0	67.8	5.8	-0.5	0.0	0.0	18.0	0.0	14.3	-28.5
2482	618837.58	4778247.16	193.00	1	E	A	84.7	0.0	-7.8	0.0	0.0	67.8	5.8	-0.5	0.0	0.0	18.0	0.0	14.3	-28.5
2488	618837.58	4778247.16	193.00	1	D	A	84.7	0.0	-7.8	0.0	0.0	68.1	5.8	-0.5	0.0	0.0	4.4	0.0	1.7	-2.6
2488	618837.58	4778247.16	193.00	1	N	A	84.7	0.0	-7.8	0.0	0.0	68.1	5.8	-0.5	0.0	0.0	4.4	0.0	1.7	-2.6
2488	618837.58	4778247.16	193.00	1	E	A	84.7	0.0	-7.8	0.0	0.0	68.1	5.8	-0.5	0.0	0.0	4.4	0.0	1.7	-2.6
2494	618837.58	4778247.16	193.00	2	D	A	84.7	0.0	-7.8	0.0	0.0	68.3	5.9	-0.6	0.0	0.0	4.4	0.0	2.7	-3.9
2494	618837.58	4778247.16	193.00	2	N	A	84.7	0.0	-7.8	0.0	0.0	68.3	5.9	-0.6	0.0	0.0	4.4	0.0	2.7	-3.9
2494	618837.58	4778247.16	193.00	2	E	A	84.7	0.0	-7.8	0.0	0.0	68.3	5.9	-0.6	0.0	0.0	4.4	0.0	2.7	-3.9

Point Source, ISO 9613, Name: "Digester Tank Axial Agitator", ID: "I03!S03A"																				
Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)
2501	618825.72	4778208.69	192.98	0	D	A	84.7	0.0	-7.8	0.0	0.0	67.6	5.7	-0.5	0.0	0.0	11.4	0.0	0.0	-7.3
2501	618825.72	4778208.69	192.98	0	N	A	84.7	0.0	-7.8	0.0	0.0	67.6	5.7	-0.5	0.0	0.0	11.4	0.0	0.0	-7.3
2501	618825.72	4778208.69	192.98	0	E	A	84.7	0.0	-7.8	0.0	0.0	67.6	5.7	-0.5	0.0	0.0	11.4	0.0	0.0	-7.3
2507	618825.72	4778208.69	192.98	1	D	A	84.7	0.0	-7.8	0.0	0.0	68.1	5.8	-0.5	0.0	0.0	10.6	0.0	18.8	-25.9
2507	618825.72	4778208.69	192.98	1	N	A	84.7	0.0	-7.8	0.0	0.0	68.1	5.8	-0.5	0.0	0.0	10.6	0.0	18.8	-25.9
2507	618825.72	4778208.69	192.98	1	E	A	84.7	0.0	-7.8	0.0	0.0	68.1	5.8	-0.5	0.0	0.0	10.6	0.0	18.8	-25.9
2513	618825.72	4778208.69	192.98	1	D	A	84.7	0.0	-7.8	0.0	0.0	68.0	5.8	-0.5	0.0	0.0	7.4	0.0	19.0	-22.7
2513	618825.72	4778208.69	192.98	1	N	A	84.7	0.0	-7.8	0.0	0.0	68.0	5.8	-0.5	0.0	0.0	7.4	0.0	19.0	-22.7
2513	618825.72	4778208.69	192.98	1	E	A	84.7	0.0	-7.8	0.0	0.0	68.0	5.8	-0.5	0.0	0.0	7.4	0.0	19.0	-22.7
2520	618825.72	4778208.69	192.98	1	D	A	84.7	0.0	-7.8	0.0	0.0	67.8	5.8	-0.5	0.0	0.0	4.5	0.0	18.5	-19.1
2520	618825.72	4778208.69	192.98	1	N	A	84.7	0.0	-7.8	0.0	0.0	67.8	5.8	-0.5	0.0	0.0	4.5	0.0	18.5	-19.1
2520	618825.72	4778208.69	192.98	1	E	A	84.7	0.0	-7.8	0.0	0.0	67.8	5.8	-0.5	0.0	0.0	4.5	0.0	18.5	-19.1
2526	618825.72	4778208.69	192.98	1	D	A	84.7	0.0	-7.8	0.0	0.0	68.2	5.9	-0.6	0.0	0.0	12.7	0.0	17.0	-26.4
2526	618825.72	4778208.69	192.98	1	N	A	84.7	0.0	-7.8	0.0	0.0	68.2	5.9	-0.6	0.0	0.0	12.7	0.0	17.0	-26.4
2526	618825.72	4778208.69	192.98	1	E	A	84.7	0.0	-7.8	0.0	0.0	68.2	5.9	-0.6	0.0	0.0	12.7	0.0	17.0	-26.4
2533	618825.72	4778208.69	192.98	1	D	A	84.7	0.0	-7.8	0.0	0.0	67.8	5.7	-0.5	0.0	0.0	4.5	0.0	29.0	-29.5
2533	618825.72	4778208.69	192.98	1	N	A	84.7	0.0	-7.8	0.0	0.0	67.8	5.7	-0.5	0.0	0.0	4.5	0.0	29.0	-29.5
2533	618825.72	4778208.69	192.98	1	E	A	84.7	0.0	-7.8	0.0	0.0	67.8	5.7	-0.5	0.0	0.0	4.5	0.0	29.0	-29.5

vert. Area Source, ISO 9613, Name: "Pump Building Bay Door (Open)", ID: "I03!S17B"																				
Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)
2660	618793.41	4778226.96	193.94	0	DEN	A	66.7	6.3	0.0	0.0	0.0	68.1	6.9	-0.1	0.0	0.0	23.4	0.0	0.0	-25.3
2667	618793.41	4778226.96	193.94	1	DEN	A	66.7	6.3	0.0	0.0	0.0	68.3	7.0	-0.2	0.0	0.0	23.7	0.0	25.5	-51.4
2671	618793.41	4778226.96	193.94	1	DEN	A	66.7	6.3	0.0	0.0	0.0	68.3	7.0	-0.2	0.0	0.0	23.8	0.0	19.1	-45.1
2678	618793.41	4778226.96	193.94	1	DEN	A	66.7	6.3	0.0	0.0	0.0	68.3	7.0	-0.2	0.0	0.0	13.4	0.0	1.1	-16.7
2685	618793.41	4778226.96	192.94	0	DEN	A	66.7	6.3	0.0	0.0	0.0	68.1	6.9	-0.2	0.0	0.0	23.6	0.0	0.0	-25.5
2691	618793.41	4778226.96	192.94	1	DEN	A	66.7	6.3	0.0	0.0	0.0	68.3	7.0	-0.2	0.0	0.0	23.9	0.0	25.3	-51.3
2698	618793.41	4778226.96	192.94	1	DEN	A	66.7	6.3	0.0	0.0	0.0	68.3	7.0	-0.2	0.0	0.0	23.9	0.0	18.9	-45.0
2705	618793.41	4778226.96	192.94	1	DEN	A	66.7	6.3	0.0	0.0	0.0	68.3	7.0	-0.2	0.0	0.0	15.5	0.0	1.1	-18.8
2711	618793.41	4778226.96	191.94	0	DEN	A	66.7	6.3	0.0	0.0	0.0	68.1	6.9	0.2	0.0	0.0	23.6	0.0	0.0	-25.7
2718	618793.41	4778226.96	191.94	1	DEN	A	66.7	6.3	0.0	0.0	0.0	68.3	7.0	0.1	0.0	0.0	23.9	0.0	24.9	-51.2
2724	618793.41	4778226.96	191.94	1	DEN	A	66.7	6.3	0.0	0.0	0.0	68.3	7.0	0.1	0.0	0.0	23.9	0.0	18.9	-45.3
2732	618793.41	4778226.96	191.94	1	DEN	A	66.7	6.3	0.0	0.0	0.0	68.3	7.0	0.1	0.0	0.0	17.1	0.0	1.1	-20.7
2832	618793.41	4778226.96	191.19	0	DEN	A	66.7	3.3	0.0	0.0	0.0	68.1	6.9	0.5	0.0	0.0	23.4	0.0	0.0	-29.0
2839	618793.41	4778226.96	191.19	1	DEN	A	66.7	3.3	0.0	0.0	0.0	68.3	7.0	0.5	0.0	0.0	23.8	0.0	24.5	-54.2
2846	618793.41	4778226.96	191.19	1	DEN	A	66.7	3.3	0.0	0.0	0.0	68.3	7.0	0.5	0.0	0.0	23.8	0.0	18.9	-48.6
2852	618793.41	4778226.96	191.19	1	DEN	A	66.7	3.3	0.0	0.0	0.0	68.3	7.0	0.5	0.0	0.0	18.0	0.0	1.1	-25.1

vert. Area Source, ISO 9613, Name: "Pump Building Bay Door (Open)", ID: "I03!S17A"																				
Nr.	X	Y	Z	Refl.	DEN	Freq.	Lw	l/a	Optime	K0	Di	Adiv	Aatm	Agr	Afol	Ahous	Abar	Cmet	RL	Lr
	(m)	(m)	(m)			(Hz)	dB(A)	dB	dB	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	(dB)	dB(A)
2737	618791.89	4778221.56	192.91	0	DEN	A	66.7	6.3	0.0	0.0	0.0	68.1	6.9	-0.2	0.0	0.0	23.4	0.0	0.0	-25.3

vert. Area Source, ISO 9613, Name: "Pump Building Bay Door (Open)", ID: "!03!S17A"

Nr.	X (m)	Y (m)	Z (m)	Refl.	DEN	Freq. (Hz)	Lw dB(A)	l/a dB	Optime dB	K0 (dB)	Di (dB)	Adiv (dB)	Aatm (dB)	Agr (dB)	Afol (dB)	Ahous (dB)	Abar (dB)	Cmet (dB)	RL (dB)	Lr dB(A)
2744	618791.89	4778221.56	192.91	1	DEN	A	66.7	6.3	0.0	0.0	0.0	68.3	7.0	-0.2	0.0	0.0	23.9	0.0	25.2	-51.3
2749	618791.89	4778221.56	192.91	1	DEN	A	66.7	6.3	0.0	0.0	0.0	68.4	7.0	-0.2	0.0	0.0	23.9	0.0	18.9	-45.1
2754	618791.89	4778221.56	192.91	1	DEN	A	66.7	6.3	0.0	0.0	0.0	68.1	6.9	-0.2	0.0	0.0	23.9	0.0	06.1	-132.0
2761	618791.89	4778221.56	192.91	1	DEN	A	66.7	6.3	0.0	0.0	0.0	68.3	7.0	-0.2	0.0	0.0	15.5	0.0	1.1	-18.8
2768	618791.89	4778221.56	193.91	0	DEN	A	66.7	6.3	0.0	0.0	0.0	68.1	6.9	-0.1	0.0	0.0	23.3	0.0	0.0	-25.2
2774	618791.89	4778221.56	193.91	1	DEN	A	66.7	6.3	0.0	0.0	0.0	68.3	7.0	-0.2	0.0	0.0	23.7	0.0	25.4	-51.3
2781	618791.89	4778221.56	193.91	1	DEN	A	66.7	6.3	0.0	0.0	0.0	68.4	7.0	-0.2	0.0	0.0	23.8	0.0	19.1	-45.2
2787	618791.89	4778221.56	193.91	1	DEN	A	66.7	6.3	0.0	0.0	0.0	68.1	6.9	-0.2	0.0	0.0	23.7	0.0	06.4	-132.1
2794	618791.89	4778221.56	193.91	1	DEN	A	66.7	6.3	0.0	0.0	0.0	68.3	7.0	-0.2	0.0	0.0	13.5	0.0	1.1	-16.7
2801	618791.89	4778221.56	191.91	0	DEN	A	66.7	6.3	0.0	0.0	0.0	68.1	6.9	0.2	0.0	0.0	23.4	0.0	0.0	-25.6
2807	618791.89	4778221.56	191.91	1	DEN	A	66.7	6.3	0.0	0.0	0.0	68.3	7.0	0.1	0.0	0.0	23.9	0.0	24.8	-51.2
2813	618791.89	4778221.56	191.91	1	DEN	A	66.7	6.3	0.0	0.0	0.0	68.4	7.0	0.1	0.0	0.0	23.9	0.0	18.9	-45.3
2818	618791.89	4778221.56	191.91	1	DEN	A	66.7	6.3	0.0	0.0	0.0	68.1	6.9	0.1	0.0	0.0	23.9	0.0	05.8	-131.9
2825	618791.89	4778221.56	191.91	1	DEN	A	66.7	6.3	0.0	0.0	0.0	68.3	7.0	0.1	0.0	0.0	17.1	0.0	1.1	-20.7
2860	618791.89	4778221.56	191.16	0	DEN	A	66.7	3.3	0.0	0.0	0.0	68.1	6.9	0.5	0.0	0.0	23.3	0.0	0.0	-28.9
2865	618791.89	4778221.56	191.16	1	DEN	A	66.7	3.3	0.0	0.0	0.0	68.3	7.0	0.5	0.0	0.0	23.8	0.0	24.4	-54.1
2871	618791.89	4778221.56	191.16	1	DEN	A	66.7	3.3	0.0	0.0	0.0	68.4	7.0	0.5	0.0	0.0	23.8	0.0	18.9	-48.7
2877	618791.89	4778221.56	191.16	1	DEN	A	66.7	3.3	0.0	0.0	0.0	68.1	6.9	0.5	0.0	0.0	23.8	0.0	05.4	-134.8
2885	618791.89	4778221.56	191.16	1	DEN	A	66.7	3.3	0.0	0.0	0.0	68.3	7.0	0.5	0.0	0.0	18.0	0.0	1.1	-25.1

vert. Area Source, ISO 9613, Name: "Pump Building Bay Door (Open)", ID: "!03!S18"

Nr.	X (m)	Y (m)	Z (m)	Refl.	DEN	Freq. (Hz)	Lw dB(A)	l/a dB	Optime dB	K0 (dB)	Di (dB)	Adiv (dB)	Aatm (dB)	Agr (dB)	Afol (dB)	Ahous (dB)	Abar (dB)	Cmet (dB)	RL (dB)	Lr dB(A)
2892	618819.74	4778210.71	191.92	0	DEN	A	62.1	6.3	0.0	0.0	0.0	67.7	4.1	1.3	0.0	0.0	19.9	0.0	0.0	-24.7
2898	618819.74	4778210.71	191.92	1	DEN	A	62.1	6.3	0.0	0.0	0.0	68.1	4.2	1.3	0.0	0.0	22.8	0.0	20.0	-48.0
2905	618819.74	4778210.71	191.92	1	DEN	A	62.1	6.3	0.0	0.0	0.0	68.0	4.2	1.3	0.0	0.0	22.8	0.0	27.1	-55.1
2911	618819.74	4778210.71	191.92	1	DEN	A	62.1	6.3	0.0	0.0	0.0	67.8	4.2	1.3	0.0	0.0	22.8	0.0	21.3	-49.0
2918	618819.74	4778210.71	191.92	1	DEN	A	62.1	6.3	0.0	0.0	0.0	68.3	4.3	1.3	0.0	0.0	22.8	0.0	16.7	-44.9
2924	618819.74	4778210.71	191.92	1	DEN	A	62.1	6.3	0.0	0.0	0.0	67.8	4.2	1.3	0.0	0.0	22.8	0.0	43.3	-71.0
2933	618819.74	4778210.71	192.92	0	DEN	A	62.1	6.3	0.0	0.0	0.0	67.7	4.1	0.8	0.0	0.0	19.9	0.0	0.0	-24.3
2940	618819.74	4778210.71	192.92	1	DEN	A	62.1	6.3	0.0	0.0	0.0	68.1	4.2	0.8	0.0	0.0	23.0	0.0	20.0	-47.7
2946	618819.74	4778210.71	192.92	1	DEN	A	62.1	6.3	0.0	0.0	0.0	68.0	4.2	0.8	0.0	0.0	23.0	0.0	27.5	-55.2
2952	618819.74	4778210.71	192.92	1	DEN	A	62.1	6.3	0.0	0.0	0.0	67.8	4.2	0.8	0.0	0.0	23.0	0.0	21.3	-48.8
2957	618819.74	4778210.71	192.92	1	DEN	A	62.1	6.3	0.0	0.0	0.0	68.3	4.3	0.8	0.0	0.0	23.0	0.0	16.8	-44.7
2962	618819.74	4778210.71	192.92	1	DEN	A	62.1	6.3	0.0	0.0	0.0	67.8	4.2	0.8	0.0	0.0	23.0	0.0	43.7	-71.1
2971	618819.74	4778210.71	193.92	0	DEN	A	62.1	6.3	0.0	0.0	0.0	67.7	4.1	0.8	0.0	0.0	19.7	0.0	0.0	-24.0
2977	618819.74	4778210.71	193.92	1	DEN	A	62.1	6.3	0.0	0.0	0.0	68.1	4.2	0.8	0.0	0.0	22.8	0.0	20.3	-47.8
2984	618819.74	4778210.71	193.92	1	DEN	A	62.1	6.3	0.0	0.0	0.0	68.0	4.2	0.8	0.0	0.0	22.7	0.0	27.9	-55.3
2990	618819.74	4778210.71	193.92	1	DEN	A	62.1	6.3	0.0	0.0	0.0	67.8	4.2	0.8	0.0	0.0	22.7	0.0	21.7	-48.8
2996	618819.74	4778210.71	193.92	1	DEN	A	62.1	6.3	0.0	0.0	0.0	68.3	4.3	0.7	0.0	0.0	22.8	0.0	17.0	-44.8
3002	618819.74	4778210.71	193.92	1	DEN	A	62.1	6.3	0.0	0.0	0.0	67.8	4.2	0.8	0.0	0.0	22.7	0.0	44.1	-71.2
3203	618819.74	4778210.71	191.17	0	DEN	A	62.1	3.3	0.0	0.0	0.0	67.7	4.1	1.8	0.0	0.0	21.9	0.0	0.0	-30.1
3209	618819.74	4778210.71	191.17	1	DEN	A	62.1	3.3	0.0	0.0	0.0	68.1	4.2	1.8	0.0	0.0	22.6	0.0	20.1	-51.4
3216	618819.74	4778210.71	191.17	1	DEN	A	62.1	3.3	0.0	0.0	0.0	68.0	4.2	1.8	0.0	0.0	22.6	0.0	26.8	-58.0
3223	618819.74	4778210.71	191.17	1	DEN	A	62.1	3.3	0.0	0.0	0.0	67.8	4.2	1.8	0.0	0.0	22.6	0.0	21.4	-52.4
3230	618819.74	4778210.71	191.17	1	DEN	A	62.1	3.3	0.0	0.0	0.0	68.3	4.3	1.8	0.0	0.0	22.6	0.0	16.6	-48.2
3236	618819.74	4778210.71	191.17	1	DEN	A	62.1	3.3	0.0	0.0	0.0	67.8	4.2	1.8	0.0	0.0	22.6	0.0	43.0	-74.0

vert. Area Source, ISO 9613, Name: "Skimmer Building Bay Door (Open)", ID: "!03!S19"

Nr.	X (m)	Y (m)	Z (m)	Refl.	DEN	Freq. (Hz)	Lw dB(A)	l/a dB	Optime dB	K0 (dB)	Di (dB)	Adiv (dB)	Aatm (dB)	Agr (dB)	Afol (dB)	Ahous (dB)	Abar (dB)	Cmet (dB)	RL (dB)	Lr dB(A)
3010	618840.14	4778191.09	192.38	0	DEN	A	62.9	4.8	0.0	0.0	0.0	67.4	3.6	0.4	0.0	0.0	3.8	0.0	0.0	-7.5
3016	618840.14	4778191.09	192.38	1	DEN	A	62.9	4.8	0.0	0.0	0.0	68.1	3.8	0.3	0.0	0.0	23.6	0.0	16.6	-44.8
3022	618840.14	4778191.09	192.38	1	DEN	A	62.9	4.8	0.0	0.0	0.0	68.0	3.7	0.3	0.0	0.0	23.5	0.0	18.9	-46.8
3028	618840.14	4778191.09	192.38	1	DEN	A	62.9	4.8	0.0	0.0	0.0	67.7	3.6	0.3	0.0	0.0	13.3	0.0	19.7	-37.0
3034	618840.14	4778191.09	192.38	1	DEN	A	62.9	4.8	0.0	0.0	0.0	67.4	3.6	0.4	0.0	0.0	4.0	0.0	11.9	-119.6
3041	618840.14	4778191.09	192.38	1	DEN	A	62.9	4.8	0.0	0.0	0.0	68.4	3.8	0.3	0.0	0.0	23.6	0.0	16.0	-44.4
3046	618840.14	4778191.09	192.38	1	DEN	A	62.9	4.8	0.0	0.0	0.0	67.7	3.6	0.3	0.0	0.0	3.9	0.0	18.7	-26.6
3054	618840.14	4778191.09	191.38	0	DEN	A	62.9	4.8	0.0	0.0	0.0	67.4	3.6	1.0	0.0	0.0	4.1	0.0	0.0	-8.4
3061	618840.14	4778191.09	191.38	1	DEN	A	62.9	4.8	0.0	0.0	0.0	68.1	3.8	1.0	0.0	0.0	23.4	0.0	16.6	-45.2
3069	618840.14	4778191.09	191.38	1	DEN	A	62.9	4.8	0.0	0.0	0.0	68.0	3.7	1.0	0.0	0.0	23.3	0.0	19.0	-47.3
3076	618840.14	4778191.09	191.38	1	DEN	A	62.9	4.8	0.0	0.0	0.0	67.7	3.6	1.0	0.0	0.0	14.1	0.0	20.2	-39.0
3082	618840.14	4778191.09	191.38	1	DEN	A	62.9	4.8	0.0	0.0	0.0	67.4	3.6	1.0	0.0	0.0	4.2	0.0	11.9	-120.5

vert. Area Source, ISO 9613, Name: "Skimmer Building Bay Door (Open)", ID: "!03!S19"

Nr.	X (m)	Y (m)	Z (m)	Refl.	DEN	Freq. (Hz)	Lw dB(A)	l/a dB	Optime dB	K0 (dB)	Di (dB)	Adiv (dB)	Aatm (dB)	Agr (dB)	Afol (dB)	Ahous (dB)	Abar (dB)	Cmet (dB)	RL (dB)	Lr dB(A)
3089	618840.14	4778191.09	191.38	1	DEN	A	62.9	4.8	0.0	0.0	0.0	68.4	3.8	1.0	0.0	0.0	23.4	0.0	16.0	-44.9
3095	618840.14	4778191.09	191.38	1	DEN	A	62.9	4.8	0.0	0.0	0.0	67.7	3.6	1.0	0.0	0.0	4.1	0.0	18.5	-27.3
3103	618840.14	4778191.09	193.38	0	DEN	A	62.9	4.8	0.0	0.0	0.0	67.4	3.6	0.2	0.0	0.0	3.8	0.0	0.0	-7.4
3110	618840.14	4778191.09	193.38	1	DEN	A	62.9	4.8	0.0	0.0	0.0	68.1	3.8	0.1	0.0	0.0	23.6	0.0	16.7	-44.8
3116	618840.14	4778191.09	193.38	1	DEN	A	62.9	4.8	0.0	0.0	0.0	68.0	3.7	0.2	0.0	0.0	23.6	0.0	19.0	-46.7
3122	618840.14	4778191.09	193.38	1	DEN	A	62.9	4.8	0.0	0.0	0.0	67.7	3.6	0.2	0.0	0.0	12.0	0.0	19.5	-35.4
3129	618840.14	4778191.09	193.38	1	DEN	A	62.9	4.8	0.0	0.0	0.0	67.4	3.6	0.2	0.0	0.0	4.0	0.0	11.5	-119.1
3136	618840.14	4778191.09	193.38	1	DEN	A	62.9	4.8	0.0	0.0	0.0	68.4	3.8	0.1	0.0	0.0	23.6	0.0	16.1	-44.4
3142	618840.14	4778191.09	193.38	1	DEN	A	62.9	4.8	0.0	0.0	0.0	67.7	3.6	0.2	0.0	0.0	4.0	0.0	18.7	-26.5
3150	618840.14	4778191.09	194.38	0	DEN	A	62.9	4.8	0.0	0.0	0.0	67.4	3.6	0.3	0.0	0.0	3.8	0.0	0.0	-7.4
3157	618840.14	4778191.09	194.38	1	DEN	A	62.9	4.8	0.0	0.0	0.0	68.1	3.8	0.2	0.0	0.0	23.5	0.0	16.9	-44.8
3164	618840.14	4778191.09	194.38	1	DEN	A	62.9	4.8	0.0	0.0	0.0	68.0	3.7	0.2	0.0	0.0	23.4	0.0	19.2	-46.8
3171	618840.14	4778191.09	194.38	1	DEN	A	62.9	4.8	0.0	0.0	0.0	67.7	3.6	0.3	0.0	0.0	10.4	0.0	19.3	-33.7
3178	618840.14	4778191.09	194.38	1	DEN	A	62.9	4.8	0.0	0.0	0.0	67.4	3.6	0.3	0.0	0.0	4.0	0.0	11.2	-118.8
3185	618840.14	4778191.09	194.38	1	DEN	A	62.9	4.8	0.0	0.0	0.0	68.4	3.8	0.2	0.0	0.0	23.5	0.0	16.2	-44.5
3192	618840.14	4778191.09	194.38	1	DEN	A	62.9	4.8	0.0	0.0	0.0	67.7	3.6	0.3	0.0	0.0	4.0	0.0	18.7	-26.6





[ghd.com](http://ghd.com)

→ **The Power of Commitment**

# Appendix D

## Change Log



# **Appendix E**

## **Financial Assurance**

# Technical Memorandum

November 10, 2023

<b>To</b>	Sam Huang, Escarpment Renewables	<b>Tel</b>	519-884-0510
<b>From</b>	Jason Wilson	<b>Ref. No.</b>	11226032
<b>Subject</b>	Financial Assurance Estimate - Grimsby Escarpment Renewables Anaerobic Digestion Facility		

## 1. Introduction

Financial Assurance (FA) for the Escarpments Renewables (Escarpment) Anaerobic Digestion (AD) Facility located at 424 Sobie Road, Grimsby Ontario (Site) has been calculated herein in accordance with Guideline F-15 (FA Guideline). Specifically, Section 6.5.5 Private Transfer Stations and Private Waste Processing Sites has been used to develop the required FA presented herein.

## 2. Financial Assurance Calculation

In accordance with the FA Guideline, total FA for a waste processing Site where the planning period is less than four years and there is no known future date for closure, cleanup or remediation is considered to be:

- The cost to remove and properly dispose of all material at licensed disposal facilities
- The cost of remediation, such as construction of a security fence if the site is abandoned
- Contingency costs 10 to 15 percent of the sum of costs for material disposal
- Project management fees 10% of the sum of costs for material disposal
- 13% GST on the cost for material disposal

The Site currently operates an AD facility, which is permitted to received 23,000 tonnes of source separated organics (SSO) and Industrial, Commercial and Institutional (ICI) organic materials per year. The AD facility will be expanded to received 159,000 tonnes per year.

The maximum amount of waste that will be stored on the Site following the AD facility expansion is shown in Table 2.1.

Table 2.1 Waste Storage Quantities

Storage Area	Quantity (m <sup>3</sup> )	Quantity (Tonnes)
<b>Solid Waste</b>		
Tip Floor	1,875	1,220
Residual Waste Trailers	95	76
Grit/Skimmings 1	5	4
Grit/Skimmings 2	9	7

Storage Area	Quantity (m <sup>3</sup> )	Quantity (Tonnes)
Grit/Skimmings 3	9	7
Waste Activated Carbon	6	12
<b>TOTAL</b>	<b>1,999</b>	<b>1326</b>
<b>Liquid Waste</b>		
Existing Receiving Tank 1	493	493
Existing Receiving Tank 2	493	493
Existing Receiving Tank 3	493	493
Existing Digester 1	2,166	2,166
Existing Digester 2	2,166	2,166
New Digester 1	3,435	3,435
New Digester 2	3,435	3,435
New Digester 3	3,435	3,435
New Digester 4	3,435	3,435
<b>TOTAL</b>	<b>19,551</b>	<b>19,551</b>
<b>Digestate</b>		
Existing Digestate Storage Tank 1	4,029	4,029
Existing Digestate Storage Tank 2	4,029	4,029
Digestate Storage Tank 3	8,000	8,000
Digestate Storage Tank 4	8,000	8,000
<b>TOTAL</b>	<b>24,058</b>	<b>24,058</b>

The loading, transportation, and disposal costs are provided in Table 2.2, below.

Table 2.2 Unit Costs

Material Type	Loading and Disposal Cost (\$/tonne)	Transportation Cost (\$/tonne)	Total (\$/tonne)
Solid Waste – Tip Floor	\$56	\$10.20	\$66.20
Solid Waste – Residual, Grit and Skimmings	\$100.00	\$12.28	\$112.28
Liquid Waste	\$10.00	\$14.20	\$24.20
Digestate	\$3.75	\$2.90	\$6.65

The costs for transportation and disposal in Table 2.2 are based on quotes provided in Attachment A. For the purpose of the calculation, the following is noted:

- Transportation costs per tonne for Liquid Waste and Solid Waste were calculated by first determining the number of trips required based on the information provided by Stormfisher and Advantage Waste Systems. Secondly the number of tonnes per trip was determined (~35 m<sup>3</sup> and 15 m<sup>3</sup> respectively) and finally the cost per tonne for transportation was determined.
- Solid Waste from the tip floor would require a front-end loader to load trucks for transport. The Ontario Provincial Standard Specification (OPSS) 127 rate for a 40kW front-end loader with a 1.5 m<sup>3</sup> bucket is \$48.25/hr. Including a labour rate of \$85/hr. for an operator and assuming the equipment can load the material in a 10-hour day, results in a loading cost of \$0.94/tonne.

## 2.1 Waste Management Costs

The resulting total cost to load, haul, and dispose of waste materials at the Site following the expansion is presented in Table 2.3.

Table 2.3 Total Waste Management Costs

Material Type	Quantity (tonnes)	Unit Cost (\$/tonne)	Total Cost (\$)
Solid Waste – Tip Floor	1,220	\$66.20	\$80,764.00
Solid Waste – Residual, Grit and Skimmings	106	\$112.28	\$11,901.68
Liquid Waste	19,551	\$24.20	\$473,134.20
Digestate	24,058	\$6.65	\$159,985.70
Project Management Fee (10%)			\$72,578.56
GST (13%)			\$94,352.13
TOTAL			\$892,716.27

The Site is equipped with a security fence. If operations are shut down, the stormwater ponds remain in operating conditions and there are no active sources of emissions. Therefore, there are no remediation costs associated with sudden closure of the Site.

The resulting FA estimate for the AD facility expansion is therefore \$892,716.27

Regards



**Jason Wilson**  
B.ENG, OLY

# **Appendix F**

**Fitec Mass Balance**



Mass Balance Escarpment Renewables

green Input Data Fields

Table 1.2: Scenario 2: REA tonnage increased to 33000t/y.


Organic waste type	Mass		TS delivered		oTS		oTSv		Protein		Fat		Biogas Yield		Methane content	
	tonne/Cd	%	%TS	%TS	%oTS	%	%	%	Nm <sup>3</sup> /t	%	Nm <sup>3</sup> /t	%	Nm <sup>3</sup> /t	%		
Pickering SSO Paste	36.71		29	55	93	16	0	144	55.6							
Davidson Slurry	27.4		23	90	95	28	15	143	60.18							
FOG	3.01		5	96	95	10	35	44	61.8							
DAF	5.48		10	94	90	37	62	50	71.75							
Liquid sugar	5.48		10	70	99	1	0	55	5.18							
ICI Liquids	12.33		5	90	95	28	15	40	60.18							
<b>Total Input</b>	<b>90.41</b>		<b>20.8</b>	<b>69.8</b>												

Total Biogas: 10405 Nm<sup>3</sup>/d  
 Methane: 56.6 %  
 Eleff: 41 %  
 Pel: 1006 kW (Potential!)

grit 1.5 %FM [kg] when removed density  
 32 %TS  
 1.4 kg/l

plastic 1.5 %FM [kg] when removed density  
 35 %TS  
 1 kg/l

Fine cleaning test results with food waste  
 oTSloss 4.24 % of oTS  
 Reject 3.4 % FM  
 Reject 44 %TS



# **Appendix G**

**Emergency Response Plan & Fire Safety  
Plan**



# EMERGENCY PREPAREDNESS & RESPONSE PLAN

**POLICY NUMBER:**  
PRO-SAF-006 Rev. 3

## SAFETY POLICIES AND PROCEDURES DISTRIBUTION: All Locations

**PAGES:** 16  
**REVISION DATE:**  
January 1, 2021

### LOCATION SPECIFIC INFORMATION

**METHOD OF COMMUNICATION:** Alarm Activated by Air Horn, Detection Systems, Radio, Voice

<b>Division:</b>	Escarpment Renewables	<b>Manager on Site:</b>	James Thomson
<b>Site:</b>	Grimsby	<b>Address:</b>	424 Sobie Road Grimsby, Ontario
<b>Emergency Meeting Location:</b>	Outside Main Exit Gate		
<b>Incident Coordinator:</b>	James Thomson	<b>Contact Number:</b>	289-455-1115
<b>Secondary Incident Coordinator:</b>	Kyle Howes	<b>Contact Number:</b>	905-208-2492
<b>First Aiders on Site:</b>	Kyle Howes, James Thomson, Travis Terpstra		
<b>Nearest Hospital:</b>	West Lincoln Memorial Hospital – 169 Main Street 905-945-2253		
<b>Plan Created By:</b>	Jody Preston	<b>Date:</b>	January 2020
<b>Plan Approved by the Following Personnel:</b>	Kyle Howes		
	Bill O'Meara		
	N/A		

### LOCATION OF EMERGENCY EQUIPMENT

<b>First Aid Kits:</b>	Office Area
<b>Fire Extinguishers:</b>	Various Areas Throughout the Facility – See Fire Safety Site Plan
<b>Eye Wash Stations:</b>	Office Area
<b>Spill Kits:</b>	Maintenance Area
<b>Specialized PPE (specify):</b>	4 Gas Detectors
<b>Emergency Phones/Radios:</b>	Land Lines in Office, All Workers have Smart Phones or Radios

Emergency Response Plan		
	Name of Individual:	Responsibility:
1	James Thomson	Incident Coordinator
2	James Thomson	Personnel who will contact the necessary emergency services and MOL, MOE etc.
	Kyle Howes	<i>Alternate if the above individual is unavailable.</i>
3	James Thomson	Personnel who will provide first aid treatment
	Kyle Howes, Travis Terpstra	<i>Alternate if the above individual is unavailable</i>
4	James Thomson	Personnel who will ensure that the injured worker is provided with adequate transportation to the hospital
	Kyle Howes	<i>Alternate if the above individual is unavailable</i>
5	James Thomson	Personnel who will meet and direct emergency service vehicles to the scene
	Kyle Howes, Travis Terpstra	<i>Alternate if the above individual is unavailable</i>
6	As assigned	Personnel who will provide emergency traffic control (if required)
	As assigned	<i>Alternate if the above individual is unavailable</i>
7	Bill O'Meara	Personnel who will contact MOL, MOE, or other government agencies (if required)
	Jody Preston	<i>Alternate if the above individual is unavailable</i>
8	James Thomson	Personnel who will document where the injured worker has been taken
	Kyle Howes	<i>Alternate if the above individual is unavailable</i>
9	Kyle Howes	Personnel who will supervise the site in the event that the supervisor has left to transport the injured worker to the hospital
	Travis Terpstra	<i>Competent worker who will fill in as supervisor if the above supervisor is unavailable</i>

## Purpose

To provide planning for the identification of potential for incidents and emergency situations as well as the mitigation of the environmental impacts that may be involved with incidents and emergency situations.

## Scope

This program applies to all divisions of Escarpment Renewables. Each workplace will have an individual emergency preparedness and response plan created specific to the location. All affected workers should be familiar with the plan and the procedures involved in dealing with various emergencies.

## Application

All emergency preparedness and response situations pertaining to this location's specific plan will be reviewed and implemented (e.g. information specific to communications systems, trained first aiders, fire response, evacuation plans, etc.). This document will be adjusted in coordination between the operations team and a health and safety representative if required. The location specific plan should be posted on the health and safety board in the workplace.

## **Roles and Responsibilities**

Managers, Supervisors and the Health and Safety Department are responsible for developing workplace and job site emergency plans in the event of an incident or a rescue is required.

Managers, Supervisors and Health & Safety Personnel must be notified of any incident as per the Incident Reporting Procedure PRO-SAF-001.

The **Incident Coordinator** is the person that serves as the main contact for the company in the case of an emergency. The Incident Coordinator is responsible for making decisions and following the steps described in this emergency response plan. The event of an emergency occurring within or affecting the worksite, the primary contact will serve as the Incident Coordinator. If the primary contact is unable to fulfill the Incident Coordinator duties, the secondary contact will take on this role. If needed, Senior Manager on site can also appoint or assume an Incident Coordinator role.

Managers and Supervisors must maintain a current set of Company personnel telephone numbers as well as contact telephone numbers to obtain equipment, material or expertise needed in the event of an emergency.

Managers and Supervisors are responsible for ensuring that Emergency Contact numbers are posted in conspicuous locations available to all staff and employees; generally these numbers are posted on the Safety Board. Workers must be trained as to the location of Emergency Contact numbers.

Managers and Supervisors must ensure adequate personnel are trained in first aid and CPR. Certificates shall be posted on the Safety Board. It is recommended that all supervisors receive training in First Aid and CPR.

Supervisors are responsible to ensure all workers (including temporary workers and sub-contractors) are aware of the basic emergency response procedures and who to contact in case of injury, illness or an accident

All employees must know the directions to the nearest hospital and the location of fire extinguishers, first aid kits and the emergency meeting location in the event of an evacuation.

Evacuation drills must be carried out at a minimum of once per year. In the case of workplaces that operate 24 hours or multiple shifts, evacuation drills should be held for each work shift. The Emergency Drill Report should be used to document all drills and evacuations ensuring effectiveness and corrective action when required.

## **Planning and Awareness**

Before an emergency happens the following items must be included as part of the planning in order to effectively deal with potential problems.

- Have all hazards been analyzed?
- Are the right people assigned to the various tasks?
- Do we know the location and/or route to the nearest hospital?
- Are communication devices effective?
- Do fire, police and emergency medical services respond to 911 or do we use another telephone number?
- Do employees know the workplace address in case they are the person who must call for help?
- Who will be the competent person in charge if the Supervisor is not available or must leave the job?
- Who are the workers trained in first aid and CPR?
- Are there any workers knowledgeable in the use of rescue techniques (i.e. – suspended worker, worker trapped in a Confined Space)?
- Is there equipment available to affect a rescue?
- Are all employees aware of the Incident Reporting Procedure?

The plan must be communicated to all employees and posted on the Safety Board. In the case of Working at Height, Confined Space Entry and other high risk tasks, no worker shall participate or be asked to perform these tasks without training and certification from the Health and Safety Department.

**Procedure**

The Incident Coordinator and delegates will have the overall administrative responsibility for any serious accident or emergency situation. Supervisors and operations personnel will usually be the first people to respond.

<b>The following are potential emergencies:</b>		<b>Page # in this Document</b>
Select the Potential Emergencies that apply to the specific site or location (review the emergency procedures and plans that apply to all workers)		
<input type="checkbox"/>	1. Building Evacuation	4
<input type="checkbox"/>	2. First Aid/Medical Aid/Critical Injury & 911 Procedures	5
<input type="checkbox"/>	3. Fire and/or Explosion	5
<input type="checkbox"/>	4. Severe Weather	6
<input type="checkbox"/>	5. Hazardous Material Spills	7
<input type="checkbox"/>	6. Transportation or Material Handling Incident	8
<input type="checkbox"/>	7. Violence in the Workplace	8
<input type="checkbox"/>	8. Bomb Threats	8
<input type="checkbox"/>	9. Utilities Outages	8
<input type="checkbox"/>	10. Unexpected Disaster, Event or Public Emergency	9
<input type="checkbox"/>	11. Animal Risks to Life or Health	9
<input type="checkbox"/>	12. Motor Vehicle Collision	9
<input type="checkbox"/>	13. Property Damage	9
<input type="checkbox"/>	14. Power Line Contact	10
<input type="checkbox"/>	15. Fall from Height	10
<input type="checkbox"/>	16. Confined/Restricted Spaces	11
<input type="checkbox"/>	17. Water Emergency & Rescue	11

**1. Building Evacuation**

All Offices, Facilities, Shops, etc. will have a posted copy of the building floor plan that will include (among other things) the location of emergency exits, fire extinguishers and the Emergency Meeting Area

All Employees Shall:

- Know the way out from their work area
- Know the location of the nearest fire extinguisher(s)
- Know the location of the Emergency Meeting Area
- Report to the supervisor in charge of the meeting area and ensure you are accounted for
- Do not return to your work area unless specifically told to do so when the area is safe and is given the all clear by Emergency Response Personnel and/or in Incident Coordinator or Supervisor
- Know and understand what areas of the building need to be evacuated and at what times.

The Incident Coordinator or Supervisor in charge of the meeting area will:

- Post and ensure employees are aware of the location of the building floor plan (See Fire Safety Site Plan sample at end of this document)
- Perform a head count to ensure all personnel are accounted for. When required, an attendance sheet, sign-in sheet, visitor log, etc. can be used
- Give permission to return to work area when safe to do so

## 2. First Aid/Medical Aid/Critical Injury & 911 Procedures

If the person is conscious:

- Report injury to supervisor, notify if a first aider and/or 911 is required
- Supervisor and/or first aider to assess the level of injury. Supervisor will contact 911 if required
- If trained, perform first aid and reassess

If the person is unconscious:

- Report to supervisor, supervisor will call 911 for assistance
- Assess injury and provide first aid and/or CPR until Emergency Personnel arrive
- Provide Emergency Personnel with details relating to nature or cause of the worker losing consciousness

When calling 911, be prepared to provide the 911 Operator the following information:

- Nature of the call (i.e. – injury, fire, motor vehicle collision)
- Incident address and (if necessary) specific area of building
- Your name
- Telephone number where you can be reached in case of disconnection

When the Emergency Personnel Arrive:

- A responsible person should be assigned to guide arriving Emergency Personnel to the incident area
- A facility floor plan complete with drawings and / or descriptions of the building fire emergency fire systems, electrical panels and hazardous material should be available to fire department personnel

All First Aid/Medical Aid/Critical Injuries shall be documented and investigated according to Incident Reporting Procedure PRO-SAF-001

In the event of a Critical Injury, contact the Environmental, Health and Safety Manager who will contact all necessary government agencies.

## 3. Fire and/or Explosion Emergency

If you discover a fire:

- Notify supervisor of the emergency as soon as safe to do so and leave the fire and/or explosion area
  - If in a building, close all doors behind you
  - Notify other affected personnel by activating the building fire alarm which may be a pull station, air horn, fire whistle, radio or paging system
  - Evacuate the area using the closest safe exit route and gather at designated meeting area

Supervisor to ensure the Fire Department has been called – Dial 911 (see Section 2 for more information)

If you hear the fire alarm/emergency notification:

- Leave the building using the closest safe exit – this includes Rolling Equipment and Operators
- Before opening any doors test the door and knob for heat
- If door or handle is hot **DO NOT OPEN** – move to a second exit; if handle and door are cool open door slightly and check for fire and smoke before proceeding

**\*Fight the fire ONLY if you have been trained and are confident that it may be controlled with the firefighting equipment available\***

For Vehicle Fire Response, see MWSI Waste Vehicle Fires Safe Job Procedure (SJP-SAF-017) for more information. If a fire is discovered inside a truck box or load, notify your supervisor and attempt to extinguish the fire using load-packing techniques. If this is not possible or ineffective, move the vehicle to a safe area and eject the load, move the vehicle away from the material and assist in traffic management (if required) until Emergency Services arrives.

## **4. Severe Weather Emergency**

### **If a severe thunderstorm/lightning/windstorm is imminent: Facilities**

Note: Mobile trailers offer little protection, even if secured or anchored down. In the event of a severe weather warning, leave these for a sturdy shelter or a permanent building before the storm approaches.

- Close all building doors
- Tune a radio to a local news/weather advisory channel
- Anyone working outside should move inside and stay inside (lightning & flying debris hazards)
- Move away from exterior walls and windows
- Site manager or supervisor is to account for whereabouts of all personnel

### **If a severe thunderstorm/lightning/windstorm is imminent: Driving**

- Tune a radio to a local news/weather advisory channel
- Turn on your headlights (low beams) and slow down
- Do not drive unless necessary
- Pull safely onto the shoulder of the road away from any trees that could fall on the vehicle
- Stay in the vehicle and turn on the emergency flashers until the heavy rains and/or winds subside
- An automobile provides better insulation against lightning than being in an open area
- Avoid contact with any metal conducting surfaces either inside your car or in an outside open area
- Avoid flooded roadways, ditches and waterways
- Avoid downed power lines
- Check your windshield wipers and tires regularly to insure that they are ready for severe weather
- Approach intersections with caution
- Treat flashing or dark traffic lights at intersections as a four way stop

### **If a tornado is imminent: Facilities**

Note: Mobile trailers offer little protection, even if secured or anchored down. In the event of a severe weather warning, leave these for a sturdy shelter or a permanent building before the storm approaches.

- Close all building doors
- Tune a radio to a local news/weather advisory channel
- Anyone working outside should move inside and remain until the warning is lifted
- Go to an inside location on the ground floor where you are away from exterior walls and windows and in a strong part of the building (inside rooms with cinder block walls offer the best protection)
- Avoid areas with wide span roofs (i.e. – tip floors, maintenance shops, etc.)
- Get under cover (a piece of furniture such as an office desk or table)
- Use arms to protect head and neck
- Site manager or supervisor is to account for whereabouts of all personnel

### **If a tornado is imminent: Outside - unable to get to shelter**

- Lie flat in the nearest depression, ditch or ravine if there is no time to escape
- Avoid areas with trees and power lines, protect your head with your arms
- Move away from the path of the tornado at a right angle direction
- Stay out of the water

### **If a tornado is imminent: Driving**

Do not drive during tornado conditions

- Never try to out-drive a tornado in a vehicle. Tornadoes can change direction quickly and can lift a car or truck and toss it through the air
- Get out of your vehicle immediately and seek shelter in a nearby building
- If there is no time to get indoors, or if there is no nearby shelter, get out of the car and lie in a ditch or low lying area away from the vehicle. Stay away from trees and power lines, protect your head with your arms



## **Earthquake: Facilities**

Generally, there is no warning for earthquakes. Depending on your location the best option is to remain where you are, lay flat on the ground and/or take shelter under the nearest available protection (i.e. – office desk or table). Stay away from windows, glass, outside doors & walls and anything that could tip over or fall. If outside during an earthquake seek an open area away from buildings, trees or power lines.

Earthquakes usually last anywhere from a few seconds to a few minutes and can often be followed by aftershocks that can be as severe as the initial shock - be prepared

- Tune a radio to a local news/weather advisory channel
- Stay where you are. Research has shown that many injuries occur when people attempt to enter or exit buildings or attempt to move to other areas
- Be aware that alarm systems and sprinklers could be triggered during an earthquake. Only attempt an emergency evacuation if directly told to do so by emergency personnel

## **Earthquake: Driving**

Depending on the severity of the earthquake, you may not even notice if one occurs. However, in the event you do experience an earthquake while driving

- Stop as quickly and safely as possible and remain in the vehicle. Avoid stopping near buildings, trees and power lines
- Tune the radio to a local news/weather advisory channel
- Proceed with caution once the earthquake has stopped, pay attention to any signs of aftershocks. Avoid bridges, overpasses, ramps or roads that may have been damaged by the quake

## **5. Hazardous Materials Spills Emergency**

Hazardous spills (leaks) of propane or a natural gas line rupture:

- If a leak is severe, evacuate the building using evacuation procedure and contact authorities
- If leak is minor, such as a lift truck or cutting torch propane tank, move the tank outside a minimum of 10 metres from the building
- MWSI Environmental, Health and Safety Manager will contact proper authorities as outlined in Emergency Contact Numbers

Hazardous spills of low or non-flammable liquids, lubricants/oils, etc.:

- Turn off PTO pump and/or shut down equipment (see MWSI Vehicle Environmental Spill Control Safe Job Procedure – SJP-SAF-018 for more information)
- If the spill is minor (i.e. – no impact to environment and handled “in-house”) contain the spill using suitable spill kit or absorbent – notify supervisor who will report details of the spill to the MWSI Environmental, Health and Safety Manager
- If the spill is major (i.e. – negative impact to the environment and/or requires a spill clean-up company) notify supervisor who will report details of the spill to the MWSI Environmental, Health and Safety Manager. Attempt to contain the spill and/or evacuate the area if required
- MWSI Environmental, Health and Safety Manager will contact proper authorities as outlined in Emergency Contact Numbers

Hazardous spill of flammable liquids, gasoline or diesel fuel:

- Turn off pump immediately using the emergency stop
- Remove all ignition sources
- Wear appropriate PPE before entering spill area
- See above for Minor and Major Spill Response Procedures
- Secure the area and call supervisor immediately
- MWSI Environmental, Health and Safety Manager will contact proper authorities as outlined in Emergency Contact Numbers

## **6. Transportation or Material Handling Incident / Emergency**

In the event of a Motor Vehicle Collision involving one of our vehicles out on the road, supervisors and operators (CSR's) shall follow the Incident Reporting Procedure (PRO-SAF-001) and/or the MWSI – Motor Vehicle Incident Safe Job Procedure (SJP-SAF-015) - see Section 12 for more information.

In the event of an incident involving a material or waste spill, damage to property or equipment (this includes all mobile equipment, vehicles, processing equipment, conveyors, etc. – See Section 13 for more information)

- Assess the level of emergency and secure the area – notify supervisor as soon as possible
- Contain any fluids that may be hazardous to people or the environment – See Section 5 (above) for more information regarding spill response and containment
- If personnel are injured contact first aider on site and arrange for emergency medical assistance if required
- Complete the Incident Report Form

## **7. Violence in the Work Place Emergency**

Escarpment Renewables has a comprehensive Policy and Procedures regarding Prevention of Violence and Harassment in the Workplace (POL-SAF-002) and What to do in Cases of Violence and Harassment (POL-SAF-005)

The potential for violence in the workplace may be indicated by warning signs such as – poor impulse control, disrespectful behaviour, making intimidating comments or threats, alluding to violence toward others, hostile attitude/blaming others for life's problems, belief they are being treated unjustly or unfairly, history of difficulty accepting others person authority, history of previous violence/substance abuse or mental health problems.

If you find yourself in a violent or a possible violent situation:

- Summon immediate assistance - contact your supervisor, the nearest person or call 911 if you feel your personal safety is being threatened
- Attempt to control the situation but do not endanger yourself, maintain personal space (arm's length)
- Talk calmly, be a good listener and use empathy
- If the situation continues to escalate, attempt to leave the area or ask the other person to leave
- After the situation is controlled notify Human Resources and cooperate in the investigation of the incident

## **8. Bomb Threat Emergency**

Bomb threats are not to be taken lightly. Persons responsible for such threats can be prosecuted. Angry or discontented customers or employees may make bomb threats. Procedures for bomb threats are as follows:

- Stay calm - do not alarm others. Immediately notify your supervisor who will report the threat
- Supervisor will contact 911 for instructions
- Decision to evacuate areas or buildings will be made by a Senior Manager with guidance from police
- Take a personal list with you if the building is evacuated and ensure all workers are accounted for

## **9. Utilities Outages**

This may be an outage of electrical power, natural gas, propane gas or water.

- Contact supervisor – report to the area Maintenance Manager or most senior manager onsite
- If an electrical outage, stay in a safe location and await instructions – this may include evacuation
- If the office area temperature drops below 18 degrees Celsius in the event of a power outage Management will advise the steps to be taken by all employees
- If the area is without the normal use of water or washroom facilities the management team at the location will advise the steps to be taken by all employees

## 10. Unexpected Disaster, Event or Public Emergency

Provincial Emergency Management Organizations deal with public safety in the event of a major emergency:

- Communication of such events will be widely reported using media channels (television, radio, news apps), texts, email and social media feeds (Twitter, Facebook)
- If you are in close proximity to such events, follow the advice and direction of Emergency Services
- Events may be classified as Public Warnings, Advisories, Critical or Red Alerts

Some situations in which a Public Emergency Alert may be issued include:

- Large Fire or Explosion
- Chemical Leak or Spill
- Nuclear Emergency
- Major Transportation Incident - train derailment, road closures in the event of a severe traffic incident
- Terrorist Attack

## 11. Animal Risks to Life or Health

This may include risks from wild animals or domesticated animals in rural and urban work locations. Controls shall be put in place and identified to all workers who may be exposed to the dangers of animal attacks.

## 12. Motor Vehicle Collision

All Escarpment Renewables drivers shall be trained regarding procedures to follow in case of a motor vehicle collision. This includes the Incident Reporting Procedure (PRO-SAF-001) and the Motor Vehicle Incident Safe Job Procedure (SJP-SAF-015). Personnel may also be equipped with an Emergency Response Card for **What To Do After an Incident/Motor Vehicle Collision** which shall include emergency procedures and contact numbers in case of an motor vehicle incident.

Immediate procedures to follow if you are involved in an incident or motor vehicle collision:

1. Assess the situation
2. Contact emergency services (call 911) if necessary
3. Notify your supervisor immediately
4. Secure the area
5. Do not admit fault
6. Do not speak to the media
7. Complete an Incident Report Form

## 13. Property Damage

All cases of property damage must be reported immediately. This could include damage to any property, roadway, sidewalk, sign, grass, tree or other vegetation, building, fence, waste container, etc.

Upon discovery of any property damage:

- Contact your supervisor and advise of the damage
- Assess the area for potential risks to yourself, co-workers and/or the public (i.e. – damaged equipment that is unsafe to operate, broken tree branch that could fall, damaged sidewalk creating a trip hazard, etc.) remain in the area until the hazard can be effectively controlled
- Take photos of the scene
- Complete Incident Report Form

Property damage could be related to another emergency (i.e. – Motor Vehicle Collision); all damage shall be reported to your Supervisor immediately and documented as part of the Investigation Report(s).

## 14. Power Line Contact

No object shall be brought closer to an energized electrical conductor with a nominal phase to phase voltage rating set out in Column 1 of the table below; the minimum approach distance is set out in Column 2.

Nominal Phase-to-Phase Voltage Rating	Minimum Distance
750-150,000 volts	3.0 metres
More than 150,000 to 250,000 volts	4.5 metres
More than 250,000 volts and over	6.0 metres

- Do not stockpile, load or unload material near power lines
- Assume all power lines are energized – if the voltage is unknown, stay 6 metres away
- In the case of sites with power lines in working areas, an Overhead Power Line Protection Check List shall be completed, reviewed with crew and kept onsite
- Ensure all warning signs are posted and legible

### In Case of Contact

- If contact has been made with equipment, operator must stay in equipment and await instruction by proper authority
- Inform supervisor of the power line contact – supervisor will notify authorities
- Never touch equipment and ground at the same time
- Follow instructions of all emergency personnel – all other personnel must stay at least 10 metres (30+ feet) away from the vehicle until the power has been shut off

### EMERGENCY EXIT FROM VEHICLE IN CONTACT WITH LIVE POWER LINE

In the event that personal safety is in jeopardy and you must exit the vehicle before power can be shut off, workers shall:

- **DO NOT PANIC** – open the door of the vehicle, remain in the seat and swing your legs out of the cab without touching the ground or any metal parts of the vehicle
- Jump from the cab of the vehicle ensuring **BOTH** feet touch the ground at the same time – **DO NOT TOUCH THE VEHICLE UNDER ANY CIRCUMSTANCE**
- Begin to move away from the vehicle by either shuffling your feet (DO NOT WALK OR RUN) or by hopping (both feet leaving the ground and touching back down at the same time). Continue to move away from the vehicle until you are a minimum of 10 metres (30+ feet) away

## 15. Falls From Height

Company Policy states that "No worker shall expose themselves to a fall from height greater than three meters or more without providing effective Fall Protection which includes; Guardrail Protection, Travel Restraint or Fall Restriction. Under no circumstance shall a person work in situation where Fall Arrest is the only form of protection available. This shall be considered dangerous work."

There are other examples when Fall Protection is required. See MWSI Fall Protection Guidelines (SWP-SAF-248) for more information.

In the case where the policy, training and/or safe job procedures are not followed and a worker experiences a fall, the following steps shall be taken in order to perform an emergency rescue related to a fall from height.

- Notify immediate Supervisor that a fall has happened – Supervisor will notify the Environmental, Health and Safety Manager (Fall Arrest Rescue Coordinator) for further instructions
- In all cases of a worker falling and being suspended 911 must be called
- Supervisor shall appoint a worker to guide Emergency Services Personnel to the location of the fallen worker

- Assess the scene and ensure that there are no other hazards that will further injure the fallen worker or another worker if a rescue is required
- If possible, place a ladder, rolling stairs or an Aerial Work Platform under the individual to support the weight of the fallen worker; this will remove stress from the lower limbs being restricted
- If the worker is conscious and does not require immediate first aid then place the equipment under the worker and allow them to egress safely to the ground
- Any worker that has suffered a fall from height must see professional medical personnel; once 911 has been called wait for help to arrive and keep the worker calm. At a minimum, when the worker is on the ground have them sit with their back supported and their legs stretched out in front of them for at least 30 minutes – do not allow the worker to either walk around or lay flat. First Aid should be rendered by qualified personnel only
- When possible, secure the scene; no access should be allowed other than Emergency Services, Company Accident Investigators and respective government officials (i.e. – the MOL)
- Notify Health and Safety Representatives, Joint Health and Safety Committee Members and applicable Safety Department personnel

If the worker is **UNCONSCIOUS** call 911 immediately. Unconscious suspended workers may be suffering from suspension trauma which is the result of lack of blood flow to the brain

- Notify immediate Supervisor that a fall has happened and the worker is **NON-RESPONSIVE** – Supervisor will notify the Environmental, Health and Safety Manager (Fall Arrest Rescue Coordinator) for further instructions. Immediately contact facility personnel trained in First Aid and CPR and send someone to guide Emergency Services to the location of the fallen worker
- Stay with fallen worker until help arrives. Assess the scene and ensure that there are no other hazards that will further injure the fallen worker or another worker performing the rescue
- If possible, place a ladder, rolling stairs or an Aerial Work Platform under the individual to support the weight of the fallen worker; this will remove stress from the lower limbs being restricted. Do not attempt to rescue the worker unless you are trained to do so and controls are in place to prevent the rescuer from falling
- Section off accident area, allow access to Emergency Services Personnel, Rescue Team, Safety Department Personnel and respective government officials (i.e. – the MOL)
- Notify Health and Safety Representatives, Joint Health and Safety Committee Members and applicable Safety Department personnel

## 16. Confined/Restricted Space Emergency

Confined Space Entry requires a Provincially Regulated Site Specific Plan. Escarpment Renewables has a comprehensive Confined Space Entry Program for Ontario (POL-SAF-028) that must be followed in cases where confined space entry is required. This includes written procedures specific to the site to be followed in case of an emergency.

Contact the Environmental, Health and Safety Manager or a member of the Safety Department for more information.

## 17. Water Emergency & Rescue

Requirements for “Drowning Protection” are detailed in the Applicable Provincial Regulations.

*These regulations shall be reviewed with all workers on site along with SWP-SAF-173 and SJP-SAF-102 Working within 10 Feet of a Pond, River or Open Waters Edge.*

### General

According to Provincial Regulations, any worker who may be exposed to the risk of drowning shall be outfitted with a suitable Personal Floatation Device (PFD or life jacket – see below).

In addition:

- Workers who may work on approaches to water in which there is no guardrail or fencing shall utilize a travel restraint system (i.e. – harness, lanyard and lifeline with a rope grab system) where they are tied off to a suitable anchor point in a manner in which it is impossible for the worker to reach the water's edge
- Workers shall never wear a life jacket and a harness/lanyard combination together. A harness is designed to pull up on deployment which can push a PFD up and restrict the workers airway which could lead to choking/suffocation of a worker

### **Working Around, Over or Near Water:**

- Warning signs shall be posted in the area to warn public and workers of the hazard of open water (e.g., Danger, Deep or Icy Water, Keep Out, etc.)
- Where there is a current in the water, a line extending across the water, with floating objects attached to it, capable of supporting the heaviest person on the site in case he/she falls into the water, shall be installed
- All workers must be alert and aware of their fellow workers at all times when working around water
- A floatation device shall protect workers in proximity to a water hazard with a risk of drowning. This device will provide buoyancy adequate to keep a worker's head above water, face up without effort by the worker (see "Life Jacket / Personal Floatation Device (PFD) Requirements" below).
- All PFD's and other rescue devices shall be located as close to the work area as possible.
- Rescue equipment such as boats must be stored near the water and ready for use.
- All workers working at the location shall be trained on the use of life jackets and preservers, rescue devices, PPE, Reach\*Throw\*Row\*Go Procedures (see below for more information), etc.
- This emergency response plan includes additional information and procedures to be followed in order to safely work adjacent to water:
  - The plan includes site address, method of access, and emergency responders who must be informed that a worker has entered water and possible assistance in rescue is required
  - Complete the "Roles and Responsibilities for Water Rescue" for more information

### **Life Jacket/Personal Floatation Device (PFD) Requirements:**

- PFDs must be Canadian Coast Guard, Department of Fisheries and Oceans approved or equivalent. The PFD information must state that it is designed to keep the wearer face up in the water

### **Emergency Water Rescue:**

In the event a worker falls into water a quick assessment of the emergency must occur – in order to determine what the situation is you need to talk to the worker. If the worker does not respond, it likely indicates a significant event and they may be gasping for air, panicking or unconscious.

When a victim is conscious and struggling:

- Locate a rescue device such as a line, rope, shepherds hook, long pole or life preserver
- Move to a safe, stable area where you can securely position yourself
- Try reaching the victim by holding out the rescue device or throwing them a life preserver with rope attached – See Reach\*Throw\*Row\*Go Procedures for more information
- Instruct the victim to grab the line as cold water can have significant effect on the physical and mental capabilities of a person (panic, hypothermia)
- Tow the conscious victim to shore slowly and steady. Maintain communication with the victim, instructing them to continue to hold on and reach down with their feet until they can feel bottom

If the victim is unconscious:

- **Contact emergency services immediately – Call 911 and site personnel trained in First Aid**
- Remove person from water
- First aid trained personnel must assess the situation
- Follow directions of 911 operator and start CPR if required

## **Rescue Equipment:**

- A ring buoy attached to a 15 meter 9.5mm diameter polypropylene rope, or rope throw bags.
  - Note: The rope throw bag itself is a softer impact item and does the same job
- Lifejackets for all persons required for a rescue operation including those standing in or near water
- A boat (where applicable) equipped with a motor if the water is likely to be rough or swift
- A boat hook (which is a short shaft with a fitting on one end shaped to help in rescuing a person or recovering an object)
- An Emergency Alarm System (i.e. – open communication devices, Air Horn) must be maintained to alert workers to the need for an emergency rescue
- Where there is current in the water, a line extending across the water, with floating objects attached to it that are capable of supporting the heaviest person on site in case he/she falls into the water

## **\*Reach \* Throw \* Row \* Go Procedures – Rescue Items for \*REACH & \*THROW Operations Shall Be Readily Available During Waterside Operations**

**“The First Step:”** Always call 911 in the event of a worker entering a body of water and requiring rescue. It is always better to have rescue assistance on the way and not needed than to need rescue assistance and not have it.

**\*Reach:** The worker is located close to the shoreline and the rescuer(s) can retrieve them by reaching with a rigid device such as a rescue pole or hook, etc. without having to enter the water. Rescued workers must be conscious, alert, and able to grab and hold on to the reaching device for this method to be effective.

**\*Throw:** Worker requiring rescue is too far away from the shoreline to be reached with a rigid device. Rescuers can throw ropes, rope bags, floatation rings, a PDF tied to a rope, etc. to retrieve the victim without having to enter the water. Workers must be conscious, alert, and able to grab and hold on to the thrown object for this method to be effective

### ***\*ROW AND \*GO METHODS SHOULD ONLY BE ATTEMPTED BY TRAINED PROFESSIONALS***

**\*Row:** Worker requiring rescue is too far away from the shoreline to be reached or to have a flotation device thrown to them. Rescuers must use a boat or approved watercraft to access and retrieve the worker without having to enter the water. Once close enough to the worker, rescuers can reach, throw, or manually lift the worker directly into the boat (whichever method is safest). The worker may be conscious and alert or unconscious. To ensure effectiveness of the row method a minimum of three rescuers are to be present at each waterside operation, two of which shall be trained and available for rescue purposes.

**\*Go:** This method should only be attempted by professionals (emergency services) trained specifically in water rescue. Rescuers must physically enter the water and swim to the worker to retrieve them. This method may be used from the shoreline or from a boat depending on the circumstances. This method is typically used for unconscious victims but may also be used for conscious and alert victims that are in distress or unable to grab and hold on to a flotation device. Only rescuers, who are trained and strong swimmers, should enter the water to retrieve a worker.

## **Spill Procedure:**

To prevent a spill or accidental release of hazardous material and contamination of water, all equipment and tools must be fueled on land and away from water. If it is not possible to remove a tool or equipment from the water when fueling, the tool or equipment must be surrounded by floating absorbent socks attached to the vessel in the event of an accidental release/spill. Additional socks, absorbent pads and waste containment disposal bags must be available on site. Any spill of hazardous material that enters a waterway must be reported to the Environmental, Health and Safety Manager

## **Key Items to Remember for Any Water Rescue:**

**Communication Is Key** – Rescuers on and off shore should be in constant communication with each other as well as the worker needing rescue. Those rescuers not directly retrieving the worker need to be the eyes and ears or “spotters” for those rescuers that are retrieving the victims

**Personal Safety Is Paramount** – These procedures are to rescue the worker already in the water, not create new ones! All rescuers in or near the water **MUST** be wearing Personal Flotation Devices (PFDs). All rescuers on shore should also be wearing PFDs when possible. A rescuer should never remove his or her PFD and place it on another person. Whenever possible, rescuers should tie themselves off to a stationary object on shore to prevent being pulled into the water (i.e., trees, rocks, pylons, buildings, vehicle, etc.)

**Keep It Simple** – Rescuers should try to avoid entering the water whenever possible. Do Not Throw, Row, or Go if a worker can be reached from the shoreline

**Be Aware Of Your Surroundings** – During any incident, rescuers need to be alert and aware of the hazards around them. Be sure to consider the weather, hazards on the shoreline, hazards in the water, currents, other watercraft, etc. when planning and executing any type of a water rescue

## **After The Rescue:**

Once the worker has been rescued, trained personnel shall provide First Aid and CPR. **First Aid for people with water-immersion injuries is unique and requires special training.** First Aiders must assume an underlying cause occurred for the near drowning. What was the reason for the worker to enter the water? Did he/she have a heart attack? Was he/she struck or pushed into the water? Most importantly, is there the potential for head, neck or spine injuries? If the worker is unconscious, assume this is the case.

CPR or Cardiopulmonary Resuscitation can be performed on unconscious persons in order to maintain brain function until professional Emergency Service Workers arrive. Only trained First Aiders can perform CPR. If an AED (Defibrillator) is available, follow the directions for shocking and CPR Procedures according to the device instructions.

### **CPR Procedures for Trained First Aiders**

- Ensure it is safe for you to proceed – do not risk personal injury
- Is the person conscious? Clap, speak loudly or physically stimulate the person. If there is no response consider the ABC (Airway, Breathing, Compressions) Procedure
- Ensure the Airway is Open – carefully tilt the persons head back to open the airway
- Check for Breathing - feel for air moving in and out of the persons mouth or nose. If breath is detected place the person in the recovery position
- Begin Compressions - if breath is not detected, begin circulating oxygen by performing chest compressions. Push hard and deep (approximately 2 inches on adults) while performing compressions. Maintain a rhythm of about 100 compressions per minute or 30 compressions every 18-20 seconds. Note that if the person was in the water, compressions may result in water being pushed out of the person through the airway. Ensure the airway is clear at all times while performing compressions
- After 30 compressions stop and reassess Airway and Breathing; if airway is blocked ensure it is clear, if breathing is detected place the person in the recovery position, if breath is not detected resume compressions
- Continue until EMS personnel arrive, another person is able to assist or take over, your personal safety becomes a concern, or you are too physically exhausted to continue



## Roles and Responsibilities for Water Rescue

<input type="checkbox"/> N/A <b>Emergency Response Plan for Work on Bodies of Water</b> This plan is for Shore-Based* Water Rescue	
Location:	Escarpment Renewables
Emergency Response Team:	James Thomson
	Kyle Howes
	Sam Huang
List the appropriate person responsible for the activity on the right:	
James Thomson	Will Sound Emergency Alarm
James Thomson	Will take charge and make sure the area is safe
James Thomson	Will call Emergency Services – Dial 911 if necessary
James Thomson	Will don all required safety equipment and will toss a Floatation Device to the person being rescued
Kyle Howes	Will assist in rescue procedure and will ensure that the rescuer is secure
Kyle Howes	Will assist and will bring First Aid Equipment, blankets, additional PFD's etc. to the rescue site
Sam Huang	Will go to the site or accident location entrance and provide direction for Emergency Response Personnel
<b>EMERGENCY CONTACTS</b>	
Emergency Services: 911	Ministry of Labour: 1-877-202-0008
Hospital: 905-945-2253	Head Office: 905-475-6356
Supervisor: James Thomson - 289-455-1115	Other: Jody Preston - 416-676-2977

<input type="checkbox"/> N/A <b>Emergency Response Plan for Work On/Near Ice Covered Bodies of Water</b> This plan is for Shore-Based* Water/Ice Rescue	
Location:	Escarpment Renewables
Emergency Response Team:	James Thomson
	Kyle Howes
	Sam Huang
List the appropriate person responsible for the activity on the right:	
James Thomson	Will Sound Emergency Alarm
James Thomson	Will take charge and make sure the area is safe
James Thomson	Will call Emergency Services – Dial 911 if necessary
James Thomson	Will don all required safety equipment and will toss a Floatation Device to the person being rescued
Kyle Howes	Will assist in rescue procedure and will ensure that the rescuer is secure
Kyle Howes	Will assist and will bring First Aid Equipment, blankets, additional PFD's etc. to the rescue site
Sam Huang	Will go to the site or accident location entrance and provide direction for Emergency Response Personnel
<b>EMERGENCY CONTACTS</b>	
Emergency Services: 911	Ministry of Labour: 1-877-202-0008
Hospital: 905-945-2253	Head Office: 905-475-6356
Supervisor: James Thomson - 289-455-1115	Other: Jody Preston - 416-676-2977

\*In Water Rescue Shall Only Be Performed By Trained Personnel or Emergency Service Personnel

## Emergency Contact Numbers

Fire:	<b>911</b>
Ambulance:	<b>911</b>
Police:	<b>911</b>
Hospital Name:	West Lincoln Memorial Hospital
Address:	424 Sobie Road - Grimsby, Ontario
Phone Number:	905-228-1506
Provincial Government Office: (Health and Safety/MOL):	1-877-202-0008
Provincial Government Office (Environment):	1-800-565-4923
Local Hydro Utility Company:	Grimsby Power 905-945-5437
Spills Reporting Agency:	Spills Action Centre 1-800-286-6060
Transportation Ministry:	N/A
OTHER	Jody Preston 416-676-2977 Luke Procter 905-806-3105
Head Office:	<b>424 Sobie Road Grimsby, Ontario 905-228-1506</b>
Division or Regional Headquarters:	White Owl Family Office 180 Renfrew Drive, Suite 130 Markham, Ontario L3R 9&2

# FIRE SAFETY PLAN

Bio-Digester Facility  
Escarpment Renewables  
424 Sobie Rd., Grimsby ON L3M 4E7

**HAZARDOUS PROCESSING AREAS:** Yes - Digester Tanks

**WARNING:** The bladders contain bio-gas, methane, hydrogen sulphide, carbon dioxide, and LEL. **Breathing in these gases could be fatal.** Exercise caution, wear ALTAIR 4X monitors if you enter into the area. Wear SCBA when required.

This approved document shall be kept readily available on the premises in the Fire Safety Plan box at all times, for use by fire officials in case of an emergency.

The designated location of the Fire Safety Plan is in the Main Office.

Fire Safety Plan prepared by:

Michael Agnew – Trillium Fire Protection (905)-684-0196

Mark Berti – Fire Safety One (905) 988-7734

Revised by – Jody Preston, Miller Waste Systems Inc. Facility Safety Trainer

Date of Submission: Sept. 5th, 2019

Revision Date: November 13, 2019

## TABLE OF CONTENTS

P. 2	Introduction
P. 4	Ontario Fire Code Definitions
P. 5	Fire Safety Plan Approved Location
P. 5	Fire Safety Plan Review Requirements
P. 5	Fire Emergency Procedures Posted & Maintained
P. 6	Audit of Building Resources
P. 9	Audit of Human Resources
P. 10	Owner/Manager Responsibilities for Fire Safety
P. 11	Appointment of Designated Supervisory Staff
P. 12	Training of Supervisory Staff
P. 13	Supervisory Staff Duties and Responsibilities
P. 14	Site Staff Duties and Responsibilities
P. 15	Supervisory Staff Emergency Procedures
P. 16	Emergency Procedures for Occupants
P. 17	Fire Drill Procedures & Training
P. 18	Organizing & Conducting a Fire Drill
P. 19	Emergency Drill Report (SAMPLE)
P. 20	Control of Fire Hazards
P. 21	Alternative Measures for Occupant Safety
P. 23	Notice Detection System Out of Service
P. 24	Fire Protection Components
P. 25	Maintenance of Building Facilities & Fire Protection Equipment
P. 29	Schematics (Site Plan and Floor Plans)

## **INTRODUCTION**

This Fire Safety Plan is required by the Ontario Fire Code, Section 2.8

This Fire Safety Plan is designed to provide occupant safety in the event of fire, to provide effective utilization of the fire safety features of the building and to minimize the possibility of fires. This plan discusses what occupants are to do in the event of fire, fire safety, supervisory staff and related duties, and other related issues.

The Fire Safety Plan will also assist firefighters in the performance of their duties, by providing floor plans and building information, if an emergency ever occurs.

In order for this plan to be effective, management must know the Fire Safety Plan and be able to implement it in the event of fire. The Fire Code requires the owner to be responsible for carrying out the provisions for fire safety, and defines “owner” as “any person, firm or corporation controlling the property under consideration”. Consequently, the owner may be any one of, or a combination of parties, including building management, maintenance staff and tenant groups.

This official document is to be kept readily available at all times for use by staff and fire officials in the event of an emergency. The fire safety plan approved location is the Fire Safety Plan box at the front entrance of the building.

The fire safety plan shall be stored in a white box with contrasting lettering indicating FIRE SAFETY PLAN. The box shall be secured with a padlock to prevent unauthorized access with a spare padlock located inside the box. The box shall be located near the main entrance to the office building which is the main access point for the fire service.

Submission Procedures:

At least one (1) copy of the Plan (8 ½ X 11 format) must be submitted to the Chief Fire Official. Upon approval, two (2) more copies of the plan will be submitted to the Chief Fire Official. Two copies of the plan will be retained by the Fire Department, and one copy returned to the author.

**The Chief Fire Official is to be notified regarding any subsequent changes in the approved Fire Safety Plan. The Fire Safety Plan shall be reviewed as often as necessary, but at least every 12 months, and shall be revised as necessary so that it takes into account changes in the uses or other characteristics of the building or premises.**

## ONTARIO FIRE CODE DEFINITIONS

### Excerpts from The Ontario Fire Code

**Article 1.2.1.1.** - Unless otherwise specified the Owner is responsible for carrying out the provisions of this code.

**Article 1.1.2.3.** - The original or a copy of any record required by this Code shall be made available to the **Chief Fire Official** for examination on request.

### Definitions

**CHECK** - Means visual observation to ensure the device or system is in place and is not obviously damaged or obstructed.

**INSPECT** - Means physical examination to determine that the device or system will apparently perform in accordance with its intended function.

**TEST** - Means the operation of a device or system to ensure that it will perform in accordance with its intended operation or function.

**OWNER** - Means any person, firm or corporation having control over any portion of the **building** or property under consideration and includes the persons in the **building** or property.

**BUILDING** - Means any structure used or intended for supporting or sheltering any use or **occupancy**.

**SUPERVISORY STAFF** - Means those occupants of a **building** who have some delegated responsibility for the fire safety of other occupants under the fire safety plan and may include the **fire department** where the **fire department** agrees to accept these responsibilities.

## **FIRE SAFETY PLAN APPROVED LOCATION**

The Fire Safety Plan shall be stored in a white box with contrasting lettering indicating FIRE SAFETY PLAN. The box shall be secured with a padlock to prevent unauthorized access, with a spare padlock located inside the box. The box shall be located near the main entrance to the building which is the main access point for the fire service.

## **FIRE SAFETY PLAN REVIEW REQUIREMENTS**

The Fire Safety Plan shall be reviewed as often as necessary, but at least every 12 months, and shall be revised as necessary so that it takes into account changes in the uses or other characteristics of the building or premises.

## **FIRE EMERGENCY PROCEDURES POSTED AND MAINTAINED**

At least one copy of the **Fire Emergency Procedures for Occupants** (Page 16 of this document) shall be prominently posted and maintained on each floor area.



## **AUDIT OF BUILDING RESOURCES**

**OCCUPANCY TYPE:** D and F3

**OCCUPANT LOAD:** Less than 6 persons

**PRINCIPAL ENTRANCE FOR FIRE DEPARTMENT RESPONSE:** Private driveway from Sobie Road

**EXITS:** See schematics

**NO. OF BUILDINGS:** 2 (Office and Workshop)

**AREA:** Tanks and bladders = approx. 11 780 m<sup>3</sup>. Office space 30 m<sup>2</sup> approx. Workshop 30 m<sup>2</sup> approx.

**TYPE OF CONSTRUCTION:** Combination of combustible and non-combustible

**YEAR OF CONSTRUCTION:** 2017

**EMERGENCY GENERATOR:** No

**HEATING SYSTEM (TYPE):** Two types:

1. Engine Heat (Fire Services should NOT shut down the engine heat until a site supervisor has arrived to assist in the shutdown)
2. Lochinvar Propane Boiler (Closed glycol-based system which covers in-floor and sides of tanks)

**MAIN GAS SHUT OFF LOCATION:** Three (one for back-up heater, two for the flare)

**MAIN ELECTRICAL SHUT OFF LOCATION:** Inside the transfer compound (fenced in)

**WATER MAIN SHUT OFF LOCATION:** No water on site

**HVAC UNITS:** No

**ROOF ACCESS:** Dirt ramp from the driveway. Roof is not to be accessed without authorization from Escarpment Renewables staff

**ATTIC ACCESS:** No

**FIRE DEPARTMENT ACCESS:** From the driveway off Sobie Road

**DESIGNATED FIRE ROUTE:** Private driveway around the building complex

**FIRE DEPARTMENT KEY BOX:** No

**FIRE DEPARTMENT CONNECTION (SPRINKLER/STANDPIPE):** No

**NEAREST HYDRANT LOCATION:** Sobie Road at Park Road

**HOSE CABINETS:** No

**FIRE PUMP:** No

**SPRINKLER SYSTEM (TYPE):** No

**AREA OF COVERAGE FOR SPRINKLERS:** Not applicable

**SPRINKLER SHUT OFF OR ISOLATION VALVES:** Not applicable

**DETECTION SYSTEM:** Methane detectors, Hydrogen Sulphide detectors, Carbon Dioxide detectors and LEL detectors

**SECONDARY POWER SUPPLY:** No back-up power

**MONITORED:** The detection system is monitored by Escarpment Renewables site computer system. When a detection device is activated, the computer system generates a notification to the cell phones of Escarpment Renewables employees. The employees are required to acknowledge the notification and attend at the site.

**EXITS FROM THE BUILDING:** See schematics

**NO. OF STAIRWELLS:** None. The quad building has below grade ladders in the tank room

**EMERGENCY POWER AND LIGHTING:** No

**PORTABLE FIRE EXTINGUISHERS:** All structures have ABC or CO2 Extinguishers installed at doorways/exits

**HAZARDOUS PROCESSING AREAS:** Yes - Digester Tanks

**WARNING:** The bladders contain bio-gas, methane, hydrogen sulphide, carbon dioxide, and LEL. Breathing in these gases could be fatal. Exercise caution, wear ALTAIR 4X monitors if you enter into the area. Wear SCBA when required

**STORAGE AREAS:** On site trailer storage

### **DESCRIPTION OF SITE:**

This site contains the following major components (see site plan):

1. Building - houses methane bags (grounding all around the building)
2. Engine and carbon filtration system (Contains main breaker for site. Fire Services should NOT shut off main electrical until Niagara Power staff or Escarpment Renewables attend the site to assist with the shut off)
3. Office Building
4. Weighing Scale
5. Two digestate storage tanks
6. Two digester tanks
7. Plug flow digester
8. Pre-storage underground tank
9. Front-end gravity feeder
10. Separation pump (pumphouse)
11. Bunker area for solid ASM and NASM storage
12. Leachate sedimentation pond which receives run-off rainwater from the bunker area
13. Fresh water drainage pond
14. Workshop and spare parts warehouse
15. Propane Tanks (3)
16. Diesel Fuel Tank (for telehandler)
17. Two main power lines - one for the office, the other for the rest of the site

## **AUDIT OF HUMAN RESOURCES**

**BUILDING OWNER:** Escarpment Renewables

**BUILDING OWNER ADDRESSES AND PHONE NUMBERS:**

424 Sobie Rd, Grimsby L3M 4E7  
(905) 228-1506

**PROPERTY EMERGENCY CONTACTS:**

James Thomson – 289-455-1115  
Kyle Howes – 905-208-2492  
Sam Huang – 416-991-4786

**PORTABLE FIRE EXTINGUISHER CONTACT:** Fire Safety House – 905-878-8303

**PREMISES OCCUPIED BY:** Escarpment Renewables

## **OWNER/MANAGER RESPONSIBILITIES FOR FIRE SAFETY**

The building owner has numerous responsibilities related to fire safety and has responsibility for carrying out the provisions of the Ontario Fire Code. "Owner" means any person, firm, corporation having control over any portion of the building or property under consideration and includes the persons in the building or property. The Building Owner must appoint a Fire Safety Coordinator to be responsible for the overall fire safety within the building. The Fire Safety Coordinator must ensure that all staff and responsible persons are properly trained before giving them any responsibilities under the Fire Safety Plan.

The owner must ensure that the following measures are enacted:

1. Keep a copy of the approved Fire Safety Plan on the premises in an approved location. Ensure that all provisions set out in the Plan are carried out
2. The Fire Safety Plan shall be reviewed as often as necessary, but at least every 12 months, and shall be revised as necessary so that it takes into account changes in the use or other characteristics of the building premises
3. Ensure the Fire Safety Plan is current. The Chief Fire Official shall be notified regarding any changes in the Fire Safety Plan
4. Ensure that the Fire Safety Plan, or parts thereof, are distributed to all occupants.
5. Post and maintain at least one (1) copy of the "Emergency Procedures for Occupants" (page 17 of this document) on each floor level
6. Appoint and organize designated supervisory staff to carry out fire safety duties. Each supervisory staff person shall be provided with a copy of their duties as identified in the Fire Safety Plan
7. Provide for the instruction and training of supervisory staff, and other occupants, so that they are aware of their responsibilities for fire safety
8. Records of training of supervisory staff are to be kept on site. Such training will take place prior to anyone assuming fire safety duties under this Plan
9. Designate and train alternates to replace supervisory staff during any absence
10. Holding of fire drills in accordance with the Ontario Fire Code, incorporating emergency procedures appropriate to the site
11. Control of fire hazards in the buildings and on site
12. Maintenance of building facilities provided for the safety of occupants
13. Ensuring that checks, tests and inspections as required by the Ontario Fire Code are completed on schedule and that records are kept for a minimum period of 2 years

## APPOINTMENT OF DESIGNATED SUPERVISORY STAFF

This fire safety plan includes the appointment and organization of designated “**supervisory staff**” and alternates who are required to be trained to respond to a fire emergency in a predetermined manner. Supervisory staff duties and responsibilities are outlined in this fire safety plan. The person(s) designated as supervisory staff must be qualified and willing to take on the added duties and responsibilities. The person(s) who is designated as “supervisory staff” does not have to be from management or be a supervisor from the company/organization.

OFC 2.8.1.2 (1) **Supervisory Staff** shall be instructed in the fire emergency procedures as described in the fire safety plan before they are given any responsibility for fire safety.

(2) **Supervisory Staff** shall be available on notification of a fire emergency to fulfill their obligation as described in the fire safety plan.

(3) Subject to Article 2.8.2.2, **Supervisory Staff** are not required to be in the **building** on a continual basis.

### **Identification of Supervisory Staff: (\*and the alternate)**

Role	Supervisory Staff	Alternates
Fire Warden	James Thomson	Kyle Howes Sam Huang

## **TRAINING OF SUPERVISORY STAFF**

### **Training of Supervisory Staff: Escarpment Renewables**

Ongoing inspections, training and fire drills are necessary to ensure an effective fire safety program.

Training will be scheduled as often as necessary to ensure the supervisory staff know their responsibilities.

The orientation training program for supervisory staff should include fire safety instructions on: what to do upon discovery of fire and how to prevent or minimize fire hazards at the site.

All supervisory staff must know their duties when an emergency occurs and the location and operation of portable fire extinguishers.

### **General Responsibilities for Supervisory Staff**

1. Keep entrances and exits clear of any obstructions at all times
2. Do not permit combustible materials to accumulate
3. Keep access roadways and fire routes accessible at all times
4. In the event of any alert from the computer monitoring system, initiate alternative measures as specified in operational procedures for the site
5. Participate in fire drills
6. Comply with the Ontario Fire Code. Arrange for substitute in your absence

## **SUPERVISORY STAFF DUTIES AND RESPONSIBILITIES**

In order for the emergency response portion of this fire safety plan to be effectively implemented, management and every employee must understand the important role they play in promoting fire safety in the workplace. Everyone must be required to adhere to the fire safety practices and procedures. The orientation training program for all employees should include fire safety instructions on: what to do upon discovery of fire and how to prevent or minimize fire hazards in the workplace. A copy of the Fire Emergency Procedures and other duties outlined in the fire safety plan must be given to all supervisory staff.

Supervisory Staff must have a working knowledge of the site detection system and should know how to operate a portable fire extinguisher.



## **SITE STAFF DUTIES AND RESPONSIBILITIES**

### **In General:**

1. Staff must read the Fire Safety Plan each year in order to understand emergency procedures
2. Keep access to entrances and EXITS, inside and outside, clear of any obstructions at all times
3. Do not permit combustible materials to accumulate in quantities or locations that would constitute a fire hazard
4. Promptly remove all combustible waste from areas where waste is placed for disposal, if applicable
5. Participate in fire drills
6. Have a working knowledge of the site safety systems
7. Report any deficiencies to the Fire Warden
8. Comply with the Ontario Fire Code

## **SUPERVISORY STAFF EMERGENCY PROCEDURES**

### **Upon discovery of smoke or fire:**

1. Alert occupants and leave the fire area
2. Close all doors behind you - Yell "FIRE, FIRE, FIRE!"
3. Make provisions or take precautions to confine, control, and extinguish the fire if safe to do so

You may attempt to fight the fire if it is safe to do so, and if you have been trained on the use of portable fire extinguishers

4. Assist occupants to evacuate the building if safe to do so
5. Exit the building using the nearest exit. If you encounter smoke or fire, use an alternate exit
6. Call the Fire Service, from a safe location, by dialing 9-1-1, provide the correct address and location of the fire, and your name
7. Designate a person to proceed to the main entrance to meet Fire Service personnel

### **Upon arrival of Fire Department:**

1. Inform the Fire Officer regarding conditions in the building
2. Provide fire personnel access, vital information and any emergency keys

## **EMERGENCY PROCEDURES FOR OCCUPANTS**

### **Upon discovery of fire:**

1. Leave the fire area, closing all doors behind you
2. Alert other occupants of the building - Yell "FIRE, FIRE, FIRE!"
3. Make provisions or take precautions to confine, control, and extinguish the fire if safe to do so

You may attempt to fight the fire if it is safe to do so, and if you have been trained on the use of fire extinguishers

4. Use the nearest exit to leave the building
5. Telephone the FIRE SERVICE, from a safe location, dial 9-1-1. Never assume that this has been done
6. Give the correct site address (424 Sobie Rd., Grimsby) and location of the fire and your name
7. Proceed to the designated meeting area (see below)
8. Do not return until it is declared safe to do so by a Fire Official

**DESIGNATED MEETING AREA: Sobie Road, outside the front gate at the front of the site – NOTE: Depending on wind direction, occupants may be directed to a secondary area**

## **FIRE DRILL PROCEDURES AND TRAINING**

The purpose of a fire drill is to ensure that the Supervisory Staff and occupants are familiar with emergency evacuation procedures. This will ensure an orderly evacuation should it become necessary. The Fire Drill will be prepared in consultation with the Chief Fire Official.

It is the responsibility of **Escarpment Renewables** to schedule the annual drill. Advance notice (at least 48 hours), should be posted advising the occupants of the time and date of these drills. Notify the **Fire Service Dispatch** prior to any drill. Dial **905-684-4311**. Give the address of the site, your name and the expected duration of the drill. Simulate a fire emergency and alert persons on site by yelling "FIRE, FIRE, FIRE!" or using cell phones. Record the actions of the occupants and staff. Note any deficiencies/ problems. Contact the Fire Service upon completion of drill.

Following each drill, all Supervisory Staff and occupants should attend a debriefing to report on their observations. Fire drills must be conducted in accordance with the FIRE CODE. All fire drill records must be retained and kept on site for 12 months after the fire drill.

NOTE: For **this building complex (Bio-Digester Facility)**, the Ontario Fire Code requires that fire drills be conducted **annually**.

## **ORGANIZING AND CONDUCTING A FIRE DRILL**

Fire drills must be conducted on a frequency set out by the Ontario Fire Code 2.8.3.2. All employees/occupants understand the procedures to be followed in an emergency. Employees are trained to safely shut down critical systems or equipment they are using during an emergency in order to prevent further hazards.

A person is designated to respond to the safety needs of any guests or contractors during an emergency.

All fire drill records must be retained and kept on site for 12 months after the fire drill.

A procedure is established to evaluate the fire drill once it has been completed. (see sample below).



# EMERGENCY DRILL REPORT

**FORM NUMBER:**  
FOR-SAF-021 Rev. 1

**SAFETY FORM**  
**DISTRIBUTION:** All Locations

**PAGES:** 1  
**REVISION DATE:**  
January 1, 2021

<b>Date of Drill:</b>		<b>Time of Drill:</b>	
<b>Location:</b>			
<b>Type of Drill:</b>	<input type="checkbox"/> Planned	<input type="checkbox"/> False Alarm	
<b>Type of Emergency:</b>	<input type="checkbox"/> Fire	<input type="checkbox"/> Other Emergency:	
<b>Total Time Required to Evacuate Facility:</b>		Minutes	Seconds

<b>Did All Personnel Evacuate Facility?</b>	<input type="checkbox"/> Yes	<input type="checkbox"/> No
<b>Did All Personnel Meet at the Designated Area?</b>	<input type="checkbox"/> Yes	<input type="checkbox"/> No
<b>Did you identify any individuals with disabilities or injuries in need of assistance?</b>	<input type="checkbox"/> Yes	<input type="checkbox"/> No
<b>If yes, were they evacuated safely?</b>	<input type="checkbox"/> Yes	<input type="checkbox"/> No
<b>If "NO", why not?</b>		

<b>Rate the Overall Effectiveness of the Drill:</b>			
<b>Speed of Evacuation</b>	<input type="checkbox"/> Good	<input type="checkbox"/> Fair	<input type="checkbox"/> Poor
<b>Effectiveness of Procedures</b>	<input type="checkbox"/> Good	<input type="checkbox"/> Fair	<input type="checkbox"/> Poor
<b>Communication During Drill</b>	<input type="checkbox"/> Good	<input type="checkbox"/> Fair	<input type="checkbox"/> Poor

<b>Names of Supervisory/Management Staff Present:</b>	
1.	2.
3.	4.
<b>Corrective Action Required:</b>	
<b>Additional Comments:</b>	
<b>Report Completed By:</b>	<b>Date:</b>

## **CONTROL OF FIRE HAZARDS**

### **Industrial Properties**

1. Do not store combustible material in non-approved areas
2. Ensure that fire and smoke barrier doors are operating properly and are never wedged open
3. Avoid improper storage of flammable liquids and gases
4. Never use defective electrical appliances, frayed extension cords, overloaded outlets or extension cords for permanent wiring
5. Avoid careless use of smoking materials
6. Never improperly dispose of oily rags.

### **Specific to this Site**

If any operations are conducted near a bio gas building, precautions must be taken to avoid rupturing any tanks or pipes located above or below ground.

Upon arrival of delivery trucks, drivers must be stopped and on-site staff will provide direction as to delivery operations.

All arriving drivers and/or contractors will be met by site personnel and will be provided with a verbal summary of site safety precautions.

Contractors will be briefed as to site safety operations before any work is commenced.

## **ALTERNATIVE MEASURES FOR OCCUPANT SAFETY**

Where possible, all staff and occupants should be made aware of temporary shutdowns of site safety and detection components. All shut-downs will be confined to as limited an area and duration as possible.

The **OWNER** is responsible for the safety of occupants at all times.

In the event of shut-down, or operational problems with building safety or detection systems, the owner or their representative will initiate alternative measures as noted:

**Notification:** Occupants will be notified and instructions will be posted as to alternative measures or actions to be taken in case of emergency.

### **Shut Down Procedure:**

1. The Fire Warden will notify Grimsby Fire Department Dispatch at (905) 684-4311. Provide your name, address of the site and a description of the problem and when you expect it to be corrected.
2. Notices are to be posted outside all affected buildings stating the problem and when it is expected to be corrected. (sample notice is provided herein – page 23)
3. Notify the Fire Department and the building occupants when repairs have been completed and systems are operational.

### **Hot Works:**

Hot works (such as, but not limited to, roofing or welding) must have precautions put into place before the work commences. Fire hazards and preventative measures must be identified. The owner and/or managers must take the lead role in identifying these potential fire hazards and establishing fire prevention practices to safely eliminate or control the hazard.



**Subsection 2.8.2.1. (5) of the Ontario Fire Code sets out the following:**

*Before demolition or construction, including hot surface applications, commences in or on the building or premises, the fire safety plan shall be revised to incorporate*

- (a) temporary alternative measures for the fire safety of the occupants during the demolition or construction, and*
- (b) temporary procedures to control fire hazards associated with the demolition or construction, including procedures to mitigate risks to adjacent buildings.*

Examples of temporary alternative measures and temporary procedures may include (but are not limited to):

The owner/manager (Escarpment Renewables) must review the scope of all hot works procedures before they commence. All hot works procedures will be monitored by institution of a Fire Watch. The Fire Watch will continue throughout the duration of the work activity and for a period of thirty (30) minutes minimum after completion of the work. Fire Watch procedures shall be documented, as set out in this plan, and records are to be maintained for a period of two years. Employees must be fully trained in the established fire prevention practices. Appropriately sized and type of fire extinguisher shall be readily available. Employees shall be trained in the use of such fire extinguishers.

# **IMPORTANT NOTICE**

## **Detection System Out of Service**

The Detection System may not function if there is a leak

The Detection system is being serviced by qualified personnel and will be restored as quickly as possible

The building is not to be occupied while the Detection System is out of service

If you discover a fire:

- Shout “FIRE, FIRE, FIRE!” to warn others
- Leave the area using your nearest exit
- Use alternate exit if required
- Call 9-1-1 to notify Fire Department
- If you hear someone shouting “FIRE”, leave the area immediately

When the detection system is back in service, this notice will be removed.

If you require further information - Site contact person and phone number is: James Thomson – 289-455-1115

## **FIRE PROTECTION COMPONENTS**

### **EXITS:**

An exit is that part of a means of egress that leads from the floor area it serves to a public thoroughfare or to an approved open space. Walls, floors, doors and other means provide a protected path necessary for occupants to proceed with reasonable safety to a place of refuge.

### **FIRE DEPARTMENT ACCESS:**

Fire Department access allows firefighters and their equipment to gain access to the building. Vehicles parked in a Fire Route, excess vegetation, snow and other forms of obstructions to access routes, fire hydrants and Fire Dept. connections are not permitted by the Fire Code. Maintaining Fire Dept. access is an ongoing matter. In addition, access into a building requires consideration e.g. with a key box and thorough preplanning.

### **PORTABLE EXTINGUISHERS:**

Portable extinguishers are intended as a first aid measure to cope with fires of limited size. The basic types of fires are Class A, B and C. Portable extinguishers are rated for corresponding classes of fires.

## **MAINTENANCE OF BUILDING FACILITIES AND FIRE PROTECTION EQUIPMENT**

This Fire Safety Plan contains a detailed schedule identifying the required checks, inspections and tests of all fire safety systems and features provided. Ontario Fire Code definitions of key words are as follows:

- CHECK        Means a visual observation to ensure the device or system is in place, and is not obviously damaged or obstructed.
- INSPECT     Means physical examination to determine that the device or system will apparently perform in accordance with its intended function.
- TEST         Means the operation of a device or system to ensure that it will perform in accordance with its intended operation or function.

### **The building owner/manager must:**

Ensure that all fire protection features provided in each building are checked, inspected, tested and maintained in accordance with the frequencies specified in Division B Part 2 and Part 6 of the Fire Code and all applicable referenced standards.

When using in-house personnel to conduct some of these checks, inspections and tests, ensure that the person is fully trained and qualified to carry out the activity. Keep permanent records of all tests and corrective measures taken for a period of two years after they are made. The records are to be made available upon request to the Chief Fire Official.

## **FIRE SAFETY MAINTENANCE DUTIES**

### **LEL, CARBON MONOXIDE, CARBON DIOXIDE, METHANE AND HYDROGEN SULPHIDE DETECTORS** **(also reference manufacturer's instructions)**

<b>Action</b>	<b>Frequency</b>	<b>Responsibility</b>
Maintain all types of detectors as recommended by the manufacturer.	Annually	Owner
Test alarm functions as recommended by the manufacturer.	Annually	Owner
Replace all detectors.	On a frequency prescribed by the manufacturer	Owner

## PORTABLE FIRE EXTINGUISHERS

NFPA 10 sets out details for maintenance guidelines for portable fire extinguishers.

<b>Action</b>	<b>Frequency</b>	<b>Responsibility</b>
Each extinguisher shall have a securely attached tag showing the maintenance or recharge date, the servicing agency, and the signature of the person who performed the service.	Annually	Contractor
A permanent record containing all the inspection and maintenance conducted on all of the portable fire extinguishers shall be maintained for a period of at least 2 years and be made available to the Chief Fire Official upon request.	Annually	Contractor
Portable extinguishers shall be inspected as follows: <ul style="list-style-type: none"> <li>- Check nozzle for operation and any obstructions</li> <li>- Seal or tamper indicators are in place</li> <li>- Pressure gauge is reading satisfactorily</li> <li>- No apparent physical or mechanical damage</li> <li>- Instructions for use on name plate are legible and face outward</li> </ul>	Monthly	Contractor
Extinguishers shall be subject to maintenance not more than one year apart or when specifically indicated by an inspection. Maintenance procedures shall include a thorough examination of the 3 basic elements of an extinguisher: mechanical parts, extinguishing agent and expelling means	Annually	Contractor
Stored pressure extinguishers which require a 12 year hydrostatic test shall be emptied and subject to applicable maintenance procedures.	Every 6 years	Contractor
Hydrostatically test dry chemical and vaporizing liquid type extinguishers.	Every 12 years	Contractor

### MEANS OF EGRESS

<b>Action</b>	<b>Frequency</b>	<b>Responsibility</b>
Inspect all doors in fire separations.	Monthly	Owner
Check all doors and fire separations to ensure they are closed.	Daily	Owner
Maintain exit signs to ensure they are clean, legible, illuminated and in good repair.	Daily	Owner
Ensure corridors and exits are free of obstructions.	Daily	Owner

### FIRE DEPARTMENT ACCESS


<b>Action</b>	<b>Frequency</b>	<b>Responsibility</b>
Ensure that fire access routes are maintained so as to be immediately ready for use at all times by fire department vehicles.	Daily	Owner

### ELECTRICAL DISCONNECT SWITCHES

<b>Action</b>	<b>Frequency</b>	<b>Responsibility</b>
Disconnect switches for ventilating systems shall be inspected to establish that the system can shut down in an emergency.	Annually	Owner

## **SCHEMATICS**





**LEGEND**

- Portable Fire Extinguisher
- Gas Detectors
- Diverter Valves
- Electrical Panels
- Emergency Stop
- Diesel Fuel Tank (2200L)
- Propane


Grimsby Energy Inc.  
442 Sobie Rd.  
ANAEROBIC DIGESTER

Building Layout  
July 2019



**Trillium Fire Protection**  
905-684-0196  
mpdagnew@gmail.com

#11



**LEGEND**

-  Fire Hydrant
-  Gas Detectors
-  Diesel Fuel Tank
-  Propane Tank
-  Evacuation Meeting Place

Grimsby Energy Inc.  
442 Sobie Rd.

**ANAEROBIC DIGESTER**

Site Plan  
July 2019



Trilium Fire Protection  
905-684-0196  
mpdagnew@gmail.com

# FIRE SAFETY PLAN

Bio-Digester Facility

Grimsby Energy Inc.

424 Sobie Rd., Grimsby ON L3M 4E7

**HAZARDOUS PROCESSING AREAS:** Yes - Digester tanks.

**WARNING:** The bladders contain bio-gas, methane, hydrogen sulphide, carbon dioxide, and LEL. **Breathing in these gases could be fatal.** Exercise caution, wear ALTAIR 4X monitors if you enter into the area. Wear SCBA).

This approved document shall be kept readily available on the premises in the Fire Safety Plan box at all times, for use by fire officials in case of an emergency.

The designated location of the Fire Safety Plan is in the Main Office.

Fire Safety Plan prepared by:

Michael Agnew - Trillium Fire Protection (905)-684-0196

Mark Berti - Fire Safety One (905) 988-7734

Date of Submission: (Sept. 5th, 2019)

Revision Date: \_\_\_\_\_

Revision Date: \_\_\_\_\_



## TABLE OF CONTENTS

P. 2	Introduction
P. 4	Ontario Fire Code Definitions
P. 5	Fire Safety Plan Approved Location
P. 5	Fire Safety Plan Review Requirements
P. 5	Fire Emergency Procedures Posted & Maintained
P. 6	Audit of Building Resources
P. 9	Audit of Human Resources
P. 10	Owner/Manager Responsibilities for Fire Safety
P. 12	Appointment of Designated Supervisory Staff
P. 13	Training of Supervisory Staff
P. 14	Supervisory Staff Duties and Responsibilities
P. 15	Site Staff Duties and Responsibilities
P. 16	Supervisory Staff Emergency Procedures
P. 17	Emergency Procedures for Occupants
P. 18	Fire Drill Procedures & Training
P. 19	Organizing & Conducting a Fire Drill
P. 20	Control of Fire Hazards
P. 21	Alternative Measures for Occupant Safety
P. 23	Notice Detection System Out of Service
P. 24	Fire Protection Components
P. 25	Maintenance of Building Facilities & Fire Protection Equipment
P. 29	Schematics (Site Plan and Floor Plans)

## **INTRODUCTION**

This Fire Safety Plan is required by the Ontario Fire Code, Section 2.8

This Fire Safety Plan is designed to provide occupant safety in the event of fire, to provide effective utilization of the fire safety features of the building and to minimize the possibility of fires. This plan discusses what occupants are to do in the event of fire, fire safety, supervisory staff and related duties, and other related issues.

The Fire Safety Plan will also assist firefighters in the performance of their duties, by providing floor plans and building information, if an emergency ever occurs.

In order for this plan to be effective, management must know the Fire Safety Plan and be able to implement it in the event of fire. The Fire Code requires the owner to be responsible for carrying out the provisions for fire safety, and defines "owner" as "any person, firm or corporation controlling the property under consideration". Consequently, the owner may be any one of, or a combination of parties, including building management, maintenance staff and tenant groups.

This official document is to be kept readily available at all times for use by staff and fire officials in the event of an emergency. The fire safety plan approved location is the Fire Safety Plan box at the front entrance of the building.

The fire safety plan shall be stored in a white box with contrasting lettering indicating FIRE SAFETY PLAN. The box shall be secured with a padlock to prevent unauthorized access with a spare padlock located inside the box. The box shall be located near the main entrance to the office building which is the main access point for the fire service.

Submission Procedures:

At least one (1) copy of the Plan (8 ½ X 11 format) must be submitted to the Chief Fire Official. Upon approval, two (2) more copies of the plan will be submitted to the Chief Fire Official. Two copies of the plan will be retained by the Fire Department, and one copy returned to the author.

**The Chief Fire Official is to be notified regarding any subsequent changes in the approved Fire Safety Plan. The Fire Safety Plan shall be reviewed as often as necessary, but at least every 12 months, and shall be revised as necessary so that it takes into account changes in the uses or other characteristics of the building or premises.**

## ONTARIO FIRE CODE DEFINITIONS

### Excerpts from The Ontario Fire Code

**Article 1.2.1.1.** - Unless otherwise specified the Owner is responsible for carrying out the provisions of this code.

**Article 1.1.2.3.** - The original or a copy of any record required by this Code shall be made available to the **Chief Fire Official** for examination on request.

### Definitions

**CHECK** - Means visual observation to ensure the device or system is in place and is not obviously damaged or obstructed.

**INSPECT** - Means physical examination to determine that the device or system will apparently perform in accordance with its intended function.

**TEST** - Means the operation of a device or system to ensure that it will perform in accordance with its intended operation or function.

**OWNER** - Means any person, firm or corporation having control over any portion of the **building** or property under consideration and includes the persons in the **building** or property.

**BUILDING** - Means any structure used or intended for supporting or sheltering any use or **occupancy**.

**SUPERVISORY STAFF** - Means those occupants of a **building** who have some delegated responsibility for the fire safety of other occupants under the fire safety plan and may include the **fire department** where the **fire department** agrees to accept these responsibilities.

### **FIRE SAFETY PLAN APPROVED LOCATION**

The Fire Safety Plan shall be stored in a white box with contrasting lettering indicating FIRE SAFETY PLAN. The box shall be secured with a padlock to prevent unauthorized access, with a spare padlock located inside the box. The box shall be located near the main entrance to the building which is the main access point for the fire service.

### **FIRE SAFETY PLAN REVIEW REQUIREMENTS**

The Fire Safety Plan shall be reviewed as often as necessary, but at least every 12 months, and shall be revised as necessary so that it takes into account changes in the uses or other characteristics of the building or premises.

### **FIRE EMERGENCY PROCEDURES POSTED AND MAINTAINED**

At least one copy of the **Fire Emergency Procedures for Occupants** (Page 17 of this document) shall be prominently posted and maintained on each floor area.



## **AUDIT OF BUILDING RESOURCES**

**OCCUPANCY TYPE:** D and F3

**OCCUPANT LOAD:** Less than 6 persons

**PRINCIPAL ENTRANCE FOR FIRE DEPARTMENT RESPONSE:** Private driveway from Sobie Road

**EXITS:** See schematics

**NO. OF BUILDINGS:** 2 (Office and Workshop)

**AREA:** Tanks and bladders = approx 11 780 m<sup>3</sup>. Office space 30 m<sup>2</sup> approx. Workshop 30 m<sup>2</sup> approx.

**TYPE OF CONSTRUCTION:** Combination of combustible and non-combustible

**YEAR OF CONSTRUCTION:** 2017

**EMERGENCY GENERATOR:** No

**HEATING SYSTEM (TYPE):** Two types:

1. Engine Heat (Fire Services should NOT shut down the engine heat until a site supervisor has arrived to assist in the shut down)
2. Lochinvar Propane Boiler  
(Closed glycol based system which covers in-floor and sides of tanks).

**MAIN GAS SHUT OFF LOCATION:** Three. ( one for back-up heater, two for the flare)

**MAIN ELECTRICAL SHUT OFF LOCATION:** Inside the transfer compound (fenced in)

**WATER MAIN SHUT OFF LOCATION:** No water on site

**HVAC UNITS:** No

**ROOF ACCESS:** Dirt ramp from the driveway. Roof is not to be accessed without authorization from Grimsby Energy Inc. staff.

**ATTIC ACCESS:** No

**FIRE DEPARTMENT ACCESS:** From the driveway off Sobie Road

**DESIGNATED FIRE ROUTE:** Private driveway around the building complex

**FIRE DEPARTMENT KEY BOX:** No

**FIRE DEPARTMENT CONNECTION (SPRINKLER/STANDPIPE):** No

**NEAREST HYDRANT LOCATION:** Sobie Road at Park Road

**HOSE CABINETS:** No

**FIRE PUMP:** No

**SPRINKLER SYSTEM (TYPE):** No

**AREA OF COVERAGE FOR SPRINKLERS:** Not applicable

**SPRINKLER SHUT OFF OR ISOLATION VALVES:** Not applicable

**DETECTION SYSTEM:** Methane detectors, Hydrogen Sulphide detectors, Carbon Dioxide detectors and LEL detectors.

**SECONDARY POWER SUPPLY:** No back-up power

**MONITORED:** The detection system is monitored by Grimsby Energy Inc. site computer system. When a detection device is activated, the computer system generates a notification to the cell phones of Grimsby Energy Inc. employees. The employees are required to acknowledge the notification and attend at the site.

**EXITS FROM THE BUILDING:** See schematics

**NO. OF STAIRWELLS:** None. The quad building has below grade ladders in the tank room.

**EMERGENCY POWER AND LIGHTING:** No

**PORTABLE FIRE EXTINGUISHERS:** To be installed

**HAZARDOUS PROCESSING AREAS:** Yes - Digester tanks. **WARNING:** The bladders contain bio-gas, methane, hydrogen sulphide, carbon dioxide, and LEL. Breathing in these gases could be fatal. Exercise caution, wear ALTAIR 4X monitors if you enter into the area. Wear SCBA).

**STORAGE AREAS:** On site trailer storage

**DESCRIPTION OF SITE:**

This site contains the following major components (see site plan):

1. Building - houses methane bags (grounding all around the building)
2. Engine and carbon filtration system (Contains main breaker for site. Fire Services should NOT shut off main electrical until Niagara Power staff or Grimsby Energy Staff attend the site to assist with the shut off)
3. Office Building
4. Weighing Scale
5. Two digestate storage tanks
6. Two digester tanks
7. Plug flow digester
8. Pre-storage underground tank
9. Front-end gravity feeder
10. Separation pump (pumphouse)
11. Bunker area for solid ASM and NASM storage
12. Leachate sedimentation pond which receives run-off rainwater from the bunker area.
13. Fresh water drainage pond
14. Workshop and spare parts warehouse
15. Propane Tanks (3)
16. Diesel Fuel Tank (for loader)
17. Two main power lines - one for the office, the other for the rest of the site

## **AUDIT OF HUMAN RESOURCES**

**BUILDING OWNER:** Grimsby Energy Incorporated

**BUILDING OWNER ADDRESSES AND PHONE NUMBERS:**

424 Sobie Rd, Grimsby L3M 4E7  
(905) 228-1506

**PROPERTY EMERGENCY CONTACTS:**

Adam Farkas (289) 214-4603  
Greg Wilson (289) 260-2351  
Tom Ferencevic (289) 668-0201

**PORTABLE FIRE EXTINGUISHER CONTACT:** To be determined

**PREMISES OCCUPIED BY:** Grimsby Energy Incorporated

## **OWNER/MANAGER RESPONSIBILITIES FOR FIRE SAFETY**

The building owner has numerous responsibilities related to fire safety and has responsibility for carrying out the provisions of the Ontario Fire Code. "Owner" means any person, firm, corporation having control over any portion of the building or property under consideration and includes the persons in the building or property. The Building Owner must appoint a Fire Safety Coordinator to be responsible for the overall fire safety within the building. The Fire Safety Coordinator must ensure that all staff and responsible persons are properly trained before giving them any responsibilities under the Fire Safety Plan.

The owner must ensure that the following measures are enacted:

1. Keep a copy of the approved Fire Safety Plan on the premises in an approved location. Ensure that all provisions set out in the Plan are carried out.
2. The Fire Safety Plan shall be reviewed as often as necessary, but at least every 12 months, and shall be revised as necessary so that it takes into account changes in the use or other characteristics of the building premises.
3. Ensure the Fire Safety Plan is current. The Chief Fire Official shall be notified regarding any changes in the Fire Safety Plan.
4. Ensure that the Fire Safety Plan, or parts thereof, are distributed to all occupants.
5. Post and maintain at least one (1) copy of the "Emergency Procedures for Occupants" (page 17 of this document) on each floor level.
6. Appoint and organize designated supervisory staff to carry out fire safety duties. Each supervisory staff person shall be provided with a copy of their duties as identified in the Fire Safety Plan.
7. Provide for the instruction and training of supervisory staff, and other occupants, so that they are aware of their responsibilities for fire safety.
8. Records of training of supervisory staff are to be kept on site. Such training will take place prior to anyone assuming fire safety duties under this Plan.
9. Designate and train alternates to replace supervisory staff during any absence.
10. Holding of fire drills in accordance with the Ontario Fire Code, incorporating emergency procedures appropriate to the site.

11. Control of fire hazards in the buildings and on site.
12. Maintenance of building facilities provided for the safety of occupants.
13. Ensuring that checks, tests and inspections as required by the Ontario Fire Code are completed on schedule and that records are kept for a minimum period of 2 years.

## APPOINTMENT OF DESIGNATED SUPERVISORY STAFF

This fire safety plan includes the appointment and organization of designated “**supervisory staff**” and alternates who are required to be trained to respond to a fire emergency in a predetermined manner. Supervisory staff duties and responsibilities are outlined in this fire safety plan. The person(s) designated as supervisory staff must be qualified and willing to take on the added duties and responsibilities. The person(s) who is designated as “supervisory staff” does not have to be from management or be a supervisor from the company/organization.

OFC 2.8.1.2 (1) **Supervisory Staff** shall be instructed in the fire emergency procedures as described in the fire safety plan before they are given any responsibility for fire safety.

(2) **Supervisory Staff** shall be available on notification of a fire emergency to fulfill their obligation as described in the fire safety plan.

(3) Subject to Article 2.8.2.2, **Supervisory Staff** are not required to be in the **building** on a continual basis.

### **Identification of Supervisory Staff: (\*and the alternate)**

Role	Supervisory Staff	Alternates
Fire Warden	Adam Farkas	Greg Wilson Tom Ferencevic

## **TRAINING OF SUPERVISORY STAFF**

### **Training of Supervisory Staff - Grimsby Energy Inc.**

#### **Training of Supervisory Staff**

Ongoing inspections, training and fire drills are necessary to ensure an effective fire safety program.

Training will be scheduled as often as necessary to ensure the supervisory staff know their responsibilities.

The orientation training program for supervisory staff should include fire safety instructions on: what to do upon discovery of fire and how to prevent or minimize fire hazards at the site.

All supervisory staff must know their duties when an emergency occurs and the location and operation of portable fire extinguishers.

#### **General Responsibilities**

Keep entrances and exits clear of any obstructions at all times.

Do not permit combustible materials to accumulate.

Keep access roadways and fire routes accessible at all times.

In the event of any alert from the computer monitoring system, initiate alternative measures as specified in operational procedures for the site.

Participate in fire drills.

Comply with the Ontario Fire Code. Arrange for substitute in your absence.



## **SUPERVISORY STAFF DUTIES AND RESPONSIBILITIES**

In order for the emergency response portion of this fire safety plan to be effectively implemented, management and every employee must understand the important role they play in promoting fire safety in the workplace. Everyone must be required to adhere to the fire safety practices and procedures. The orientation training program for all employees should include fire safety instructions on: what to do upon discovery of fire and how to prevent or minimize fire hazards in the workplace. A copy of the Fire Emergency Procedures and other duties outlined in the fire safety plan must be given to all supervisory staff.

Supervisory Staff must have a working knowledge of the site detection system and should know how to operate a portable fire extinguisher.

## **SITE STAFF DUTIES AND RESPONSIBILITIES**

### **In General:**

Staff must read the Fire Safety Plan each year in order to understand emergency procedures.

Keep access to entrances and EXITS, inside and outside, clear of any obstructions at all times.

Do not permit combustible materials to accumulate in quantities or locations that would constitute a fire hazard.

Promptly remove all combustible waste from areas where waste is placed for disposal, if applicable.

Participate in fire drills.

Have a working knowledge of the site safety systems.

Report any deficiencies to the Fire Warden.

Comply with the Ontario Fire Code.

## **SUPERVISORY STAFF EMERGENCY PROCEDURES**

### **Upon discovery of smoke or fire:**

Alert occupants and leave the fire area.

Close all doors behind you. Yell "Fire".

(You may attempt to fight the fire if it is safe to do so, and if you have been trained on the use of portable fire extinguishers.)

Assist occupants to evacuate the building if safe to do so.

Exit the building using the nearest exit. If you encounter smoke or fire, use an alternate exit.

Call the Fire Service, from a safe location, by dialing 9-1-1, provide the correct address and location of the fire, and your name.

Designate a person to proceed to the main entrance to meet Fire Service personnel.

### **Upon arrival of Fire Department:**

Inform the Fire Officer regarding conditions in the building.

Provide fire personnel access, vital information and any emergency keys.

## **EMERGENCY PROCEDURES FOR OCCUPANTS**

### **Upon discovery of fire:**

Leave the fire area, closing all doors behind you

Alert other occupants of the building. Yell "FIRE".

Make provisions or take precautions to confine, control, and extinguish the fire if safe to do so.

You may attempt to fight the fire if it is safe to do so, and if you have been trained on the use of fire extinguishers.

Use the nearest exit to leave the building.

Telephone the FIRE SERVICE, from a safe location, dial 9-1-1. Never assume that this has been done.

Give the correct site address (424 Sobie Rd., Grimsby) and location of the fire and your name.

Proceed to the designated meeting area.

Do not return until it is declared safe to do so by a Fire Official.

**DESIGNATED MEETING AREA: Sobie Road, at the front of the site.**

## **FIRE DRILL PROCEDURES AND TRAINING**

The purpose of a fire drill is to ensure that the Supervisory Staff and occupants are familiar with emergency evacuation procedures. This will ensure an orderly evacuation should it become necessary. The Fire Drill will be prepared in consultation with the Chief Fire Official.

It is the responsibility of **Grimsby Energy Inc.** to schedule the annual drill.

Advance notice (at least 48 hours), should be posted advising the occupants of the time and date of these drills. Notify the **Fire Service Dispatch** prior to any drill. Dial **905-684-4311**. Give the address of the site, your name and the expected duration of the drill.

Simulate a fire emergency and alert persons on site by yelling "Fire" or using cell phones. Record the actions of the occupants and staff. Note any deficiencies/problems. Contact the Fire Service upon completion of drill.

Following each drill, all Supervisory Staff and occupants should attend a debriefing to report on their observations. Fire drills must be conducted in accordance with the FIRE CODE. All fire drill records must be retained and kept on site for 12 months after the fire drill.

NOTE: For **this building complex (Bio-Digester Facility)**, the Ontario Fire Code requires that fire drills be conducted **annually**.

## ORGANIZING AND CONDUCTING A FIRE DRILL

Fire drills must be conducted on a frequency set out by the Ontario Fire Code 2.8.3.2. All employees/occupants understand the procedures to be followed in an emergency. Employees are trained to safely shut down critical systems or equipment they are using during an emergency in order to prevent further hazards.

A person is designated to respond to the safety needs of any guests or contractors during an emergency.

All fire drill records must be retained and kept on site for 12 months after the fire drill.

A procedure is established to evaluate the fire drill once it has been completed. (see sample below).

### RECORD OF FIRE DRILL

Forward the Completed Record of Fire Drill to: Grimsby Energy Inc.
Date and Time of fire drill:
Name of person supervising drill and completing this report:
Management/Supervisory Personnel Present:
Time of Notification to Fire Department (prior to drill)
Observations from the drill:

---

## **CONTROL OF FIRE HAZARDS**

### **Industrial Properties**

Do not store combustible material in non-approved areas.

Ensure that fire and smoke barrier doors are operating properly and are never wedged open.

Avoid improper storage of flammable liquids and gases

Never use defective electrical appliances, frayed extension cords, overloaded outlets or extension cords for permanent wiring.

Avoid careless use of smoking materials.

Never improperly dispose of oily rags.

### **Specific to this Site**

If any operations are conducted near a bio gas building, precautions must be taken to avoid rupturing any tanks or pipes located above or below ground.

Upon arrival of delivery trucks, drivers must be stopped and on-site staff will provide direction as to delivery operations.

All arriving drivers and/or contractors will be met by site personnel and will be provided with a verbal summary of site safety precautions.

Contractors will be briefed as to site safety operations before any work is commenced.

## **ALTERNATIVE MEASURES FOR OCCUPANT SAFETY**

Where possible, all staff and occupants should be made aware of temporary shutdowns of site safety and detection components. All shut-downs will be confined to as limited an area and duration as possible.

The **OWNER** is responsible for the safety of occupants at all times.

In the event of shut-down, or operational problems with building safety or detection systems, the owner or their representative will initiate alternative measures as noted:

**Notification:** Occupants will be notified and instructions will be posted as to alternative measures or actions to be taken in case of emergency.

### **Shut Down Procedure:**

1. The Fire Warden will notify Grimsby Fire Department Dispatch at (905) 684-4311. Provide your name, address of the site and a description of the problem and when you expect it to be corrected.
2. Notices are to be posted outside all affected buildings stating the problem and when it is expected to be corrected. (sample notice is provided herein)
3. Notify the Fire Department and the building occupants when repairs have been completed and systems are operational.

### **Hot Works:**

Hot works (such as, but not limited to, roofing or welding) must have precautions put into place before the work commences. Fire hazards and preventative measures must be identified. The owner and/or managers must take the lead role in identifying these potential fire hazards and establishing fire prevention practices to safely eliminate or control the hazard.



**Subsection 2.8.2.1. (5) of the Ontario Fire Code sets out the following:**

*Before demolition or construction, including hot surface applications, commences in or on the building or premises, the fire safety plan shall be revised to incorporate*

- (a) temporary alternative measures for the fire safety of the occupants during the demolition or construction, and*
- (b) temporary procedures to control fire hazards associated with the demolition or construction, including procedures to mitigate risks to adjacent buildings.*

Examples of temporary alternative measures and temporary procedures may include (but are not limited to):

The owner/manager (Grimsby Energy Incorporated) must review the scope of all hot works procedures before they commence. All hot works procedures will be monitored by institution of a Fire Watch. The Fire Watch will continue throughout the duration of the work activity and for a period of thirty (30) minutes minimum after completion of the work. Fire Watch procedures shall be documented, as set out in this plan, and records are to be maintained for a period of two years. Employees must be fully trained in the established fire prevention practices. Appropriately sized and type of fire extinguisher shall be readily available. Employees shall be trained in the use of such fire extinguishers.

# **IMPORTANT NOTICE**

## **Detection System Out of Service**

The Detection System may not function if there is a leak.

The Detection system is being serviced by qualified personnel and will be restored as quickly as possible.

The building is not to be occupied while the Detection System is out of service.

If you discover a fire:

- Shout to warn others
- Leave the area using your nearest exit
- Use alternate exit if required
- Call 9-1-1 to notify Fire Department
- If you hear someone shouting "Fire", leave the area immediately.

When the detection system is back in service, this notice will be removed.

If you require further information - Site contact person and phone number is:

---

## **FIRE PROTECTION COMPONENTS**

### **EXITS:**

An exit is that part of a means of egress that leads from the floor area it serves to a public thoroughfare or to an approved open space. Walls, floors, doors and other means provide a protected path necessary for occupants to proceed with reasonable safety to a place of refuge.

### **FIRE DEPARTMENT ACCESS:**

Fire Department access allows firefighters and their equipment to gain access to the building. Vehicles parked in a Fire Route, excess vegetation, snow and other forms of obstructions to access routes, fire hydrants and Fire Dept. connections are not permitted by the Fire Code. Maintaining Fire Dept. access is an ongoing matter. In addition, access into a building requires consideration e.g. with a key box and thorough preplanning.

### **PORTABLE EXTINGUISHERS:**

Portable extinguishers are intended as a first aid measure to cope with fires of limited size. The basic types of fires are Class A, B and C. Portable extinguishers are rated for corresponding classes of fires.

## MAINTENANCE OF BUILDING FACILITIES AND FIRE PROTECTION EQUIPMENT

This Fire Safety Plan contains a detailed schedule identifying the required checks, inspections and tests of all fire safety systems and features provided. Ontario Fire Code definitions of key words are as follows:

- CHECK** Means a visual observation to ensure the device or system is in place, and is not obviously damaged or obstructed.
- INSPECT** Means physical examination to determine that the device or system will apparently perform in accordance with its intended function.
- TEST** Means the operation of a device or system to ensure that it will perform in accordance with its intended operation or function.

### **The building owner/manager must:**

Ensure that all fire protection features provided in each building are checked, inspected, tested and maintained in accordance with the frequencies specified in Division B Part 2 and Part 6 of the Fire Code and all applicable referenced standards.

When using in-house personnel to conduct some of these checks, inspections and tests, ensure that the person is fully trained and qualified to carry out the activity. Keep permanent records of all tests and corrective measures taken for a period of two years after they are made. The records are to be made available upon request to the Chief Fire Official.

## FIRE SAFETY MAINTENANCE DUTIES

### LEL, CARBON MONOXIDE, CARBON DIOXIDE, METHANE AND HYDROGEN SULPHIDE DETECTORS

(also reference manufacturer's instructions)

<b>Action</b>	<b>Frequency</b>	<b>Responsibility</b>
Maintain all types of detectors as recommended by the manufacturer.	Annually	Owner
Test alarm functions as recommended by the manufacturer.	Annually	Owner
Replace all detectors.	On a frequency prescribed by the manufacturer	Owner

## PORTABLE FIRE EXTINGUISHERS

NFPA 10 sets out details for maintenance guidelines for portable fire extinguishers.

<b>Action</b>	<b>Frequency</b>	<b>Responsibility</b>
Each extinguisher shall have a securely attached tag showing the maintenance or recharge date, the servicing agency, and the signature of the person who performed the service.	Annually	Contractor
A permanent record containing all the inspection and maintenance conducted on all of the portable fire extinguishers shall be maintained for a period of at least 2 years and be made available to the Chief Fire Official upon request.	Annually	Contractor
Portable extinguishers shall be inspected as follows: Check nozzle for operation and any obstructions Seal or tamper indicators are in place Pressure gauge is reading satisfactorily No apparent physical or mechanical damage Instructions for use on name plate are legible and face outward	Monthly	Owner
Extinguishers shall be subject to maintenance not more than one year apart or when specifically indicated by an inspection. Maintenance procedures shall include a thorough examination of the 3 basic elements of an extinguisher: mechanical parts, extinguishing agent and expelling means.	Annually	Contractor
Stored pressure extinguishers which require a 12 year hydrostatic test shall be emptied and subject to applicable maintenance procedures.	Every 6 years	Contractor
Hydrostatically test dry chemical and vaporizing liquid type extinguishers.	Every 12 years	Contractor

### **MEANS OF EGRESS**

<b>Action</b>	<b>Frequency</b>	<b>Responsibility</b>
Inspect all doors in fire separations.	Monthly	Owner
Check all doors and fire separations to ensure they are closed.	Daily	Owner
Maintain exit signs to ensure they are clean, legible, illuminated and in good repair.	Daily	Owner
Ensure corridors and exits are free of obstructions.	Daily	Owner

### **FIRE DEPARTMENT ACCESS**




<b>Action</b>	<b>Frequency</b>	<b>Responsibility</b>
Ensure that fire access routes are maintained so as to be immediately ready for use at all times by fire department vehicles.	Daily	Owner

### **ELECTRICAL DISCONNECT SWITCHES**

<b>Action</b>	<b>Frequency</b>	<b>Responsibility</b>
Disconnect switches for ventilating systems shall be inspected to establish that the system can shut down in an emergency.	Annually	Owner


## **SCHEMATICS**





LEGEND

	Portable Fire Extinguisher
	Gas Detectors
	Diverter Valves
	Electrical Panels
	Emergency Stop
	Diesel Fuel Tank (2200L)
	Propane
Grimsby Energy Inc. 442 Sobie Rd. <b>ANAEROBIC DIGESTER</b>	
	Building Layout July 2019
 <b>Trillium Fire Protection</b> 905-684-0196 mpdagnew@gmail.com	



**LEGEND**

-  Fire Hydrant
-  Gas Detectors
-  Diesel Fuel Tank
-  Propane Tank
-  Evacuation Meeting Place

Grimsby Energy Inc.  
442 Sobie Rd.

**ANAEROBIC DIGESTER**

Site Plan  
July 2019




Trilium Fire Protection  
905-684-0196  
mpdagnew@gmail.com

# **Appendix H**

## **As-Built Grading Plan**



SOBIE ROAD



# **Appendix I**

**Detailed Engineering and Equipment Documents**

Detail Engineering and Equipment Documents are pending final design